



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 18.08.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 17.08.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 17-अगस्त-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 17.08.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 18-Aug-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	72911	59492	47674	27343	3484	210904
Peak Shortage (MW)	75	590	0	263	0	928
Energy Met (MU)	1618	1403	1153	618	70	4862
Hydro Gen (MU)	377	120	170	90	33	790
Wind Gen (MU)	28	72	83	-	-	182
Solar Gen (MU)*	103.23	72.21	113.62	3.02	0.66	293
Energy Shortage (MU)	0.30	3.40	0.00	0.26	0.00	3.96
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	73361	60843	51798	28297	3463	214688
Time Of Maximum Demand Met	13:58	09:42	15:32	22:48	20:00	14:48

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.027	0.00	0.16	2.57	2.73	80.11	17.16

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	14194	0	289.7	183.4	-1.9	470	0.00
	Haryana	10802	0	232.4	168.0	-0.9	301	0.00
	Rajasthan	10977	0	236.5	59.7	-4.9	429	0.00
	Delhi	6179	0	132.6	113.0	1.3	286	0.00
	UP	27844	0	579.1	259.1	-1.8	372	0.00
	Uttarakhand	2395	75	53.0	25.6	0.5	171	0.27
	HP	1717	0	35.1	2.4	-1.7	31	0.00
	J&K(UT) & Ladakh(UT)	2316	0	48.6	23.4	0.8	265	0.03
	Chandigarh	330	0	6.6	6.3	0.3	65	0.00
WR	Railways_NR ISTS	203	0	4.1	3.7	0.4	50	0.00
	Chhattisgarh	5096	0	114.2	70.0	-1.7	299	0.00
	Gujarat	19114	0	419.4	167.6	-2.6	618	0.00
	MP	11412	457	249.0	127.7	0.1	500	2.58
	Maharashtra	24595	703	546.8	200.2	5.7	923	0.82
	Goa	671	0	14.8	11.7	2.7	104	0.00
	DNHDDPDCL	1265	0	28.7	28.8	-0.1	57	0.00
	AMNSIL	794	0	17.9	8.5	-0.3	216	0.00
	BALCO	522	0	12.5	12.5	0.0	30	0.00
SR	Andhra Pradesh	11112	0	227.9	90.3	0.3	684	0.00
	Telangana	12916	0	270.8	141.8	-1.8	628	0.00
	Karnataka	10472	0	212.7	52.1	-1.7	786	0.00
	Kerala	3995	0	82.4	46.8	1.0	471	0.00
	Tamil Nadu	16011	0	348.5	157.3	-2.8	826	0.00
	Puducherry	480	0	10.7	9.9	0.2	68	0.00
ER	Bihar	7599	0	162.2	151.4	-0.7	231	0.00
	DVC	3251	0	72.2	-38.7	0.1	244	0.00
	Jharkhand	2126	263	44.1	32.9	-0.5	255	0.26
	Odisha	5520	0	115.6	42.1	-3.1	361	0.00
	West Bengal	10351	0	222.5	88.3	-2.0	236	0.00
	Sikkim	69	0	1.2	1.2	0.0	18	0.00
	Railways_ER ISTS	3	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	176	0	3.0	2.9	-0.3	30	0.00
	Assam	2367	0	48.8	41.2	0.7	144	0.00
	Manipur	172	0	2.4	2.7	-0.3	24	0.00
	Meghalaya	310	0	5.5	-0.2	-0.1	75	0.00
	Mizoram	115	0	1.8	0.6	-0.1	16	0.00
	Nagaland	171	0	3.1	2.7	-0.1	26	0.00
	Tripura	269	0	5.0	3.8	-0.2	44	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	42.3	17.7	-21.7	-18.2
Day Peak (MW)	2120.0	775.8	-959.0	-771.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	313.3	-304.2	74.2	-89.3	6.0	0.0
Actual(MU)	300.8	-301.1	80.6	-90.8	4.0	-6.4
O/D/U/D(MU)	-12.5	3.1	6.5	-1.5	-1.9	-6.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3653	8697	3878	3896	597	20720	42
State Sector	5042	11612	9190	2522	141	28506	58
Total	8694	20309	13068	6418	738	49226	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	807	1427	607	678	15	3533	68
Lignite	27	10	52	0	0	89	2
Hydro	377	120	170	90	33	790	15
Nuclear	34	68	76	0	0	178	3
Gas, Naptha & Diesel	23	50	5	0	22	101	2
RES (Wind, Solar, Biomass & Others)	137	146	224	5	1	513	10
Total	1404	1823	1134	773	71	5204	100
Share of RES in total generation (%)	9.76	8.01	19.79	0.68	0.94	9.86	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.02	18.35	41.45	12.35	47.31	28.46	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.061

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	214688	14:48	0
Non-Solar hr	211690	19:43	1275

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 18-Aug-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	701	0.0	17.0	-17.0
2	HVDC	PUSAULI B/B	-	0	107	0.0	5.3	-5.3
3	765 kV	GAYA-VARANASI	2	561	531	0.0	2.9	-2.9
4	765 kV	SASARAM-FATEHPUR	1	253	272	0.0	2.2	-2.2
5	765 kV	GAYA-BALIA	1	0	641	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	0	163	0.0	2.8	-2.8
7	400 kV	PUSAULI -ALLAHABAD	1	59	18	0.3	0.0	0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	528	0.0	8.1	-8.1
9	400 kV	PATNA-BALIA	2	169	374	0.0	5.8	-5.8
10	400 kV	NAUBATPUR-BALIA	2	108	90	0.0	0.9	-0.9
11	400 kV	BIHARSHARIFF-BALIA	2	258	29	2.3	0.0	2.3
12	400 kV	MOTIHARI-GORAKHPUR	2	62	285	0.0	3.8	-3.8
13	400 kV	BIHARSHARIFF-VARANASI	2	156	188	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	53	0.6	0.1	0.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						3.7	57.3	-53.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	313	571	0.0	4.3	-4.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1875	0	26.8	0.0	26.8
3	765 kV	JHARSUGUDA-DURG	2	30	369	0.0	3.9	-3.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	475	0.0	6.3	-6.3
5	400 kV	RANCHI-SIPAT	2	447	87	4.2	0.0	4.2
6	220 kV	BUDHIPADAR-RAIGARH	1	30	64	0.0	0.5	-0.5
7	220 kV	BUDHIPADAR-KORBA	2	25	127	0.0	1.8	-1.8
ER-WR						31.1	16.8	14.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	522	0.0	12.5	-12.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1640	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2138	0.0	34.5	-34.5
4	400 kV	TALCHER-I/C	2	240	74	4.0	0.0	4.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	86.7	-86.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	301	0.0	4.0	-4.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	423	0.0	5.3	-5.3
3	220 kV	ALIPURDUAR-SALAKATI	2	0	90	0.0	1.4	-1.4
ER-NER						0.0	10.6	-10.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.4	-8.4
NER-NR						0.0	8.4	-8.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2502	0.0	58.8	-58.8
2	HVDC	VINDHYACHAL B/B	-	111	0	2.4	0.0	2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1449	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	1946	0.0	32.8	-32.8
5	765 kV	GWALIOR-PHAGI	2	408	1020	0.6	11.7	-11.1
6	765 kV	JABALPUR-ORAI	2	0	948	0.0	31.7	-31.7
7	765 kV	GWALIOR-ORAI	1	522	0	9.0	0.0	9.0
8	765 kV	SATNA-ORAI	1	0	857	0.0	17.9	-17.9
9	765 kV	BANASKANTHA-CHITORGARH	2	473	839	1.1	6.9	-5.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	3210	0.0	58.7	-58.7
11	400 kV	ZERDA-KANKROLI	1	161	131	1.2	0.7	0.4
12	400 kV	ZERDA -BHINMAL	1	111	91	0.8	0.5	0.3
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	294	255	1.4	2.0	-0.5
15	400 kV	NEEMUCH-Chittorgarh	2	214	327	0.2	3.3	-3.1
16	220 kV	BHANPURA-RANPUR	1	0	99	0.0	1.8	-1.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.1	-1.1
18	220 kV	MEHGAON-AURAIYA	1	80	24	0.6	0.1	0.6
19	220 kV	MALANPUR-AURAIYA	1	54	32	0.3	0.2	0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						17.7	264.4	-246.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	506	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	1002	0.0	24.1	-24.1
3	765 kV	SOLAPUR-RAICHUR	2	1934	582	16.0	0.7	15.3
4	765 kV	WARDHA-NIZAMABAD	2	0	2245	0.0	26.3	-26.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2048	0.0	22.3	-22.3
6	400 kV	KOLHAPUR-KUDGI	2	1767	0	27.4	0.0	27.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	112	2.3	0.0	2.3
WR-SR						45.6	85.4	-39.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	809	640	738	17.70
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	1003	793	871	20.91
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	108	0	58	1.38
	NER	132kV GELEPHU-SALAKATI	63	0	38	0.92
	NER	132kV MOTANGA-RANGIA	71	0	59	1.42
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	67	0	58	1.39
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	709	580	679	16.30
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-900	-717	-854	-20.50
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-771	-739	-757	-18.17
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-59	0	-51	-1.22

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06
Bangladesh	21.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.43
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.49

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.31	0.00	2.33	0.00	0.00	0.00	0.00	0.00	41.64
Nepal	2.53	0.00	13.68	0.00	0.00	0.00	0.00	0.00	16.21
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	41.84	0.00	16.01	0.00	0.00	0.00	0.00	0.00	57.85

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.31	0.00	2.33	0.00	0.00	0.00	0.00	0.00	41.64
Nepal	2.47	0.00	13.68	0.00	0.00	0.00	0.00	0.00	16.15
Bangladesh	-21.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.43
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	20.35	0.00	16.01	0.00	0.00	0.00	0.00	0.00	36.36