



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 09.11.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 08.11.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 8-नवंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 08.11.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 09-Nov-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55500	60869	45836	23248	2738	188191
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1245	1453	1098	479	51	4326
Hydro Gen (MU)	141	36	120	134	20	452
Wind Gen (MU)	13	32	37	-	-	83
Solar Gen (MU)*	150.47	91.10	106.19	3.35	1.03	352
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	59699	66706	51727	23930	2965	199924
Time Of Maximum Demand Met	18:20	10:43	11:58	18:02	17:33	10:56

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.43	7.00	7.43	84.23	8.34

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7379	0	147.5	71.6	0.4	382	0.00
	Haryana	7558	0	153.6	110.9	-0.5	260	0.00
	Rajasthan	16799	0	332.4	116.0	0.7	491	0.00
	Delhi	4243	0	82.8	74.7	-0.9	223	0.00
	UP	18881	0	388.9	154.6	-1.9	297	0.00
	Uttarakhand	2058	0	41.8	30.3	1.1	124	0.00
	HP	1965	0	35.8	23.4	-0.9	162	0.00
	J&K(UT) & Ladakh(UT)	2682	0	54.4	47.4	-0.2	229	0.00
	Chandigarh	210	0	4.0	3.9	0.1	51	0.00
WR	Railways_NR ISTS	190	0	3.9	3.9	0.0	23	0.00
	Chhattisgarh	4566	0	96.5	36.2	-0.6	268	0.00
	Gujarat	19864	0	404.9	212.4	0.0	848	0.00
	MP	15409	0	305.2	177.0	-2.5	627	0.00
	Maharashtra	26033	0	570.7	228.1	2.5	570	0.00
	Goa	719	0	15.1	14.6	-0.1	140	0.00
	DNHDDPDCL	1313	0	29.9	30.0	-0.1	39	0.00
	AMNSIL	822	0	18.0	8.8	0.5	281	0.00
SR	BALCO	532	0	12.7	12.7	0.0	8	0.00
	Andhra Pradesh	10601	0	218.3	76.5	-0.6	578	0.00
	Telangana	10479	0	207.4	96.4	-0.2	485	0.00
	Karnataka	12873	0	243.5	106.1	2.4	556	0.00
	Kerala	4198	0	85.2	66.0	0.9	262	0.00
	Tamil Nadu	16243	0	334.0	204.0	2.2	871	0.00
	Puducherry	450	0	10.0	9.5	-0.1	31	0.00
ER	Bihar	5050	0	96.4	87.8	-1.6	0	0.00
	DVC	3218	0	65.4	-41.8	-0.2	0	0.00
	Jharkhand	1908	0	37.3	25.6	-1.4	0	0.00
	Odisha	5221	0	105.8	30.2	-1.5	0	0.00
	West Bengal	8723	0	172.4	41.9	-2.3	0	0.00
	Sikkim	98	0	1.6	1.5	0.1	0	0.00
	Railways_ER ISTS	15	0	0.1	0.1	0.0	0	0.00
NER	Arunachal Pradesh	137	0	2.5	2.5	-0.3	22	0.00
	Assam	1754	0	31.0	23.5	0.4	118	0.00
	Manipur	209	0	2.4	2.7	-0.3	33	0.00
	Meghalaya	352	0	6.3	5.0	-0.1	84	0.00
	Mizoram	118	0	1.9	1.4	-0.3	6	0.00
	Nagaland	160	0	2.4	2.1	0.0	14	0.00
	Tripura	258	0	4.5	5.3	0.1	36	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	7.9	12.0	-23.2	-12.2
Day Peak (MW)	563.0	576.2	-975.0	-511.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	255.7	-203.6	173.9	-227.4	1.4	0.0
Actual(MU)	248.0	-203.5	176.7	-233.0	-0.4	-12.1
O/D/U/D(MU)	-7.8	0.1	2.9	-5.5	-1.8	-12.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4502	7749	6098	2076	597	21021	42
State Sector	7578	9656	10111	1949	230	29524	58
Total	12080	17405	16209	4025	827	50545	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	713	1547	575	735	15	3586	74
Lignite	27	18	56	0	0	101	2
Hydro	141	36	120	134	20	452	9
Nuclear	35	52	76	0	0	164	3
Gas, Naptha & Diesel	9	11	5	0	20	46	1
RES (Wind, Solar, Biomass & Others)	174	127	168	5	1	475	10
Total	1101	1792	1000	874	57	4823	100

Share of RES in total generation (%)	15.85	7.10	16.75	0.54	1.92	9.85
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.89	12.02	36.40	15.83	37.92	22.60

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.025
Based on State Max Demands	1.066

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	199924	10:56	0
Non-Solar hr	199086	18:26	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 09-Nov-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	301	0.0	7.5	-7.5
2	HVDC	PUSAULI B/B	-	0	297	0.0	7.3	-7.3
3	765 kV	GAYA-VARANASI	2	31	1249	0.0	18.5	-18.5
4	765 kV	SASARAM-FATEHPUR	1	24	610	0.0	8.7	-8.7
5	765 kV	GAYA-BALIA	1	0	607	0.0	12.0	-12.0
6	400 kV	PUSAULI-VARANASI	1	0	205	0.0	3.7	-3.7
7	400 kV	PUSAULI -ALLAHABAD	1	0	180	0.0	3.5	-3.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	17	683	0.0	8.8	-8.8
9	400 kV	PATNA-BALIA	2	0	1059	0.0	19.5	-19.5
10	400 kV	NAUBATPUR-BALIA	2	0	350	0.0	6.2	-6.2
11	400 kV	BIHARSHARIFF-BALIA	2	161	194	0.0	1.9	-1.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	568	0.0	9.2	-9.2
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	109	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	107.6	-107.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	367	401	1.3	0.0	1.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	529	787	2.0	0.0	2.0
3	765 kV	JHARSUGUDA-DURG	2	0	996	0.0	19.0	-19.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	686	0.0	9.9	-9.9
5	400 kV	RANCHI-SIPAT	2	82	340	0.0	3.5	-3.5
6	220 kV	BUDHIPADAR-RAIGARH	1	0	110	0.0	1.1	-1.1
7	220 kV	BUDHIPADAR-KORBA	2	122	60	0.6	0.0	0.6
ER-WR						3.9	33.5	-29.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	528	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1993	0.0	48.1	-48.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2902	0.0	56.8	-56.8
4	400 kV	TALCHER-I/C	2	0	222	0.0	3.9	-3.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	117.5	-117.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	562	0.0	9.2	-9.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	755	0.0	11.8	-11.8
3	220 kV	ALIPURDUAR-SALAKATI	2	0	123	0.0	2.1	-2.1
ER-NER						0.0	23.0	-23.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	1005	0.0	24.1	-24.1
NER-NR						0.0	24.1	-24.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1013	0.0	23.3	-23.3
2	HVDC	VINDHYACHAL B/B	-	140	104	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1447	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	3	1313	0.0	19.6	-19.6
5	765 kV	GWALIOR-PHAGI	2	382	1988	0.7	29.2	-28.6
6	765 kV	JABALPUR-ORAI	2	0	818	0.0	27.6	-27.6
7	765 kV	GWALIOR-ORAI	1	896	0	15.5	0.0	15.5
8	765 kV	SATNA-ORAI	1	0	1011	0.0	21.6	-21.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1686	0	24.5	0.0	24.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	2148	0.0	34.4	-34.4
11	400 kV	ZERDA-KANKROLI	1	370	0	5.3	0.0	5.3
12	400 kV	ZERDA -BHINMAL	1	260	0	3.8	0.0	3.8
13	400 kV	VINDHYACHAL -RIHAND	1	973	0	22.4	0.0	22.4
14	400 kV	RAPP-SHUJALPUR	2	612	179	3.1	1.0	2.1
15	400 kV	NEEMUCH-Chittorgarh	2	0	0	2.2	0.0	2.2
16	220 kV	BHANPURA-RANPUR	1	0	189	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	57	0	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	78	0	0.9	0.0	0.9
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						79.9	201.2	-121.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	20.7	-20.7
2	HVDC	RAIGARH-PUGALUR	2	0	2504	0.0	44.8	-44.8
3	765 kV	SOLAPUR-RAICHUR	2	822	1075	3.8	7.3	-3.6
4	765 kV	WARDHA-NIZAMABAD	2	0	1933	0.0	30.1	-30.1
5	765 kV	WARORA-WARANGAL(NEW)	2	600	219	0.0	37.9	-37.9
6	400 kV	KOLHAPUR-KUDGI	2	1396	0	23.8	0.0	23.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	110	1.5	0.0	1.5
WR-SR						29.1	140.8	-111.7

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	191	123	152	3.65
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	281	137	221	5.29
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-157	0	-80	-1.91
	NER	132kV GELEPHU-SALAKATI	16	0	10	0.25
	NER	132kV MOTANGA-RANGIA	74	0	27	0.64
NEPAL	NR	NEPAL IMPORT (FROM UP)	-9	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	67	0	60	1.45
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	509	326	441	10.59
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-918	-913	-916	-21.99
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-511	-497	-508	-12.19
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-57	0	-51	-1.22

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 09-Nov-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	22.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.86
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.86

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	7.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.49
Nepal	0.00	0.00	0.00	0.00	0.00	10.86	0.00	0.00	10.86
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	7.49	0.00	0.00	0.00	0.00	10.86	0.00	0.00	18.35

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	7.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.49
Nepal	0.00	0.00	0.00	0.00	0.00	10.86	0.00	0.00	10.86
Bangladesh	-22.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.86
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-15.37	0.00	0.00	0.00	0.00	10.86	0.00	0.00	-4.51

Date of Reporting: 09-Nov-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-C-H)	(J=B+C+D+E)	(+ve) Import, (-ve) (K)
0:00	50.05	163031	6520	4369	42	11806	1873	140646	1336	158620	166592	-71
0:15	50.05	162165	6509	4377	42	11477	1877	140193	1341	157746	165816	-41
0:30	50.05	161356	6517	4306	42	11131	1855	139697	1390	157008	164938	-57
0:45	49.95	160471	6505	4265	42	10770	1877	139139	1369	156164	163967	-55
1:00	50.00	159208	6518	4247	41	10570	1873	138140	1365	154920	162754	-51
1:15	50.00	157982	6533	4260	41	10649	1878	137246	1361	153681	161968	-59
1:30	49.95	157576	6529	4202	41	10721	1879	136623	1351	153333	161346	-50
1:45	50.00	156323	6509	4132	41	10701	1861	135450	1384	152150	160078	-45
2:00	50.00	155614	6530	4141	41	10582	1872	134859	1373	151432	159398	-31
2:15	49.95	155108	6527	4129	41	10549	1877	134231	1356	150938	158710	-27
2:30	49.95	154729	6542	4231	41	10162	1877	134070	1379	150457	158302	-6
2:45	49.90	154372	6528	4327	41	9721	1887	133999	1404	150004	157907	-3
3:00	49.95	154540	6521	4433	41	10109	1875	133896	1349	150066	158224	-8
3:15	49.90	153785	6521	4551	38	9924	1875	133142	1320	149196	157371	-6
3:30	49.95	153932	6537	4645	37	9793	1877	133331	1366	149250	157586	-10
3:45	50.00	153786	6536	4668	37	9752	1870	133384	1351	149081	157598	-54
4:00	50.00	153798	6533	4652	38	9910	1879	133225	1333	149108	157570	-55
4:15	49.95	154955	6526	4458	39	10518	1873	134002	1363	150458	158779	-127
4:30	50.00	155856	6530	4502	38	11147	1897	134272	1378	151316	159764	-129
4:45	50.00	156926	6529	4530	39	11024	1899	135289	1380	152357	160690	-34
5:00	50.05	158175	6522	4567	39	10922	1905	136617	1343	153569	161915	-44
5:15	50.05	160812	6535	4572	42	12086	1896	138166	1379	156198	164676	-58
5:30	50.05	163935	6527	4461	42	13643	1876	139859	1422	159432	167830	-73
5:45	50.05	165810	6535	4426	43	14580	1899	140879	1427	161341	169789	-101
6:00	50.05	167971	6548	4382	42	16641	1873	141186	1420	163547	172092	-268
6:15	50.05	171645	6531	4238	65	19151	1932	142267	1419	167342	175603	-149
6:30	50.05	176043	6540	4196	273	21378	1872	144204	1383	171574	179846	-130
6:45	50.05	179789	6539	4109	822	22692	1880	145907	1415	174858	183364	-139
7:00	49.94	182473	6535	3981	1870	22919	1923	147189	1355	176622	185772	-131
7:15	49.94	184371	6539	3825	3604	22903	1903	147176	1421	176942	187371	-105
7:30	50.04	185941	6538	3713	6473	22408	1928	146409	1457	175755	188926	-28
7:45	49.99	186567	6546	3454	10319	19201	1930	146753	1497	172794	189700	-36
8:00	50.10	186354	6538	3180	14551	17131	1892	144636	1543	168623	189471	-63
8:15	50.04	188339	6553	2869	19585	16029	1897	142883	1580	165885	191396	47
8:30	49.99	189669	6544	2662	23781	14519	1878	141528	1562	163226	192474	-12
8:45	49.99	190722	6560	2537	27591	13528	1881	139656	1583	160594	193336	-15
9:00	50.04	191741	6536	2441	31324	12748	1902	137577	1598	157976	194126	28
9:15	49.99	195258	6539	2416	34480	11627	1887	138997	1653	158362	197599	35
9:30	49.99	197200	6530	2493	37689	11277	1890	137830	1632	157018	199341	23
9:45	49.99	198004	6537	2569	40298	10425	1874	136999	1707	155137	200409	-15
10:00	50.04	198237	6499	2623	42296	10464	1873	135234	1701	153318	200690	-14
10:15	49.99	198865	6511	2608	44293	10448	1857	133854	1692	151964	201263	-9
10:30	49.99	199482	6502	2590	45304	10624	1892	133362	1700	151588	201974	9
10:45	0.00	199512	6514	2583	46575	10948	1844	132118	1634	150354	202216	12
11:00	50.04	199354	6538	2712	47438	10720	1863	130864	1659	149204	201794	-33
11:15	49.99	198496	6524	2673	47979	10381	1867	129965	1714	147844	201103	-47
11:30	49.99	198572	6506	2820	48542	10277	1859	129393	1686	147210	201083	-28
11:45	49.99	198119	6530	2843	48678	10224	1903	128836	1729	146598	200743	-32
12:00	49.94	198003	6515	2820	48881	9977	1848	128796	1735	146302	200572	-48
12:15	49.98	196887	6504	2793	48638	9704	1881	128102	1746	145456	199368	-44
12:30	49.93	196405	6532	2759	48676	9409	1887	127862	1723	144970	198848	-34
12:45	50.03	195814	6513	2768	48167	9251	1898	127997	1741	144879	198335	-29
13:00	49.98	194063	6521	2803	47943	9101	1894	126741	1720	143317	196723	-48
13:15	50.03	190738	6520	2805	47083	8422	1893	125180	1643	140850	193546	-64
13:30	50.03	190592	6507	2703	46151	8323	1826	126129	1657	141738	193296	-52
13:45	49.93	191239	6515	2509	45109	8451	1886	127768	1715	143621	193953	-44
14:00	49.98	191530	6498	2196	44516	8670	1874	128688	1664	144818	194106	-59
14:15	49.93	192343	6493	2288	42685	8752	1877	131358	1694	147370	195147	-227
14:30	49.93	193769	6493	2232	40884	9136	1876	134193	1680	150653	196494	-185
14:45	49.88	194881	6521	2190	38561	9606	1870	137153	1683	154130	197584	-74
15:00	49.93	195509	6506	2023	36203	10310	1871	139668	1666	157283	198247	-48
15:15	49.93	194676	6519	1754	33420	11218	1866	141198	1613	159502	197588	-33
15:30	49.88	194814	6504	1562	30671	11939	1846	143279	1626	162581	197427	-74
15:45	49.93	195146	6523	1448	27471	13561	1864	145571	1589	166227	198027	-14
16:00	50.03	194860	6520	1556	24215	14386	1852	147549	1555	169089	197633	-16
16:15	49.98	192767	6532	1615	20445	14034	1857	149425	1555	170707	195463	-44
16:30	50.03	193934	6524	1652	16525	15469	1878	152988	1532	175757	196568	-16
16:45	49.93	193778	6526	1704	12262	16913	1857	155558	1550	179812	196370	-51
17:00	49.98	194587	6521	1646	8364	18820	1882	158394	1469	184577	197096	-96
17:15	49.83	192954	6531	1735	4925	20404	1854	159012	1422	186294	195883	-192
17:30	49.98	194639	6522	1896	2423	24012	1862	159722	1514	190320	197951	-216
17:45	49.83	196699	6540	2170	924	26051	1913	160774	1451	193605	199823	-233
18:00	49.88	198198	6522	2320	407	28074	1928	161162	1473	195471	201886	-219
18:15	49.93	198356	6534	2544	318	28490	1866	160437	1462	195494	201651	-221
18:30	50.03	198958	6547	2700	230	28553	1873	160769	1440	196028	202112	-206
18:45	50.03	197534	6542	2892	235	27860	1880	159984	1461	194407	200854	-179
19:00	50.03	195015	6496	3039	238	26264	1856	158718	1499	191738	198110	-156
19:15	50.03	192730	6475	3121	230	25657	1812	157137	1439	189379	195871	-158
19:30	50.03	189913	6494	3178	93	24541	1828	155447	1433	186642	193014	-165
19:45	50.03	186884	6489	3225	96	21614	1815	155338	1464	183563	190041	-157
20:00	50.03	183635	6488	3168	94	20412	1823	153227	1445	180373	186657	-141
20:15	50.03	181225	6487	3236	83	19338	1838	151888	1447	177906	184317	-119
20:30	50.03	179759	6498	3256	82	18567	1825	151239	1439	176421	182906	-136
20:45	49.98	178578	6484	3252	85	18400	1823	150261	1389	175241	181694	-119
21:00	50.03	176336	6494	3284	115	18014	1824	148457	1393	172937	179581	-87
21:15	49.98	175276	6500	3336	116	17088	1825	148153	1440	171824	178458	-106
21:30	49.98	174307	6493	3411	120	16304	1833	147762	1411	170776	177334	-93
21:45	50.03	173332	6498	3471	120	16094	1823	146762	1453	169741	176221	-66
22:00	50.03	171550	6489	3598	121	14803	1824	146272	1409	167831	174516	-113
22:15	49.88	171155	6490	3640	121	13875	1827	146607	1397	167394	173957	-73
22:30	49.93	171488	6485	3603	123	14201	1838	146479	1434	167762	174163	-93
22:45	49.98	170993	6487	3685	123	13613	1825	14				