



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 16.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 15.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 15-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 15.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 16-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60875	61015	39010	22634	2609	186143
Peak Shortage (MW)	0	129	0	0	0	129
Energy Met (MU)	1224	1447	1039	462	47	4219
Hydro Gen (MU)	88	47	83	20	11	249
Wind Gen (MU)	26	128	112	-	-	266
Solar Gen (MU)*	141.83	84.32	97.06	2.29	1.15	327
Energy Shortage (MU)	0.00	1.60	0.00	0.00	0.00	1.60
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64882	74075	54933	23654	2765	216777
Time Of Maximum Demand Met	10:41	10:00	09:38	17:58	19:06	09:56

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.026	0.00	0.00	3.02	3.02	82.61	14.37

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8172	0	138.5	76.0	-0.2	645	0.00
	Haryana	8139	0	156.0	108.7	-0.8	354	0.00
	Rajasthan	17898	0	314.8	97.8	-5.0	507	0.00
	Delhi	5275	0	88.2	82.1	-2.7	440	0.00
	UP	20625	0	366.9	148.6	-4.6	329	0.00
	Uttarakhand	2375	0	45.5	37.8	-0.3	164	0.00
	HP	2136	0	38.7	32.3	-0.5	152	0.00
	J&K(UT) & Ladakh(UT)	3115	0	67.0	65.0	-2.2	867	0.00
	Chandigarh	307	0	4.6	4.5	0.2	65	0.00
WR	Railways_NR ISTS	209	0	4.2	3.8	0.3	46	0.00
	Chhattisgarh	5364	0	110.6	63.0	1.8	307	0.00
	Gujarat	19438	0	347.4	167.7	-2.0	1108	0.00
	MP	17859	172	324.4	212.5	-0.5	557	1.60
	Maharashtra	28954	0	589.4	227.8	-0.6	673	0.00
	Goa	754	0	15.1	14.6	0.0	72	0.00
	DNHDDPDCL	1330	0	29.6	29.6	0.0	64	0.00
	AMNSIL	765	0	17.0	7.9	0.3	268	0.00
	BALCO	531	0	12.7	12.7	0.0	9	0.00
SR	RIL JAMNAGAR	110	0	1.0	1.0	0.0	0	0.00
	Andhra Pradesh	10104	0	182.8	29.0	-1.2	915	0.00
	Telangana	13900	0	248.0	140.2	-2.1	627	0.00
	Karnataka	15794	0	273.6	86.9	-1.5	620	0.00
	Kerala	4385	0	88.0	70.6	0.6	737	0.00
	Tamil Nadu	12012	0	239.9	118.1	-3.0	558	0.00
	Puducherry	305	0	6.8	6.5	-0.2	27	0.00
ER	Bihar	5461	0	98.9	90.3	-3.5	375	0.00
	DVC	3239	0	69.9	-35.5	-0.9	346	0.00
	Jharkhand	1950	0	37.4	30.0	-0.9	232	0.00
	Odisha	5214	0	103.3	35.2	-1.0	417	0.00
	West Bengal	7369	0	149.8	33.1	-0.8	185	0.00
	Sikkim	116	0	2.0	2.2	-0.1	32	0.00
	Railways_ER ISTS	18	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	183	0	3.2	3.0	0.1	25	0.00
	Assam	1424	0	24.6	17.5	0.3	151	0.00
	Manipur	275	0	4.0	4.1	-0.1	148	0.00
	Meghalaya	376	0	6.5	4.9	-0.2	118	0.00
	Mizoram	157	0	2.3	1.9	-0.1	18	0.00
	Nagaland	155	0	2.5	2.4	0.0	17	0.00
	Tripura	229	0	4.0	3.3	0.1	40	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.7	-7.2	-22.3	-11.5
Day Peak (MW)	-410.0	-430.2	-999.0	-730.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	291.4	-230.4	67.4	-130.6	2.2	0.0
Actual(MU)	283.7	-216.2	49.1	-127.7	0.6	-10.5
O/D/U/D(MU)	-7.7	14.2	-18.3	2.9	-1.6	-10.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6169	6419	5208	3833	698	22326	37
State Sector	10043	17185	6593	4479	221	38520	63
Total	16212	23603	11801	8312	918	60846	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	682	1436	603	649	14	3383	74
Lignite	29	18	44	0	0	91	2
Hydro	88	47	83	20	11	249	5
Nuclear	26	54	71	0	0	151	3
Gas, Naptha & Diesel	9	12	12	0	25	57	1
RES (Wind, Solar, Biomass & Others)	194	215	235	6	1	650	14
Total	1028	1781	1047	675	51	4582	100

Share of RES in total generation (%)	18.86	12.05	22.42	0.83	2.31	14.19
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.00	17.72	37.07	3.85	24.26	22.93

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.042

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	216777	9:56	320
Non-Solar hr	193705	18:41	232

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 16-Jan-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.2	-1.2
3	765 kV	GAYA-VARANASI	2	209	1122	0.0	13.5	-13.5
4	765 kV	SASARAM-FATEHPUR	1	32	702	0.0	9.1	-9.1
5	765 kV	GAYA-BALIA	1	0	973	0.0	15.0	-15.0
6	400 kV	PUSAULI-VARANASI	1	1	114	0.0	1.0	-1.0
7	400 kV	PUSAULI -ALLAHABAD	1	68	44	0.0	0.0	0.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	16	796	0.0	9.9	-9.9
9	400 kV	PATNA-BALIA	2	0	1020	0.0	16.6	-16.6
10	400 kV	NAUBATPUR-BALIA	2	0	705	0.0	5.3	-5.3
11	400 kV	BIHARSHARIFF-BALIA	2	20	339	0.0	6.7	-6.7
12	400 kV	MOTIHARI-GORAKHPUR	2	0	611	0.0	9.3	-9.3
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	109	0.0	2.9	-2.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	90.5	-89.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	454	859	0.0	0.7	-0.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	948	181	11.8	0.0	11.8
3	765 kV	JHARSUGUDA-DURG	2	0	952	0.0	14.2	-14.2
4	400 kV	JHARSUGUDA-RAIGARH	4	0	607	0.0	7.7	-7.7
5	400 kV	RANCHI-SIPAT	2	216	139	1.8	0.0	1.8
6	220 kV	BUDHIPADAR-RAIGARH	1	19	80	0.0	0.8	-0.8
7	220 kV	BUDHIPADAR-KORBA	2	91	71	0.6	0.0	0.6
ER-WR						14.1	23.4	-9.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1200	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2576	0.0	40.6	-40.6
4	400 kV	TALCHER-I/C	2	213	386	1.0	0.0	1.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	74.7	-74.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	293	0	4.5	0.0	4.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	503	0	8.2	0.0	8.2
3	220 kV	ALIPURDUAR-SALAKATI	2	112	0	1.8	0.0	1.8
ER-NER						14.5	0.0	14.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3543	0.0	49.1	-49.1
2	HVDC	VINDHYACHAL B/B	-	325	100	0.0	1.3	-1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	495	0.0	12.4	-12.4
4	765 kV	GWALIOR-AGRA	2	0	3167	0.0	40.6	-40.6
5	765 kV	GWALIOR-PHAGI	2	381	2002	0.4	23.7	-23.3
6	765 kV	JABALPUR-ORAI	2	0	1521	0.0	40.3	-40.3
7	765 kV	GWALIOR-ORAI	1	781	0	12.9	0.0	12.9
8	765 kV	SATNA-ORAI	1	0	1284	0.0	20.8	-20.8
9	765 kV	BANASKANTHA-CHITORGARH	2	357	1279	1.5	10.3	-8.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	3514	0.0	50.3	-50.3
11	400 kV	ZERDA-KANKROLI	1	142	176	0.7	1.2	-0.5
12	400 kV	ZERDA -BHINMAL	1	98	122	0.5	0.9	-0.4
13	400 kV	VINDHYACHAL -RIHAND	1	982	0	19.7	0.0	19.7
14	400 kV	RAPP-SHUJALPUR	2	526	575	2.5	3.5	-1.0
15	400 kV	NEEMUCH-Chittorgarh	2	706	537	3.8	2.3	1.5
16	220 kV	BHANPURA-RANPUR	1	0	154	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	81	25	0.6	0.1	0.5
19	220 kV	MALANPUR-AURAIYA	1	50	44	0.3	0.3	0.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						42.9	261.0	-218.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	303	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	0	913	0.0	17.1	-17.1
3	765 kV	SOLAPUR-RAICHUR	2	1913	503	15.0	1.1	13.9
4	765 kV	WARDHA-NIZAMABAD	2	568	2048	0.8	24.5	-23.8
5	765 kV	WARORA-WARANGAL(NEW)	2	515	2057	0.6	23.2	-22.7
6	400 kV	KOLHAPUR-KUDGI	2	1819	0	33.1	0.0	33.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	124	2.3	0.0	2.3
WR-SR						58.9	65.9	-7.1

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	187	31	82	1.97	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-200	91	-69	-1.65	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-243	-103	-187	-4.48	
	NER	132kV GELEPHU-SALAKATI	-27	-6	-16	-0.39	
	NER	132kV MOTANGA-RANGIA	-31	-6	-7	-0.16	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-60	0	-39	-0.94	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-60	0	-38	-0.90	
	ER	NEPAL IMPORT (FROM BIHAR)	-162	-34	-77	-1.85	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-268	-28	-144	-3.46	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-935	-645	-880	-21.12	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-730	50	-480	-11.52	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-51	-1.22	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.22	5.13	0.00	0.00	0.60	0.00	0.00	5.95
Nepal	2.12	0.00	3.76	0.00	0.00	0.60	0.00	0.00	6.48
Bangladesh	21.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.97
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.09	0.22	8.89	0.00	0.00	1.20	0.00	0.00	34.40

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.81
Nepal	0.00	0.00	0.00	0.00	0.00	0.30	0.00	0.00	0.30
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.81	0.00	0.00	0.00	0.00	0.30	0.00	0.00	1.11

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.81	-0.22	-5.13	0.00	0.00	-0.60	0.00	0.00	-5.14
Nepal	-2.12	0.00	-3.76	0.00	0.00	-0.30	0.00	0.00	-6.18
Bangladesh	-21.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.97
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.28	-0.22	-8.89	0.00	0.00	-0.90	0.00	0.00	-33.29

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												Date of Reporting: 16 Jan 2025
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.08	143215	5913	16650	58	5486	2339	114169	3060	126507	147675	-1487
0:15	49.98	141711	5911	16625	62	5258	2320	112281	3019	125024	145476	-1476
0:30	49.93	140519	5902	16282	57	5470	2151	111410	3031	124180	144303	-1463
0:45	49.93	139922	5911	16162	54	5382	2149	111143	3016	123706	143817	-1369
1:00	49.98	139128	5901	15814	48	5295	2329	110879	3027	123266	143293	-1283
1:15	49.93	137921	5908	15423	53	5466	2337	109379	3011	122445	141577	-1253
1:30	49.98	136720	5911	15019	53	5444	2323	108594	3026	121648	140370	-1207
1:45	50.03	136011	5896	14931	58	5388	2316	108092	3088	121022	139769	-1243
2:00	50.03	135262	5913	14789	65	5279	2330	107717	3019	120408	139112	-1240
2:15	49.98	134775	5927	14474	64	5133	2332	107801	3029	120237	138760	-1290
2:30	50.03	134760	5893	14019	66	5218	2330	108155	3026	120675	138707	-1285
2:45	49.98	134278	5886	13695	65	5296	2147	108219	3006	120518	138314	-1253
3:00	49.98	133851	5912	13302	59	5336	2332	108182	3027	120490	138150	-1295
3:15	49.98	134116	5907	13110	60	5341	2347	108547	2977	120946	138289	-1215
3:30	49.98	134396	5902	12998	54	5309	2358	108684	2960	121344	138265	-1202
3:45	49.98	134292	5919	12639	54	5258	2387	109125	2932	121599	138314	-1180
4:00	49.98	134800	5910	12378	52	5214	2198	109988	2959	122370	138699	-1195
4:15	49.98	136850	5907	11833	51	5741	2191	112282	2920	124966	140925	-1195
4:30	49.98	137987	5913	11549	54	5871	2435	113731	2921	126384	142474	-1208
4:45	50.03	139630	5924	11023	56	6432	2447	115420	2900	128551	144202	-1302
5:00	50.03	141622	5914	10865	60	6244	2230	117654	2909	130697	145876	-1338
5:15	49.98	145807	5904	10940	61	6389	2440	121734	2881	134806	150349	-1317
5:30	50.03	149440	5897	10904	58	6639	2472	125334	2843	138478	154147	-1341
5:45	50.03	153883	5900	10950	60	7628	2476	128759	2861	142873	158634	-1357
6:00	50.08	156922	5900	10779	56	7737	2236	131797	2918	146087	161423	-1373
6:15	49.98	161976	5899	10796	205	8603	2195	135384	2899	150975	165981	-1275
6:30	50.03	168860	5897	10832	206	10479	2162	140950	2936	157822	173462	-1365
6:45	50.03	175001	5910	10909	214	12742	2306	144532	2857	163878	179470	-1255
7:00	50.03	180528	5906	11150	366	14655	2427	147282	2852	169012	184638	-1284
7:15	49.93	186336	5909	11161	803	16394	2274	150615	2912	174372	190068	-1259
7:30	50.03	192021	5904	11068	1718	17954	2505	154218	2901	179235	196268	-1259
7:45	50.03	195632	5911	10835	3184	19328	2499	154939	2855	181613	199551	-1254
8:00	50.03	197978	5890	10675	4992	20105	2500	154841	2910	182311	201913	-1187
8:15	49.98	202973	5907	10473	7765	21232	2504	155912	2976	184735	206769	-1167
8:30	50.08	205080	5910	10307	11100	21167	2261	154983	3003	183673	208731	-1191
8:45	50.08	207596	5907	10164	14896	19623	2498	155126	2949	182536	211163	-1202
9:00	50.13	208928	5905	10159	18779	17907	2249	154347	2979	179990	212325	-1239
9:15	50.03	214181	5910	10103	22825	16533	2288	156894	2943	181253	217496	-1173
9:30	50.03	215599	5891	9866	25764	15651	2491	156669	2927	179969	219259	-1196
9:45	49.98	216643	5886	9322	28769	13706	2352	156671	2934	178552	219640	-1300
10:00	50.03	216564	5883	9326	31553	12043	2366	155342	2918	175685	219431	-1352
10:15	49.88	215257	5866	9324	34938	8763	2352	154802	2903	170995	218948	-1379
10:30	50.03	215960	5885	9443	38368	8130	2265	152643	2862	168149	219596	-1382
10:45	50.03	215575	5879	9472	41295	7956	2448	149034	2779	164808	218863	-1375
11:00	49.98	214213	5900	9543	43624	7630	2416	145909	2804	161046	217826	-1378
11:15	50.03	212871	5884	9604	45170	7678	2359	142615	2776	158097	216086	-1621
11:30	50.03	211417	5887	9873	46551	7629	2359	140329	2799	154993	215427	-1752
11:45	50.03	209755	5911	10130	47673	7543	2221	137660	2787	151952	213925	-1697
12:00	50.03	207781	5882	9943	48954	6829	2226	134378	2724	148884	210936	-1688
12:15	50.03	206085	5893	10160	49520	6063	2356	133618	2759	146405	210369	-1709
12:30	49.98	205465	5890	10148	49478	6469	2334	132099	2757	145839	209175	-1733
12:45	49.98	203725	5879	9825	49545	6911	2343	130344	2705	144355	207552	-1784
13:00	50.03	201063	5876	9547	49859	6618	2349	128185	2713	141657	205147	-1819
13:15	49.93	197424	5891	9617	48757	5978	2356	125892	2721	139050	201212	-1761
13:30	50.03	196398	5890	9501	48296	6264	2358	124897	2703	138601	199909	-1788
13:45	49.98	195973	5883	9460	47361	6459	2360	125317	2660	139152	199500	-1806
14:00	49.98	194870	5876	9149	46349	6275	2361	125808	2677	139372	198495	-1823
14:15	49.98	194247	5881	9096	44907	6361	2242	126587	2603	140244	197677	-1868
14:30	49.98	194513	5855	8878	43448	6218	2372	129061	2672	142187	198504	-1868
14:45	49.83	193849	5879	8799	40535	6391	2234	130810	2591	144515	197239	-1852
15:00	49.88	194223	5876	8582	38571	6853	2223	133046	2592	147070	197743	-1857
15:15	49.88	193798	5873	8485	35944	6861	2377	135925	2595	149369	198060	-1790
15:30	50.03	193783	5887	8303	33301	7257	2356	138026	2515	152179	197645	-1791
15:45	50.03	193567	5878	8359	30562	8225	2372	139259	2496	154646	197151	-1741
16:00	50.03	192544	5896	8445	27035	9211	2370	140312	2571	157064	195840	-1777
16:15	49.98	190405	5861	8674	23378	9466	2392	141986	2480	158353	194237	-1700
16:30	50.03	190512	5865	8630	19748	10521	2227	144916	2440	162134	194347	-1422
16:45	50.03	189914	5888	8778	15989	10869	2206	146642	2473	165147	192845	-1219
17:00	50.08	189134	5897	8821	12041	12200	2195	149240	2470	168272	192864	-1130
17:15	50.03	187283	5893	8757	8275	13734	2425	149806	2513	170251	191403	-1071
17:30	50.08	188630	5878	8672	5224	16924	2186	151459	2487	174734	192830	-1102
17:45	50.03	190195	5890	8655	3278	18346	2437	152683	2476	178262	193765	-1064
18:00	50.03	190562	5892	8756	2019	19159	2458	154196	2480	179787	194960	-1073
18:15	49.93	192469	5881	8721	1486	20075	2314	155721	2477	182262	196675	-1081
18:30	50.03	193331	5899	8851	573	20867	2321	156241	2487	183907	197239	-1104
18:45	50.03	193363	5907	9065	521	21370	2516	155800	2501	183777	197680	-1050
19:00	50.08	191589	5905	9493	418	19709	2498	155566	2510	181678	196099	-1026
19:15	50.03	190389	5897	9908	256	18116	2232	155557	2522	180225	194488	-1007
19:30	50.03	188815	5909	10355	416	16768	2129	154943	2510	178044	193030	-1009
19:45	50.03	185884	5899	10630	410	15048	2247	153612	2471	174844	190317	-979
20:00	50.03	182453	5897	10811	411	13747	2231	151171	2475	171231	186743	-1040
20:15	50.03	180083	5901	10944	411	13212	2120	148990	2607	168728	184185	-1078
20:30	49.98	176832	5900	11366	416	12347	2112	146043	2468	165050	180652	-1057
20:45	50.03	175017	5904	11706	379	11508	2215	144722	2485	162932	178919	-1050
21:00	50.03	171743	5898	11945	379	10139	2109	142439	2538	159419	175447	-1113
21:15	49.93	169501	5904	12026	376	9436	2112	141483	2486	157099	173823	-1489
21:30	49.98	167167	5896	12052	373	9186	2127	139553	2480	154742	171667	-1556
21:45	50.03	164568	5904	12211	375	8670	2249	137217	2542	151982	169168	-1507
22:00	50.08	161160	5900	12097	372	8271	2134	134755	2514	148691	166043	-1596
22:15	49.98	160584	5899	12024	375	8173	1901	133617	2504	148185	164493	-1556
22:30	50.03	158458	5916	11966	374	8027	1930	132329	2545	146118	163087	-1561
22:45</												