



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 21.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 20.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 20-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 20.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 21-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58623	65415	44795	23210	2662	194705
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1202	1552	1133	468	49	4403
Hydro Gen (MU)	90	46	80	26	10	253
Wind Gen (MU)	17	41	57	-	-	114
Solar Gen (MU)*	134.41	103.99	125.48	3.35	1.03	368
Energy Shortage (MU)	0.00	0.00	0.00	0.08	0.00	0.08
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	63805	77786	57595	24358	2895	222178
Time Of Maximum Demand Met	10:20	10:35	09:18	18:54	17:48	10:23

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.035	0.00	0.00	3.43	3.43	72.57	24.00

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8058	0	144.8	60.9	-1.4	631	0.00
	Haryana	7886	0	146.7	93.8	-1.5	298	0.00
	Rajasthan	17674	0	321.7	100.1	0.3	782	0.00
	Delhi	4779	0	80.6	80.6	-2.2	431	0.00
	UP	19297	0	350.3	122.7	-0.8	304	0.00
	Uttarakhand	2374	0	44.1	36.2	-0.3	135	0.00
	HP	2140	0	38.3	32.2	-0.5	190	0.00
	J&K(UT) & Ladakh(UT)	3150	0	66.8	64.5	-1.6	556	0.00
	Chandigarh	288	0	4.5	4.5	0.0	59	0.00
WR	Railways_NR ISTS	206	0	4.2	3.7	0.5	56	0.00
	Chhattisgarh	5599	0	112.6	63.1	-1.5	345	0.00
	Gujarat	23555	0	430.2	199.9	-5.1	658	0.00
	MP	18087	0	340.9	216.0	-2.3	849	0.00
	Maharashtra	28571	0	590.6	202.4	3.2	949	0.00
	Goa	703	0	14.7	14.3	0.4	72	0.00
	DNHDDPDCL	1342	0	30.3	30.4	-0.1	35	0.00
	AMNSIL	765	0	15.6	6.8	0.5	303	0.00
	BALCO	535	0	12.7	12.7	0.0	13	0.00
SR	RIL JAMNAGAR	175	0	3.9	3.9	0.0	0	0.00
	Andhra Pradesh	11157	0	205.8	66.2	0.1	638	0.00
	Telangana	14335	0	262.8	132.9	-1.3	459	0.00
	Karnataka	15850	0	278.7	85.5	-0.9	552	0.00
	Kerala	4429	0	85.2	67.5	0.3	387	0.00
	Tamil Nadu	14919	0	292.1	167.7	-5.6	424	0.00
	Puducherry	388	0	8.1	7.7	-0.1	66	0.00
ER	Bihar	5407	0	98.2	89.9	-4.6	398	0.08
	DVC	3267	0	68.7	-34.9	-1.3	377	0.00
	Jharkhand	2145	0	38.8	26.8	0.4	119	0.00
	Odisha	5297	0	104.4	34.4	-2.6	458	0.00
	West Bengal	7599	0	155.5	28.5	-1.5	199	0.00
	Sikkim	123	0	1.9	2.0	-0.1	22	0.00
	Railways_ER ISTS	16	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	179	0	2.9	2.9	-0.1	22	0.00
	Assam	1477	0	27.6	20.3	0.6	64	0.00
	Manipur	266	0	3.9	3.8	0.0	40	0.00
	Meghalaya	358	0	6.7	5.2	-0.1	19	0.00
	Mizoram	150	0	2.1	1.9	-0.2	15	0.00
	Nagaland	161	0	2.4	2.4	0.0	28	0.00
	Tripura	220	0	3.9	3.2	0.0	36	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.8	-8.7	-22.7	-12.4
Day Peak (MW)	-280.0	-486.8	-1037.0	-746.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	238.0	-233.0	151.7	-162.0	5.3	0.0
Actual(MU)	221.6	-210.4	141.3	-164.5	5.3	-6.8
O/D/U/D(MU)	-16.4	22.5	-10.4	-2.5	-0.1	-6.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5300	7116	6608	3744	698	23465	45
State Sector	8773	10159	5904	3569	222	28626	55
Total	14073	17274	12512	7313	919	52091	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	734	1606	630	693	14	3677	77
Lignite	29	21	45	0	0	95	2
Hydro	90	46	80	26	10	253	5
Nuclear	32	54	71	0	0	157	3
Gas, Naptha & Diesel	5	19	5	0	24	53	1
RES (Wind, Solar, Biomass & Others)	177	147	224	6	1	556	12
Total	1067	1893	1056	725	50	4791	100

Share of RES in total generation (%)	16.58	7.78	21.24	0.85	2.12	11.60
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.02	13.09	35.59	4.43	22.51	20.16

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.048

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	222178	10:23	0
Non-Solar hr	201690	18:39	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 21-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.2	-1.2
3	765 kV	GAYA-VARANASI	2	200	1018	0.0	14.0	-14.0
4	765 kV	SASARAM-FATEHPUR	1	0	638	0.0	10.4	-10.4
5	765 kV	GAYA-BALIA	1	0	633	0.0	10.9	-10.9
6	400 kV	PUSAULI-VARANASI	1	5	116	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	68	51	0.1	0.0	0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	138	706	0.0	8.4	-8.4
9	400 kV	PATNA-BALIA	2	0	832	0.0	12.4	-12.4
10	400 kV	NAUBATPUR-BALIA	2	3	537	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	141	247	0.0	3.4	-3.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	558	0.0	8.8	-8.8
13	400 kV	BIHARSHARIFF-VARANASI	2	59	417	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	70	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	76.2	-75.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	511	957	0.0	2.3	-2.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	319	1025	0.0	3.5	-3.5
3	765 kV	JHARSUGUDA-DURG	2	0	1084	0.0	20.0	-20.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	737	0.0	12.3	-12.3
5	400 kV	RANCHI-SIPAT	2	29	410	0.0	2.7	-2.7
6	220 kV	BUDHIPADAR-RAIGARH	1	0	110	0.0	1.7	-1.7
7	220 kV	BUDHIPADAR-KORBA	2	108	53	0.7	0.0	0.7
ER-WR						0.7	42.5	-41.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1252	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2866	0.0	50.3	-50.3
4	400 kV	TALCHER-I/C	2	190	113	2.1	0.0	2.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	85.6	-85.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	229	16	3.1	0.0	3.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	152	0	5.8	0.0	5.8
3	220 kV	ALIPURDUAR-SALAKATI	2	28	0	1.4	0.0	1.4
ER-NER						10.3	0.0	10.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	669	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3023	0.0	56.6	-56.6
2	HVDC	VINDHYACHAL B/B	-	0	214	0.0	4.8	-4.8
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	27.8	-27.8
4	765 kV	GWALIOR-AGRA	2	401	2612	0.5	26.8	-26.3
5	765 kV	GWALIOR-PHAGI	2	360	1880	0.3	25.0	-24.8
6	765 kV	JABALPUR-ORAI	2	138	1234	0.0	27.0	-27.0
7	765 kV	GWALIOR-ORAI	1	1038	0	16.0	0.0	16.0
8	765 kV	SATNA-ORAI	1	0	1110	0.0	19.1	-19.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1999	381	15.7	0.3	15.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	2402	0.0	35.7	-35.7
11	400 kV	ZERDA-KANKROLI	1	374	64	3.2	0.1	3.1
12	400 kV	ZERDA -BHINMAL	1	258	45	2.2	0.0	2.2
13	400 kV	VINDHYACHAL -RIHAND	1	973	0	22.1	0.0	22.1
14	400 kV	RAPP-SHUJALPUR	2	665	412	4.2	1.9	2.3
15	400 kV	NEEMUCH-Chittorgarh	2	646	450	3.8	1.9	1.9
16	220 kV	BHANPURA-RANPUR	1	0	201	0.0	3.2	-3.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	115	0	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	81	22	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						70.1	232.3	-162.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	513	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	2002	0.0	45.4	-45.4
3	765 kV	SOLAPUR-RAICHUR	2	1478	1125	6.9	6.1	0.9
4	765 kV	WARDHA-NIZAMABAD	2	37	2033	0.0	28.0	-28.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2248	0.0	31.0	-31.0
6	400 kV	KOLHAPUR-KUDGI	2	1526	0	23.7	0.0	23.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	107	2.1	0.0	2.1
WR-SR						32.8	122.6	-89.7
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	161	0	61	1.47		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-196	98	-65	-1.56		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-234	-127	-182	-4.36		
	NER	132kV GELEPHU-SALAKATI	-28	-14	-21	-0.50		
	NER	132kV MOTANGA-RANGIA	14	-3	8	0.18		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-69	0	-50	-1.21		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-69	0	-49	-1.17		
	ER	NEPAL IMPORT (FROM BIHAR)	-179	-32	-85	-2.03		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-308	-15	-179	-4.29		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-942	-748	-895	-21.47		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-747	-406	-516	-12.39		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-95	0	-52	-1.25		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.30	5.52	0.00	0.00	0.08	0.00	0.00	5.90
Nepal	2.00	0.00	2.37	0.00	0.00	1.49	0.00	0.00	5.86
Bangladesh	22.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.21
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.21	0.30	7.89	0.00	0.00	1.57	0.00	0.00	33.97

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.78
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.78

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.78	-0.30	-5.52	0.00	0.00	-0.08	0.00	0.00	-5.12
Nepal	-2.00	0.00	-2.37	0.00	0.00	-1.49	0.00	0.00	-5.86
Bangladesh	-22.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.21
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.43	-0.30	-7.89	0.00	0.00	-1.57	0.00	0.00	-33.19

Date of Reporting: 21-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.07	147130	6257	8251	764	5370	1778	126674	3311	138115	152405	-1541
0:15	50.02	147068	6240	8257	763	4979	1666	126691	3316	138048	151912	-1521
0:30	50.07	146290	6250	8233	765	5084	1659	126068	3307	137292	151366	-1505
0:45	50.07	145029	6253	8040	765	4958	1671	125019	3386	136224	150092	-1392
1:00	50.07	144256	6266	7948	762	4830	1668	124296	3378	135546	149148	-1325
1:15	50.02	142897	6261	7770	1001	4609	1659	123297	3346	134126	147943	-1304
1:30	50.02	142353	6264	7739	760	4559	1809	122908	3354	133854	147393	-1343
1:45	50.02	141851	6283	7629	761	4369	1812	122664	3332	133461	146850	-1323
2:00	50.02	141085	6256	7473	761	4215	1677	122191	3343	132851	145916	-1343
2:15	50.02	140213	6264	7358	997	4107	1675	121799	3304	131858	145504	-1363
2:30	50.02	140253	6272	7056	761	4231	1802	121719	3330	132436	145171	-1365
2:45	49.97	139981	6279	6832	758	4331	1803	121941	3367	132391	145311	-1367
3:00	50.02	139899	6275	6635	761	4309	1797	122174	3369	132503	145320	-1333
3:15	49.97	140131	6162	6584	761	4344	1809	122445	3366	132786	145471	-1369
3:30	50.02	140343	6273	6481	760	4405	1807	122768	3416	133102	145910	-1362
3:45	50.02	140415	6279	6393	761	4417	1799	122772	3375	133261	145796	-1363
4:00	50.02	140997	6264	6265	998	4446	1801	123458	3370	133734	146602	-1396
4:15	49.97	143104	6274	6072	764	4884	1672	124940	3353	136268	147959	-1396
4:30	50.02	144929	6260	5869	764	5386	1801	126611	3363	138296	150054	-1385
4:45	50.02	146522	6249	5610	764	5650	1677	128129	3373	140148	151452	-1431
5:00	49.97	148611	6249	5537	768	5982	1819	130002	3355	142306	153712	-1450
5:15	49.92	152684	6271	5476	769	6231	1675	133768	3327	146439	157517	-1439
5:30	49.97	156766	6256	5332	774	6339	1671	137825	3396	150660	161593	-1430
5:45	49.92	161379	6264	5208	1011	7196	1677	141853	3397	155160	166606	-1540
6:00	50.07	165381	6266	5123	795	7732	1676	145373	3394	159463	170359	-1508
6:15	49.96	171284	6262	5038	793	8680	1748	149994	3415	165453	175930	-1371
6:30	50.02	179388	6265	4847	895	11540	1987	155217	3449	173646	184200	-1344
6:45	50.07	185564	6273	4689	887	13738	2270	159314	3422	179988	190593	-1337
7:00	50.02	193034	6251	4568	1005	17267	2524	162685	3410	187461	197710	-1363
7:15	49.97	200119	6279	4517	1478	20614	2646	166022	3460	194124	205016	-1313
7:30	50.02	205351	6308	4506	2439	23332	2893	167303	3496	198406	210277	-1277
7:45	50.02	208498	6309	4430	4094	24363	3577	166953	3554	199974	213280	-1224
8:00	50.12	209024	6301	4353	6194	23504	3551	166186	3505	198477	213594	-1186
8:15	50.07	211881	6310	4214	8966	22475	3659	166823	3580	198701	216027	-1180
8:30	50.12	212541	6316	4030	12019	21714	3258	166032	3642	196492	217011	-1210
8:45	50.07	214031	6301	3719	15222	19224	3288	166598	3591	195090	217943	-1199
9:00	50.12	214752	6306	3460	18585	17042	3292	165829	3624	192707	218138	-1186
9:15	50.07	219817	6294	3331	21761	16916	2998	167754	3692	194725	222746	-1178
9:30	50.07	220187	6299	3304	25061	16141	2028	166793	3662	191822	223288	-1224
9:45	50.07	221400	6301	3381	28292	15300	1941	165417	3670	189727	224302	-1258
10:00	50.07	221551	6285	3474	31644	13267	1891	164451	3646	186433	224658	-1355
10:15	50.02	221891	6275	3451	34871	10954	1855	163854	3698	183569	224958	-1380
10:30	50.07	221456	6265	3427	38671	9801	1761	161218	3680	179358	224823	-1444
10:45	50.02	220049	6287	3313	41803	7950	1644	158774	3758	174933	223529	-1414
11:00	49.97	218856	6271	3246	44333	7497	1656	155803	3694	171277	222500	-1435
11:15	49.97	216980	6275	3252	46126	6487	1635	153001	3788	167602	220564	-1370
11:30	49.92	215911	6269	3230	47796	6299	1636	150346	3778	164885	219354	-1440
11:45	49.92	214766	6266	3187	49268	6418	1727	147997	3721	162311	218584	-1412
12:00	50.07	213488	6253	3036	51093	6448	1629	145193	3664	159359	217316	-1554
12:15	50.02	211957	6244	3089	51793	5905	1609	143145	3679	157075	215464	-1635
12:30	50.02	210994	6241	3032	52704	5935	1629	141429	3644	155258	214614	-1627
12:45	50.02	208964	6240	2951	53432	6101	1646	138614	3657	152581	212641	-1635
13:00	50.17	206687	6237	2932	54122	5709	1644	135352	3640	149633	209636	-1679
13:15	50.02	202209	6232	2918	53950	5416	1643	131488	3599	145341	205246	-1670
13:30	50.07	200980	6237	2927	54967	5342	1638	129312	3611	143086	204034	-1691
13:45	50.07	200892	6226	2892	54982	5506	1630	128903	3676	143018	203815	-1693
14:00	50.07	200116	6237	2801	54175	5603	1629	129000	3605	143140	203050	-1710
14:15	50.02	199856	6219	2831	52453	5478	1621	130436	3648	144572	202686	-1676
14:30	50.02	200916	6224	2885	50763	5244	1627	132652	3557	147268	202952	-1697
14:45	49.96	201085	6228	2896	48870	5378	1638	135707	3567	149319	204284	-1697
15:00	50.02	200946	6202	2798	46148	5902	1649	137712	3549	152000	203960	-1690
15:15	49.97	200134	6222	2785	43359	5859	1655	139912	3472	153990	203264	-1669
15:30	50.02	200267	6234	2738	40212	6403	1639	142800	3455	157317	203481	-1721
15:45	49.97	199874	6238	2675	36985	7081	1644	145253	3463	160214	203339	-1756
16:00	50.02	199882	6247	2646	33310	7756	1649	147750	3511	163926	202869	-1403
16:15	50.02	197583	6244	2684	29251	7873	1757	149689	3463	165648	200961	-1403
16:30	50.07	198174	6255	2737	24779	8482	1645	154017	3415	170658	201330	-1373
16:45	49.96	198610	6262	2765	20069	10693	1649	156750	3458	175776	201646	-1251
17:00	50.02	198339	6247	2799	15241	12636	1639	159514	3434	180299	201510	-1144
17:15	50.02	196505	6247	2817	10494	14825	1658	159879	3393	183194	199313	-1139
17:30	50.12	197450	6265	2743	6509	18539	1870	161615	3370	188198	200911	-1030
17:45	50.03	199466	6261	2844	3335	20756	1675	164393	3368	193287	202632	-1005
18:00	50.08	199572	6269	3010	1460	21037	1664	165934	3301	195102	202675	-1021
18:15	49.93	200266	6264	3241	556	21738	1659	166749	3297	196469	203504	-1052
18:30	50.03	201318	6293	3503	168	22972	1664	166551	3280	197647	204431	-1054
18:45	50.02	201296	6308	3776	123	22793	1652	166463	3325	197397	204440	-1017
19:00	50.02	199765	6294	4044	118	21435	1663	166190	3336	195603	203080	-1020
19:15	49.97	198783	6300	4404	115	19985	1666	165912	3352	194264	201734	-1001
19:30	49.97	197513	6289	4719	114	18701	1674	165678	3368	192680	200543	-1041
19:45	50.02	195436	6282	5066	93	17158	1675	164962	3423	190277	198659	-1058
20:00	50.03	191230	6206	5346	83	15372	1670	162440	3436	185801	194553	-1100
20:15	49.97	187760	6278	5518	86	12597	1672	161450	3367	182156	190968	-1094
20:30	49.92	185588	6274	5748	84	11625	1678	159838	3378	179756	188625	-1022
20:45	49.92	183456	6268	5863	85	11102	1672	158284	3330	177508	186604	-980
21:00	49.97	180132	6273	5882	46	10533	1673	155502	3351	174204	183260	-996
21:15	49.97	178124	6271	6067	39	10133	1676	154425	3397	172018	182008	-1015
21:30	50.03	174945	6293	5992	43	9471	1679	151568	3342	168910	178388	-1196
21:45	49.92	172152	6288	5959	46	8670	1807	149778	3394	166147	175942	-1397
22:00	50.03	168190	6290	6132	44	7593	1674	147568	3378	162014	172679	-1373
22:15	49.93	167679	6277	6194	48	7531	1678	146436	3399	161437	171563	-1367
22:30	49.98	166899	6278	6399	47	7275						