



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 08.10.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 07.10.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 7-अक्टूबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 07.10.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 08-Oct-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	69711	66419	46836	27614	3170	213750
Peak Shortage (MW)	65	0	0	0	0	65
Energy Met (MU)	1532	1500	1137	588	57	4814
Hydro Gen (MU)	225	87	139	103	39	592
Wind Gen (MU)	2	45	44	-	-	91
Solar Gen (MU)*	166.46	105.61	116.82	3.01	0.70	393
Energy Shortage (MU)	0.46	0.00	0.00	0.00	0.00	0.46
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69839	67576	54063	28113	3250	215437
Time Of Maximum Demand Met	19:10	18:48	11:58	21:35	18:16	19:09

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.032	0.00	0.00	6.55	6.55	77.49	15.96

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10793	0	219.4	101.6	-0.4	471	0.00
	Haryana	10164	0	215.8	148.9	-1.5	156	0.00
	Rajasthan	15558	0	332.4	134.1	-2.3	463	0.00
	Delhi	5643	0	120.8	108.9	-0.5	240	0.00
	UP	25195	0	504.9	185.5	0.1	469	0.00
	Uttarakhand	2297	0	47.6	29.5	1.1	191	0.08
	HP	1699	0	33.9	14.3	-0.5	93	0.00
	J&K(UT) & Ladakh(UT)	2482	0	48.4	32.4	3.5	653	0.38
	Chandigarh	276	0	5.5	5.3	0.2	46	0.00
WR	Railways_NR ISTS	188	0	3.9	3.8	0.2	75	0.00
	Chhattisgarh	5916	0	135.0	86.0	-0.2	447	0.00
	Gujarat	21288	0	449.8	182.0	-5.9	679	0.00
	MP	13044	0	275.6	168.8	-2.0	734	0.00
	Maharashtra	25684	0	563.3	216.7	1.4	732	0.00
	Goa	696	0	14.6	13.8	0.6	53	0.00
	DNHDDPDCL	1363	0	30.7	30.7	0.0	101	0.00
	AMNSIL	854	0	18.1	9.6	-0.4	197	0.00
	BALCO	530	0	12.6	12.7	-0.1	5	0.00
SR	Andhra Pradesh	10581	0	217.6	64.9	-0.3	1152	0.00
	Telangana	13163	0	257.4	109.6	-0.2	755	0.00
	Karnataka	11602	0	222.0	70.6	-1.6	409	0.00
	Kerala	4009	0	81.4	61.5	0.3	234	0.00
	Tamil Nadu	16675	0	348.9	191.6	1.7	1303	0.00
	Puducherry	436	0	9.8	9.5	-0.3	23	0.00
ER	Bihar	7076	0	143.3	133.3	-1.5	155	0.00
	DVC	3379	0	71.0	-38.3	0.5	370	0.00
	Jharkhand	2114	0	44.9	31.2	-0.5	69	0.00
	Odisha	6080	0	125.5	25.5	-2.0	457	0.00
	West Bengal	9872	0	201.8	56.3	-1.8	298	0.00
	Sikkim	93	0	1.4	1.5	-0.1	18	0.00
	Railways_ER ISTS	13	0	0.1	0.2	0.0	8	0.00
NER	Arunachal Pradesh	157	0	2.8	2.3	-0.2	40	0.00
	Assam	2090	0	36.5	28.1	0.3	140	0.00
	Manipur	200	0	2.7	2.8	-0.2	17	0.00
	Meghalaya	267	0	4.4	-1.6	-0.1	49	0.00
	Mizoram	126	0	1.9	0.7	-0.3	3	0.00
	Nagaland	165	0	2.9	2.4	-0.1	12	0.00
	Tripura	310	0	5.5	5.4	-0.2	70	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	43.8	7.8	-23.4	-24.9
Day Peak (MW)	1954.0	366.7	-996.0	-1133.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	313.6	-180.4	76.5	-195.8	-13.9	0.0
Actual(MU)	308.1	-167.7	70.2	-199.9	-16.1	-5.4
O/D/U/D(MU)	-5.4	12.7	-6.3	-4.1	-2.2	-5.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5035	10715	4168	3081	301	23300	54
State Sector	4091	8304	5927	1674	155	20150	46
Total	9126	19019	10095	4755	456	43451	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	846	1406	675	756	16	3699	72
Lignite	23	14	54	0	0	91	2
Hydro	225	87	139	103	39	592	12
Nuclear	30	46	76	0	0	152	3
Gas, Naptha & Diesel	17	44	5	0	23	89	2
RES (Wind, Solar, Biomass & Others)	175	152	190	5	1	523	10
Total	1316	1750	1138	863	78	5146	100

Share of RES in total generation (%)	13.29	8.69	16.69	0.56	0.96	10.16
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.70	16.32	35.51	12.44	50.08	24.62

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.034
Based on State Max Demands	1.077

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	212366	14:59	0
Non-Solar hr	215437	19:09	65

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 08-Oct-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	373	0.0	8.7	-8.7
2	HVDC	PUSAULI B/B	-	0	297	0.0	7.0	-7.0
3	765 kV	GAYA-VARANASI	2	0	935	0.0	13.8	-13.8
4	765 kV	SASARAM-FATEHPUR	1	78	388	0.0	4.5	-4.5
5	765 kV	GAYA-BALIA	1	0	700	0.0	11.4	-11.4
6	400 kV	PUSAULI-VARANASI	1	0	246	0.0	5.0	-5.0
7	400 kV	PUSAULI -ALLAHABAD	1	0	106	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	757	0.0	12.2	-12.2
9	400 kV	PATNA-BALIA	2	0	1025	0.0	20.2	-20.2
10	400 kV	NAUBATPUR-BALIA	2	0	319	0.0	6.1	-6.1
11	400 kV	BIHARSHARIFF-BALIA	2	0	204	0.0	4.8	-4.8
12	400 kV	MOTIHARI-GORAKHPUR	2	0	530	0.0	9.5	-9.5
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	117	0.0	0.1	-0.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	105.4	-104.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1173	0.0	15.3	-15.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	815	1139	0.0	1.8	-1.8
3	765 kV	JHARSUGUDA-DURG	2	0	696	0.0	11.4	-11.4
4	400 kV	JHARSUGUDA-RAIGARH	4	0	823	0.0	14.5	-14.5
5	400 kV	RANCHI-SIPAT	2	99	452	0.0	3.8	-3.8
6	220 kV	BUDHIPADAR-RAIGARH	1	0	142	0.0	2.3	-2.3
7	220 kV	BUDHIPADAR-KORBA	2	0	164	0.0	2.1	-2.1
ER-WR						0.0	51.0	-51.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	310	0.0	7.4	-7.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1642	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2625	0.0	45.3	-45.3
4	400 kV	TALCHER-I/C	2	221	0	4.2	0.0	4.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	92.4	-92.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	269	112	2.5	0.3	2.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	170	173	1.3	0.0	1.3
3	220 kV	ALIPURDUAR-SALAKATI	2	17	50	0.0	0.0	0.0
ER-NER						3.8	0.3	3.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	703	0.0	13.9	-13.9
NER-NR						0.0	13.9	-13.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5058	0.0	87.8	-87.8
2	HVDC	VINDHYACHAL B/B	-	45	0	1.2	0.0	1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2354	0.0	47.8	-47.8
4	765 kV	GWALIOR-AGRA	2	706	1226	1.5	12.6	-11.1
5	765 kV	GWALIOR-PHAGI	2	297	1832	0.0	23.6	-23.6
6	765 kV	JABALPUR-ORAI	2	165	956	0.0	20.7	-20.7
7	765 kV	GWALIOR-ORAI	1	828	0	12.3	0.0	12.3
8	765 kV	SATNA-ORAI	1	0	966	0.0	17.8	-17.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1507	0	19.6	0.0	19.6
10	765 kV	VINDHYACHAL-VARANASI	2	419	2428	0.0	27.5	-27.5
11	400 kV	ZERDA-KANKROLI	1	336	7	4.1	0.0	4.1
12	400 kV	ZERDA -BHINMAL	1	717	110	6.7	0.2	6.6
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	412	386	2.7	2.6	0.1
15	400 kV	NEEMUCH-Chittorgarh	2	418	424	2.1	3.5	-1.4
16	220 kV	BHANPURA-RANPUR	1	0	105	0.0	1.7	-1.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.6	-2.6
18	220 kV	MEHGAON-AURAIYA	1	144	0	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	110	0	1.0	0.0	1.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						52.9	248.5	-195.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	306	0.0	7.7	-7.7
2	HVDC	RAIGARH-PUGALUR	2	0	606	0.0	14.7	-14.7
3	765 kV	SOLAPUR-RAICHUR	2	1276	664	10.9	1.1	9.8
4	765 kV	WARDHA-NIZAMABAD	2	287	2009	0.4	20.9	-20.5
5	765 kV	WARORA-WARANGAL(NEW)	2	79	2104	0.0	23.7	-23.6
6	400 kV	KOLHAPUR-KUDGI	2	1645	0	30.2	0.0	30.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	100	0	1.6	0.0	1.6
9	220 kV	XELDEM-AMBEWADI	1	1	118	2.3	0.0	2.3
WR-SR						45.3	68.0	-22.6

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	785	724	780	18.71	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	955	851	901	21.62	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	120	52	91	2.18	
	NER	132kV GELEPHU-SALAKATI	20	0	13	0.30	
	NER	132kV MOTANGA-RANGIA	56	0	40	0.97	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	67	0	60	1.43	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	300	135	264	6.33	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-924	-804	-916	-21.99	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1134	-1000	-1039	-24.94	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-72	0	-58	-1.40	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 08-Oct-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	22.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.69
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.69

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	40.53	0.00	2.33	0.00	0.00	0.00	0.00	0.00	42.86
Nepal	2.56	0.00	0.00	0.00	0.00	4.82	0.00	0.00	7.38
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	43.09	0.00	2.33	0.00	0.00	4.82	0.00	0.00	50.24

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	40.53	0.00	2.33	0.00	0.00	0.00	0.00	0.00	42.86
Nepal	2.56	0.00	0.00	0.00	0.00	4.82	0.00	0.00	7.38
Bangladesh	-22.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.69
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	20.40	0.00	2.33	0.00	0.00	4.82	0.00	0.00	27.55