



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 10.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 09.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 9-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 09.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 10-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61849	65764	45195	22437	2726	197971
Peak Shortage (MW)	0	0	0	1077	0	1077
Energy Met (MU)	1272	1518	1196	476	50	4512
Hydro Gen (MU)	93	39	93	22	12	258
Wind Gen (MU)	13	64	78	-	-	155
Solar Gen (MU)*	158.97	106.39	125.91	2.70	0.92	395
Energy Shortage (MU)	0.49	0.00	0.00	2.72	0.00	3.21
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66234	75743	60915	23571	2901	226967
Time Of Maximum Demand Met	10:32	09:53	09:35	20:20	17:24	09:36

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.024	0.00	0.00	1.12	1.12	78.64	20.24

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8545	0	152.4	61.6	0.2	660	0.00
	Haryana	8130	0	158.0	104.3	-1.2	450	0.00
	Rajasthan	18218	0	337.8	121.1	-3.8	539	0.00
	Delhi	5052	0	86.7	80.3	-1.7	472	0.00
	UP	21290	0	376.2	127.8	0.9	667	0.49
	Uttarakhand	2521	0	46.8	38.1	0.4	151	0.00
	HP	2107	0	38.4	31.9	-1.0	114	0.00
	J&K(UT) & Ladakh(UT)	3099	0	67.4	65.2	-4.8	801	0.00
	Chandigarh	278	0	4.6	4.5	0.1	62	0.00
WR	Railways_NR ISTS	186	0	3.7	3.8	-0.1	19	0.00
	Chhattisgarh	5470	0	111.6	59.8	-0.3	255	0.00
	Gujarat	22318	0	418.9	191.7	-0.1	506	0.00
	MP	17232	0	324.1	193.0	-1.7	765	0.00
	Maharashtra	28257	0	588.2	186.3	-3.7	497	0.00
	Goa	697	0	14.1	13.5	0.1	55	0.00
	DNHDDPDCL	1339	0	30.8	30.8	0.0	48	0.00
	AMNSIL	719	0	15.4	5.4	0.7	274	0.00
	BALCO	531	0	12.7	12.7	0.0	8	0.00
SR	RIL JAMNAGAR	112	0	2.6	2.6	0.0	0	0.00
	Andhra Pradesh	11297	0	207.2	48.8	-0.7	411	0.00
	Telangana	14648	0	269.5	147.0	1.3	827	0.00
	Karnataka	16088	0	284.7	90.0	-2.1	723	0.00
	Kerala	4315	0	82.8	63.2	1.0	449	0.00
	Tamil Nadu	16587	0	342.9	206.0	-1.3	970	0.00
	Puducherry	396	0	8.6	8.2	-0.1	30	0.00
	Bihar	5544	39	106.7	94.3	0.6	458	2.72
	DVC	3344	0	72.0	-39.7	0.4	303	0.00
ER	Jharkhand	2080	0	38.6	25.9	1.9	360	0.00
	Odisha	5289	0	104.2	34.0	-1.1	467	0.00
	West Bengal	7526	0	152.8	12.4	-0.6	172	0.00
	Sikkim	126	0	2.0	1.9	0.1	37	0.00
	Railways_ER ISTS	21	0	0.2	0.2	0.0	3	0.00
	Arunachal Pradesh	179	0	2.9	3.0	-0.2	27	0.00
NER	Assam	1612	0	27.5	21.0	0.5	276	0.00
	Manipur	248	0	3.7	4.0	-0.3	46	0.00
	Meghalaya	373	0	6.6	5.1	-0.2	78	0.00
	Mizoram	154	0	2.6	1.9	-0.2	24	0.00
	Nagaland	152	0	2.2	2.4	-0.2	22	0.00
	Tripura	231	0	4.3	3.5	0.1	49	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.0	-7.6	-22.2	-12.3
Day Peak (MW)	-450.0	-542.6	-1036.0	-768.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	256.6	-272.1	148.1	-138.3	5.6	0.0
Actual(MU)	247.2	-273.0	143.2	-130.3	4.2	-8.6
O/D/U/D(MU)	-9.4	-0.9	-4.9	8.0	-1.4	-8.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5373	8221	4548	5693	748	24582	47
State Sector	6958	10703	6693	3349	191	27893	53
Total	12331	18923	11241	9042	939	52476	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	763	1618	622	661	14	3677	75
Lignite	20	16	60	0	0	96	2
Hydro	93	39	93	22	12	258	5
Nuclear	32	55	71	0	0	157	3
Gas, Naptha & Diesel	10	15	14	0	24	63	1
RES (Wind, Solar, Biomass & Others)	198	174	252	6	1	631	13
Total	1117	1917	1111	688	51	4884	100

Share of RES in total generation (%)	17.74	9.07	22.69	0.86	1.82	12.92
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.98	13.96	37.39	4.00	24.83	21.43

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.010
Based on State Max Demands	1.041

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226967	9:36	0
Non-Solar hr	204162	18:38	1385

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 10-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	0	0.0	0.5	-0.5
3	765 kV	GAYA-VARANASI	2	372	947	0.0	9.3	-9.3
4	765 kV	SASARAM-FATEHPUR	1	9	619	0.0	7.9	-7.9
5	765 kV	GAYA-BALIA	1	0	821	0.0	13.1	-13.1
6	400 kV	PUSAULI-VARANASI	1	17	247	0.0	0.7	-0.7
7	400 kV	PUSAULI -ALLAHABAD	1	51	107	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	152	511	0.0	5.3	-5.3
9	400 kV	PATNA-BALIA	2	0	749	0.0	11.1	-11.1
10	400 kV	NAUBATPUR-BALIA	2	11	515	0.0	3.2	-3.2
11	400 kV	BIHARSHARIFF-BALIA	2	92	266	0.0	3.3	-3.3
12	400 kV	MOTIHARI-GORAKHPUR	2	15	425	0.0	5.9	-5.9
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	3.0	-3.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	36	0.0	0.1	-0.1
ER-NR						0.6	63.3	-62.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	563	800	0.3	0.0	0.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	813	669	2.7	0.0	2.7
3	765 kV	JHARSUGUDA-DURG	2	0	937	0.0	16.2	-16.2
4	400 kV	JHARSUGUDA-RAIGARH	4	0	582	0.0	8.0	-8.0
5	400 kV	RANCHI-SIPAT	2	187	298	0.0	0.6	-0.6
6	220 kV	BUDHIPADAR-RAIGARH	1	0	138	0.0	1.9	-1.9
7	220 kV	BUDHIPADAR-KORBA	2	140	35	1.5	0.0	1.5
ER-WR						4.4	26.7	-22.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1251	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2943	0.0	52.6	-52.6
4	400 kV	TALCHER-I/C	2	93	45	0.6	0.0	0.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	10	0	0.0	0.0	0.0
ER-SR						0.0	87.9	-87.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	261	0	3.4	0.0	3.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	336	0	6.4	0.0	6.4
3	220 kV	ALIPURDUAR-SALAKATI	2	81	0	1.5	0.0	1.5
ER-NER						11.2	0.0	11.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	663	0	16.0	0.0	16.0
NER-NR						16.0	0.0	16.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4992	0.0	81.4	-81.4
2	HVDC	VINDHYACHAL B/B	-	269	102	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	979	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	0	2493	0.0	31.1	-31.1
5	765 kV	GWALIOR-PHAGI	2	299	1669	0.6	20.9	-20.3
6	765 kV	JABALPUR-ORAI	2	0	1220	0.0	29.8	-29.8
7	765 kV	GWALIOR-ORAI	1	827	0	13.9	0.0	13.9
8	765 kV	SATNA-ORAI	1	0	1128	0.0	20.2	-20.2
9	765 kV	BANASKANTHA-CHITORGARH	2	1414	526	10.1	1.0	9.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3208	0.0	47.8	-47.8
11	400 kV	ZERDA-KANKROLI	1	284	77	2.2	0.1	2.1
12	400 kV	ZERDA -BHINMAL	1	197	53	1.5	0.1	1.4
13	400 kV	VINDHYACHAL -RIHAND	1	975	0	22.0	0.0	22.0
14	400 kV	RAPP-SHUJALPUR	2	605	391	3.5	1.7	1.8
15	400 kV	NEEMUCH-Chittorgarh	2	614	436	3.4	1.9	1.5
16	220 kV	BHANPURA-RANPUR	1	0	167	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	129	0	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	95	21	0.7	0.1	0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						59.1	265.9	-206.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	511	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	1502	0.0	34.2	-34.2
3	765 kV	SOLAPUR-RAICHUR	2	1145	1140	5.4	7.9	-2.5
4	765 kV	WARDHA-NIZAMABAD	2	68	2341	0.0	32.8	-32.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2548	0.0	35.5	-35.5
6	400 kV	KOLHAPUR-KUDGI	2	1715	0	26.9	0.0	26.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	2.0	0.0	2.0
WR-SR						34.3	122.4	-88.1
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	68	58	68	2.04		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-238	82	-80	-1.93		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-251	-107	-192	-4.62		
	NER	132kV GELEPHU-SALAKATI	-24	0	-19	-0.45		
	NER	132kV MOTANGA-RANGIA	-14	0	0	-0.01		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	-39	-0.93		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-47	-1.14		
	ER	NEPAL IMPORT (FROM BIHAR)	-193	-20	-81	-1.95		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-350	-4	-150	-3.60		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-933	-650	-870	-20.89		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-768	-405	-513	-12.32		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-103	0	-53	-1.28		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.30	5.90	0.00	0.00	0.00	0.00	0.00	6.20
Nepal	2.05	0.00	1.54	0.00	0.00	2.22	0.00	0.00	5.81
Bangladesh	21.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.73
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.78	0.30	7.44	0.00	0.00	2.22	0.00	0.00	33.74

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.80
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.80

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.80	-0.30	-5.90	0.00	0.00	0.00	0.00	0.00	-5.40	
Nepal	-2.05	0.00	-1.54	0.00	0.00	0.00	-2.22	0.00	0.00	-5.81
Bangladesh	-21.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.73
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.98	-0.30	-7.44	0.00	0.00	0.00	-2.22	0.00	0.00	-32.94

Date of Reporting: 10-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.07	155518	6212	8675	85	6588	2320	132206	3378	146758	159464	-1563
0:15	50.07	154868	6226	8620	81	6645	2301	131567	3446	146167	158886	-1596
0:30	50.07	153774	6233	8448	82	6947	2316	130294	3451	145244	157771	-1591
0:45	50.02	152638	6220	8286	78	6739	2304	129878	3368	144274	156873	-1500
1:00	50.07	151644	6222	8122	80	6720	2323	128619	3395	143442	155481	-1384
1:15	49.97	150496	6241	7942	75	6231	2324	128135	3413	142479	154361	-1377
1:30	50.07	149489	6217	7796	73	6054	2313	127076	3433	141620	152962	-1381
1:45	50.02	148882	6226	7798	63	6032	2328	126664	3452	141021	152563	-1367
2:00	50.02	148188	6222	7710	77	5542	2327	126821	3437	140401	152136	-1375
2:15	50.02	147310	6220	7646	73	5508	2324	125697	3412	139591	150880	-1373
2:30	49.97	146821	6244	7464	74	5478	2322	125342	3413	139283	150337	-1391
2:45	49.97	146562	6240	7481	75	5431	2322	125075	3348	139006	149972	-1297
3:00	50.02	146198	6229	7495	79	5380	2324	124791	3309	138624	149607	-1263
3:15	49.97	146230	6222	7431	83	5599	2325	124777	3306	138716	149743	-1252
3:30	50.02	146854	6229	7400	86	5950	2324	125270	3310	139368	150569	-1263
3:45	50.02	146625	6224	7182	90	6185	2326	124997	3287	139353	150291	-1260
4:00	50.02	146839	6221	6827	91	6285	2320	125235	3311	139921	150290	-1221
4:15	49.97	149051	6229	6813	82	6567	2319	129256	3294	142156	154560	-1287
4:30	50.02	150573	6218	6743	73	6984	2323	128737	3242	143757	154320	-1295
4:45	49.97	152564	6209	6724	71	7178	2319	130471	3266	145769	156238	-1286
5:00	50.02	154665	6226	6700	72	7159	2321	132629	3280	147893	158387	-1298
5:15	50.02	159209	6215	6611	76	7162	2319	137332	3293	152522	163008	-1346
5:30	50.02	163518	6231	6603	85	7545	2327	141207	3302	156830	167300	-1323
5:45	49.97	168124	6227	6512	84	8654	2323	145070	3325	161528	172195	-1424
6:00	50.07	171218	6228	6475	91	8852	2376	148108	3351	164652	175481	-1420
6:15	50.07	176515	6224	6664	297	10266	2522	151698	3418	169554	181089	-1495
6:30	50.02	184109	6207	6826	321	11832	2753	157018	3371	176962	188328	-1271
6:45	50.02	190261	6235	6874	342	14618	2979	159643	3343	183045	194034	-1213
7:00	50.02	196933	6209	6973	568	17426	3340	162943	3303	189392	200762	-1296
7:15	49.87	202607	6221	7088	1187	20515	3465	164382	3321	194332	206179	-1191
7:30	50.02	207042	6222	7328	2387	18753	4109	164765	3519	197327	207083	-1205
7:45	50.02	209637	6215	7446	4377	19466	4113	164092	3497	197814	209206	-1184
8:00	50.07	210761	6225	7473	7592	21905	4390	161948	3495	195696	213028	-1190
8:15	50.07	213919	6222	7458	11736	21413	3400	162249	3586	194725	216064	-1186
8:30	50.07	217051	6221	7031	16740	20354	3405	161455	3536	193280	218742	-1187
8:45	50.13	219356	6224	6782	21782	18244	3394	160892	3656	190792	220974	-1155
9:00	50.13	220724	6228	6677	27001	15816	2662	160389	3441	187046	222214	-1199
9:15	50.02	224970	6216	6381	31906	14776	2363	161280	3403	186683	226325	-1255
9:30	50.08	226526	6198	6352	36625	13212	2353	159696	3521	183549	227957	-1326
9:45	50.07	226926	6210	6410	40477	11181	2348	158337	3581	180039	228544	-1418
10:00	50.13	225966	6196	6649	43761	8541	2445	156689	3503	175556	227784	-1565
10:15	50.03	225223	6208	6874	46348	7506	2428	154157	3495	172001	227016	-1542
10:30	49.98	225676	6197	6768	49329	7390	2434	151645	3517	169579	227280	-1538
10:45	49.98	224660	6224	6455	51366	6768	2420	149300	3515	166839	226048	-1474
11:00	50.03	223614	6196	6209	52727	6275	2411	147649	3506	164678	224973	-1486
11:15	49.92	221289	6223	5868	54304	5952	2388	144645	3548	161117	222928	-1524
11:30	49.97	220721	6217	5589	54988	6439	2394	142838	3549	160144	222014	-1522
11:45	50.03	219361	6214	5184	55793	6568	2383	141723	3532	158384	221397	-1772
12:00	50.08	217056	6217	4871	56481	6552	2386	138634	3594	155704	218735	-1785
12:15	49.97	215181	6212	4649	56591	6038	2390	137521	3618	153941	217019	-1839
12:30	49.98	214568	6203	4425	56406	6254	2411	137247	3574	153737	216520	-1834
12:45	49.93	212587	6207	4199	56200	6091	2413	135872	3581	152188	214563	-1828
13:00	50.03	209769	6198	4081	55603	6068	2391	134175	3646	150085	212162	-1815
13:15	50.02	205566	6199	3844	55021	5541	2396	131250	3585	146701	207836	-1817
13:30	49.97	204460	6207	3633	54554	5460	2400	130656	3565	146273	206475	-1830
13:45	49.97	204299	6215	3536	53455	5540	2394	131916	3524	147308	206580	-1841
14:00	50.07	202643	6199	3386	52595	5576	2394	131486	3477	146662	205113	-1845
14:15	49.97	202828	6218	3297	51459	5784	2388	132779	3484	148072	205409	-1853
14:30	49.97	203854	6197	3173	49971	6199	2378	134984	3523	150710	206425	-1887
14:45	49.92	204116	6191	3040	47882	6711	2380	137179	3503	153194	206886	-1883
15:00	50.02	204872	6202	2918	45797	6915	2393	139523	3511	156157	207259	-1892
15:15	50.02	203838	6203	2862	43182	6720	2403	141608	3488	157794	206466	-1754
15:30	50.02	203956	6195	2783	39874	7387	2393	144510	3478	161299	206620	-1736
15:45	50.02	203411	6200	2701	36614	7505	2394	147147	3510	164096	206071	-1689
16:00	50.02	202711	6199	2608	32748	7831	2413	150113	3447	167355	205359	-1526
16:15	50.02	201288	6209	2517	28678	8373	2438	152168	3444	170093	203827	-1475
16:30	50.02	202181	6200	2601	24221	9843	2458	155895	3477	175359	204695	-1341
16:45	49.97	203360	6214	2493	19174	12757	2554	159263	3423	181693	205878	-1272
17:00	50.02	203739	6201	2522	14007	15557	2708	161823	3429	187210	206247	-1194
17:15	49.97	202833	6203	2619	9358	18290	2716	162561	3362	190856	205109	-1142
17:30	50.02	203481	6212	2769	5390	22205	2717	162980	3369	195322	205642	-1128
17:45	50.02	203200	6220	3044	2583	23617	2936	163362	3313	197573	205075	-1120
18:00	49.97	203141	6213	3353	1064	24576	2929	164213	3287	198724	205635	-1136
18:15	49.97	203110	6217	3870	436	23941	2971	164903	3328	198804	205666	-1089
18:30	50.02	203942	6225	4332	310	24443	2975	164750	3295	199300	206330	-1076
18:45	50.02	203445	6228	4816	213	24405	2586	164356	3328	198416	205932	-1062
19:00	49.97	202255	6232	5331	217	22699	2584	164202	3338	196707	204603	-1053
19:15	50.02	200557	6219	5831	217	21147	2586	164292	3322	194509	203614	-1046
19:30	50.07	199299	6223	6164	215	20132	2580	163661	3268	192920	202243	-1055
19:45	50.03	196897	6232	6877	214	17119	2580	163633	3283	189806	199938	-1046
20:00	50.08	194406	6236	7565	220	16000	2355	161461	3304	186621	197141	-1046
20:15	50.08	192157	6225	8301	182	13792	2254	161184	3323	183674	195261	-1182
20:30	50.03	189573	6225	8822	192	12280	2180	159623	3309	180559	192631	-1183
20:45	50.03	186926	6197	9353	187	9967	2056	158844	3270	177386	189874	-1213
21:00	50.03	183418	6212	9815	151	9522	2057	155682	3248	173452	186687	-1227
21:15	50.03	180787	6218	10209	156	8630	2062	153573	3237	170422	184085	-1486
21:30	50.03	178247	6229	10609	154	7927	2065	151441	3279	167484	181704	-1505
21:45	50.03	175038	6215	10915	160	7693	2060	148007	3339	163963	178389	-1486
22:00	50.03	171130	6221	11182	161	7034	2065	144591	3413	159787	174667	-1513
22:15	49.98	170371	6217	11205	166	7965	2062	142712	3410	159000	173737	-1517
22:30	50.03	168400	6219	11217	106	7857	2070	141104				