



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 10.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 09.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 9-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 09.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 10-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	46873	55339	43534	20695	2675	169116
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1047	1260	1019	436	52	3813
Hydro Gen (MU)	141	40	149	47	19	395
Wind Gen (MU)	3	30	21	-	-	53
Solar Gen (MU)*	160.01	161.75	126.20	3.72	1.18	453
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	52081	59415	47539	21853	2899	178793
Time Of Maximum Demand Met	09:48	18:47	09:18	17:57	17:14	18:22

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.00	0.10	3.78	3.89	83.02	13.09

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	6691	0	130.8	57.1	-0.5	703	0.00
	Haryana	6237	0	130.8	107.9	-2.4	138	0.00
	Rajasthan	14297	0	275.2	77.6	-0.2	1077	0.00
	Delhi	3747	0	69.0	66.3	0.5	279	0.00
	UP	15751	0	307.3	95.0	-3.5	273	0.00
	Uttarakhand	1885	0	36.4	25.4	0.0	118	0.00
	HP	1802	0	33.0	18.9	-0.6	259	0.00
	J&K(UT) & Ladakh(UT)	2902	0	56.9	49.4	-0.8	191	0.00
	Chandigarh	173	0	3.1	3.1	0.0	17	0.00
	Railways_NR ISTS	189	0	4.1	4.0	0.1	19	0.00
WR	Chhattisgarh	4356	0	90.7	33.5	-0.3	296	0.00
	Gujarat	17325	0	362.6	218.3	-7.0	660	0.00
	MP	13809	0	244.5	162.3	0.0	450	0.00
	Maharashtra	23427	0	485.4	169.0	-3.8	720	0.00
	Goa	663	0	13.6	11.3	2.0	56	0.00
	DNHDDPDCL	1249	0	28.8	28.7	0.1	41	0.00
	AMNSIL	743	0	15.3	9.6	-0.3	243	0.00
	BALCO	539	0	12.9	12.9	0.0	11	0.00
	RIL JAMNAGAR	257	0	6.2	6.2	0.0	0	0.00
	Andhra Pradesh	8870	0	195.6	72.5	-1.9	370	0.00
SR	Telangana	8642	0	172.8	58.5	-0.1	596	0.00
	Karnataka	12822	0	241.5	85.0	0.3	694	0.00
	Kerala	3914	0	79.1	49.0	0.2	314	0.00
	Tamil Nadu	14956	0	321.0	197.1	-0.7	941	0.00
	Puducherry	388	0	8.6	8.1	-0.2	23	0.00
	Bihar	5353	0	92.5	76.6	-0.5	97	0.00
ER	DVC	2995	0	62.5	-17.7	-0.4	336	0.00
	Jharkhand	1936	0	36.7	27.2	-3.4	156	0.00
	Odisha	5131	0	100.0	29.7	-2.9	401	0.00
	West Bengal	6973	0	142.8	31.9	-2.4	312	0.00
	Sikkim	68	0	1.0	1.2	-0.2	7	0.00
	Railways_ER ISTS	31	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	164	0	2.8	2.8	-0.2	34	0.00
	Assam	1763	0	31.8	24.7	0.3	157	0.00
	Manipur	225	0	3.1	3.2	-0.1	16	0.00
	Meghalaya	285	0	5.2	4.1	-0.1	203	0.00
	Mizoram	118	0	2.2	0.8	0.0	37	0.00
	Nagaland	150	0	2.5	2.3	-0.2	9	0.00
	Tripura	266	0	4.9	3.8	-0.1	22	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	12.2	18.2	-24.5	-28.2
Day Peak (MW)	1113.9	944.8	-1047.8	-1238.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	131.1	-135.6	127.5	-129.6	6.5	0.0
Actual(MU)	153.9	-130.4	130.4	-171.3	5.9	-11.6
O/D/U/D(MU)	22.8	5.1	2.9	-41.7	-0.7	-11.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7403	15096	7238	4520	623	34880	44
State Sector	11284	20479	10238	2997	205	45202	56
Total	18687	35574	17476	7517	828	80082	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	585	1194	562	616	11	2967	71
Lignite	26	13	46	0	0	85	2
Hydro	141	40	149	47	19	395	9
Nuclear	37	53	41	0	0	131	3
Gas, Naptha & Diesel	3	11	5	0	21	40	1
RES (Wind, Solar, Biomass & Others)	175	195	165	6	1	542	13
Total	967	1505	968	669	52	4161	100

Share of RES in total generation (%)	18.15	12.96	17.02	0.87	2.28	13.03
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.51	19.11	36.70	7.89	38.42	25.69

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.027
Based on State Max Demands	1.068

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	175850	9:42	0
Non-Solar hr	178793	18:22	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 10-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	312	0.0	7.4	-7.4
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	176	1078	0.0	13.2	-13.2
4	765 kV	SASARAM-FATEHPUR	1	32	499	0.0	6.2	-6.2
5	765 kV	GAYA-BALIA	1	0	541	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	0	105	0.0	1.7	-1.7
7	400 kV	PUSAULI-ALLAHABAD	1	10	69	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	26	604	0.0	8.1	-8.1
9	400 kV	PATNA-BALIA	2	0	826	0.0	12.3	-12.3
10	400 kV	NAUBATPUR-BALIA	2	86	209	0.0	4.0	-4.0
11	400 kV	BIHARSHARIFF-BALIA	2	225	141	0.1	0.0	0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	501	0.0	7.4	-7.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	79	422	0.0	4.6	-4.6
14	220 kV	SAHUPURI-KARMANASA	1	22	8	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	78.0	-77.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	779	497	0.0	0.6	-0.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	439	512	0.0	1.1	-1.1
3	765 kV	JHARSUGUDA-DURG	2	0	1271	0.0	20.6	-20.6
4	400 kV	JHARSUGUDA-RAIGARH	4	350	321	0.0	0.5	-0.5
5	400 kV	RANCHI-SIPAT	2	179	280	0.0	1.5	-1.5
6	400 kV	JEYPORE-JACDALPUR	2	398	347	0.0	1.1	-1.1
7	220 kV	BUDHIPADAR-RAIGARH	1	56	114	0.0	1.1	-1.1
8	220 kV	BUDHIPADAR-KORBA	2	180	78	0.6	0.0	0.6
ER-WR						1.7	25.4	-23.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	529	0.0	6.4	-6.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1618	0.0	35.9	-35.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2955	0.0	50.2	-50.2
4	400 kV	TALCHER/IC	2	1258	419	2.9	0.0	2.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	24	0	0.4	0.0	0.4
ER-SR						0.4	92.5	-92.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	457	0.0	7.9	-7.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	662	0.0	10.7	-10.7
3	220 kV	ALIPURDUAR-SALAKATI	2	0	132	0.0	2.2	-2.2
ER-NER						0.0	20.7	-20.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	604	0.0	14.5	-14.5
NER-NR						0.0	14.5	-14.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2501	0.0	38.6	-38.6
2	HVDC	VINDHYACHAL B/B	-	194	0	4.6	0.0	4.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	300	0.0	7.4	-7.4
4	765 kV	GWALIOR-AGRA	2	623	1157	0.5	13.5	-13.0
5	765 kV	GWALIOR-PHAGI	2	615	2085	0.9	26.4	-25.5
6	765 kV	JABALPUR-ORAI	2	278	751	0.0	18.7	-18.7
7	765 kV	GWALIOR-ORAI	1	1054	0	15.0	0.0	15.0
8	765 kV	SATNA-ORAI	1	0	946	0.0	15.3	-15.3
9	765 kV	BANASKANTHA-CHITORGARH	2	2631	150	34.7	0.1	34.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	1660	0.0	20.6	-20.6
11	400 kV	ZERDA-KANKROLI	1	536	0	7.4	0.0	7.4
12	400 kV	ZERDA -BHINMAL	1	370	0	5.1	0.0	5.1
13	400 kV	VINDHYACHAL -RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	768	133	4.6	0.3	4.3
15	400 kV	NEEMUCH-Chittorgarh	2	700	219	3.9	1.3	2.7
16	220 kV	BHANPURA-RANPUR	1	0	113	0.0	1.9	-1.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	78	0	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	55	6	0.4	0.0	0.4
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						77.9	145.7	-67.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	991	0.0	18.7	-18.7
2	HVDC	RAIGARH-PUGALUR	2	0	1503	0.0	25.3	-25.3
3	765 kV	SOLAPUR-RAICHUR	2	952	1148	1.7	6.9	-5.2
4	765 kV	WARDHA-NIZAMABAD	2	32	1896	0.0	24.1	-24.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2268	0.0	32.5	-32.5
6	400 kV	KOLHAPUR-KUDGI	2	1225	0	19.7	0.0	19.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	113	0.0	2.1	-2.1
WR-SR						23.5	107.5	-84.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	833	193	265	6.36
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	435	326	375	9.00
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-103	-36	-75	-1.80
	NER	132kV GELEPHU-SALAKATI	-56	-38	-46	-1.11
	NER	132kV MOTANGA-RANGIA	-31	-2	-12	-0.28
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	64	1.53
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	862	348	696	16.71
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-977	-788	-960	-23.03
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1239	-999	-1173	-28.15
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-70	0	-60	-1.45

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 10-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.64	0.17	0.00	0.00	0.00	0.00	0.00	0.00	23.81
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.64	0.17	0.00	0.00	0.00	0.00	0.00	0.00	23.81

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.76
Nepal	0.76	0.16	9.27	0.00	0.00	6.11	0.00	0.00	16.30
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	3.52	0.16	9.27	0.00	0.00	6.11	0.00	0.00	19.06

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	2.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.76	
Nepal	0.76	0.16	9.27	0.00	0.00	0.00	6.11	0.00	0.00	16.30
Bangladesh	-23.64	-0.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.81
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.12	-0.01	9.27	0.00	0.00	0.00	6.11	0.00	0.00	-4.75

