




Net F/T

Network Force/Torque Sensor System

Manual



Document #: 9620-05-NET FT

Engineered Products for Robotic Productivity

Pinnacle Park • 1031 Goodworth Drive • Apex, NC 27539 • Tel: 919.772.0115 • Fax: 919.772.8259 • www.ati-ia.com • Email: info@ati-ia.com

Foreword

Information contained in this document is the property of ATI Industrial Automation, Inc. and shall not be reproduced in whole or in part without prior written approval of ATI Industrial Automation, Inc. The information herein is subject to change without notice and should not be construed as a commitment on the part of ATI Industrial Automation, Inc. This manual is periodically revised to reflect and incorporate changes made to the F/T system.

ATI Industrial Automation, Inc. assumes no responsibility for any errors or omissions in this document. Users' critical evaluation is welcome to assist in the preparation of future.

Copyright © by ATI Industrial Automation, Inc., Apex, North Carolina USA. All Rights Reserved. Published in the USA.

In consideration that ATI Industrial Automation, Inc. (ATI) products are intended for use with robotic and/or automated machines, ATI does not recommend the use of its products for applications wherein failure or malfunction of a ATI component or system threatens life or makes injury probable. Anyone who uses or incorporates ATI components within any potentially life threatening system must obtain ATI's prior consent based upon assurance to ATI that a malfunction of ATI's component does not pose direct or indirect threat of injury or death, and (even if such consent is given) shall indemnify ATI from any claim, loss, liability, and related expenses arising from any injury or death resulting from use of ATI components.

All trademarks belong to their respective owners.

Windows and Excel are registered trademarks of Microsoft Corporation.

Ipad is a registered trademark of Apple Inc.

FCC Compliance - Class A

This device complies with Part 15 Subpart B of the FCC Title 47. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Any modifications to the device could impact compliance. It is the user's responsibility to certify the device remains compliant after modifications

"Electromagnetic Compatibility"

This device complies with EMC Directive 2014/30/EU and conforms to the following standards:
EN55022:1998+A1:2000 +A2:2003, EN61000-4-2:1995 +A1:1998+A2:2001, EN61000-4-3:2002, EN61000-4-4:2004,
EN61000-4-5:1995 +A1:1996, EN61000-4-6:1996 +A1:2001, EN61000-4-8:1995, EN61000-4-11:2001.

RoHS Compliance

This product conforms to EU Directive CE 2011/65/EU (RoHS).

Note

Please read the manual before calling customer service. Before calling, have the following information available:

1. Serial number (e.g., FT01234)
2. Transducer model (e.g., Nano17, Gamma, Theta, etc.)
3. Calibration (e.g., US-15-50, SI-65-6, etc.)
4. Accurate and complete description of the question or problem
5. Computer and software information. Operating system, PC type, drivers, application software, and other relevant information about your configuration.

If possible, be near the F/T system when calling.

How to Reach Us

Sale, Service and Information about ATI products:

ATI Industrial Automation

1031 Goodworth Drive
Apex, NC 27539 USA

www.ati-ia.com

Tel: +1.919.772.0115
Fax: +1.919.772.8259
E-mail: info@ati-ia.com

Technical support and questions:

Application Engineering

Tel: +1.919.772.0115, Option 2
Fax: +1.919.772.8259
E-mail: ft_support@ati-ia.com

Statement of Compliance

Statement of Compliance

Manufacturer: ATI Industrial Automation
1031 Goodworth Drive
Apex, NC 27539
919-772-0115 x 222

Requester / Applicant: Alexander Strotzer

Name of Equipment: NetBox and Net FT Sensor

Model No. Net FT

Type of Equipment: Measurement, Control and Laboratory Use

Class of Equipment: Class A

Application of Regulations: FCC Title 47, Part 15, Subpart B and EMC Directive 2004/108/EC

Test Dates: 18 June 2007 to 21 June 2007

Guidance Documents:

Emissions: EN61326:1997 +A1:1998 +A2:2000

Immunity: EN61326:1997 +A1:1998 +A2:2000

Test Methods:

Emissions: EN55022:1998+A1:2000+A2:2003; FCC Part 15.107(b), 15.109(g),

Immunity: EN61000-4-2:1995 +A1:1998+A2:2001, EN61000-4-3:2002, EN61000-4-4:2004,
EN61000-4-5:1995 +A1:1996, EN61000-4-6:1996 +A1:2001, EN61000-4-8:1995,
EN61000-4-11:2001

The electromagnetic compatibility test and documented data described in this report has been performed and recorded by TUV Rheinland, in accordance with the standards and procedures listed herein. As the responsible authorized agent of the EMC laboratory, I hereby declare that a sample of one, of the equipment described above, has been shown to be compliant with the EMC requirements of the stated regulations and standards based on these results. If any special accessories and/or modifications were required for compliance, they are listed in the Executive Summary of this report.

This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report contains data that are not covered by NVLAP accreditation. This report shall not be reproduced except in full, without the written authorization of the laboratory.

**Michael
Moranha**

Test Engineer

19 September
2007



**Randy
Sherian**

19 September
2007

Date



200094-0



90552 and 100881

Industry Canada

IC3755

Table of Contents

Foreword	B-2
Statement of Compliance	B-4
Glossary	B-10
1. Safety.....	B-12
1.1 Explanation of Notifications.....	B-12
1.2 General Safety Guidelines.....	B-12
1.3 Safety Precautions	B-12
2. System Overview.....	B-13
2.1 Multiple Calibrations.....	B-13
2.2 Multiple Configurations	B-13
2.3 Force and Torque Values.....	B-13
2.4 System Status Code.....	B-13
2.5 Thresholding.....	B-13
2.6 Tool Transformations.....	B-13
2.7 Multiple Interfaces.....	B-13
2.8 Power Supply.....	B-13
3. Getting Started	B-14
3.1 Unpacking	B-14
3.2 System Components Description.....	B-14
3.2.1 F/T Transducer	B-15
3.2.2 Transducer Cable	B-16
3.2.3 Net Box.....	B-16
3.3 Connecting the System Components	B-17
3.3.1 Connecting the Transducer to the Net Box	B-17
3.3.2 Providing Power to the Net F/T	B-17
3.3.2.1 Method 1: Providing Power with PoE	B-17
3.3.2.2 Method 2: Providing Power to Pwr/CAN Input.....	B-18
3.3.3 Connecting to Ethernet.....	B-19
3.3.3.1 Option 1: Connect to an Ethernet Network	B-20
3.3.3.2 Option 2: Connect directly to a Computer's Ethernet Interface	B-20
3.4 IP Address Configuration for Ethernet.....	B-21
3.5 Connecting to Ethernet using a Windows Computer	B-22
3.5.1 Windows Vista and Windows 7	B-22
3.5.2 Windows XP	B-23
3.6 Connecting to an Ethernet-based Fieldbus	B-25
3.7 Connecting to DeviceNet (using DeviceNet-Compatibility Mode)	B-25

3.8	Connecting the Net Box to a CAN Bus Network	B-25
3.9	DIP Switches and Termination Resistor.....	B-25
3.9.1	Termination Resistor.....	B-26
3.9.2	Node Address.....	B-26
3.9.3	Baud Rate	B-28
3.10	Baud Rate.....	B-28
3.11	Power-Up Cycle	B-29
4.	Web Pages	B-31
4.1	Welcome Page (index.htm).....	B-31
4.2	Snapshot Page (rundata.htm)	B-32
4.3	Demo Page (demo.htm)	B-34
4.4	Settings Page (setting.htm).....	B-35
4.5	Thresholding Page (moncon.htm)	B-36
4.5.1	Threshold Relay	B-38
4.5.1.1	Standard Net Box Threshold Relay	B-38
4.5.1.2	Fieldbus Net Box and Optional Solid State Threshold Relay.....	B-40
4.6	Configurations Page (config.htm)	B-42
4.7	Communication Settings Page (comm.htm).....	B-46
4.7.1	TCP Modbus Register Map	B-50
4.8	System Information Page (manuf.htm)	B-51
4.9	ATI Web Site Menu Item	B-51
5.	Java Demo Application	B-52
5.1	Starting the Demo	B-52
5.2	Data Display with the Demo	B-53
5.3	Collecting Data with the Demo.....	B-54
5.4	The Errors Display of the Demo.....	B-56
5.5	Developing Your Own Java Application.....	B-57
6.	Net F/T Configuration Utility.....	B-58
6.1	Finding Net F/Ts on the Network	B-58
6.2	Backing Up a Configuration to a Computer.....	B-60
6.3	Restoring a Saved Configuration	B-60
6.4	Inspecting a Saved Configuration File.....	B-61
7.	Net F/T iPad Application	B-62
7.1	Monitoring and Data Collection	B-62
7.2	Exporting Data.....	B-64
7.3	Data Collection Settings	B-65
8.	Common Gateway Interface (CGI)	B-67

8.1	Settings CGI (setting.cgi)	B-68
8.2	Thresholding CGI (moncon.cgi).....	B-69
8.3	Configurations CGI (config.cgi)	B-69
8.4	Communications CGI (comm.cgi).....	B-72
9.	System Settings XML Pages	B-73
9.1	System and Configuration Information (netftapi2.xml)	B-73
9.2	Calibration Information (netftcalapi.xml)	B-76
10.	UDP Interface Using RDT.....	B-77
10.1	RDT Protocol	B-77
10.2	Extended RDT Requests.....	B-79
10.3	Calculating F/T Values for RDT	B-79
10.4	Multi-Unit Mode	B-79
10.5	Multiple Clients.....	B-79
10.6	Notes on UDP and RDT Mode	B-80
10.7	Example Code.....	B-80
11.	TCP Interface	B-80
11.1	General.....	B-80
11.2	Command Codes.....	B-80
11.3	Read F/T Command.....	B-80
11.4	Read F/T Response	B-81
11.5	Read Calibration Info Command.....	B-81
11.6	Read Calibration Info Response	B-82
11.7	Write Tool Transform Command	B-82
11.8	Write Monitor Condition Command	B-83
11.9	Write Response	B-83
12.	EtherNet/IP Operation	B-84
12.1	Overview	B-84
12.2	Module and Network Status LED	B-84
13.	DeviceNet-Compatibility Mode Operation.....	B-85
13.1	Overview	B-85
13.2	MAC ID.....	B-85
13.3	Baud Rate.....	B-85
13.4	Module and Network Status LED	B-85
13.5	EDS File.....	B-85
14.	EtherNet/IP and DeviceNet CIP Model.....	B-86
14.1	Overview	B-86

14.2 Calculating F/T Values for CIP	B-88
14.2.1 EtherNet/IP	B-88
14.2.2 DeviceNet	B-88
14.3 Object Model.....	B-89
14.3.1 Data Types	B-89
14.3.2 EtherNet/IP	B-89
14.3.3 Transducer Force/Torque Object (0x65—6 Instances).....	B-90
14.3.4 Transducer Force/Torque Object (0x65—6 Instances).....	B-90
14.3.5 System Status Object (0x67—1 Instance)	B-91
14.3.6 Configurations Object (0x71—16 Instances).....	B-91
14.3.7 Transducer Force/Torque Object (0x65—6 Instances).....	B-92
14.3.8 Thresholding Settings Object (0x73—32 Instances).....	B-93
15. CAN Bus Operation	B-94
15.1 Overview	B-94
15.2 Protocol Description.....	B-94
15.3 Base Address and Communication Format.....	B-94
15.4 Baud Rate.....	B-95
15.5 Calculating F/T Values for CAN.....	B-95
16. Fieldbus Operation.....	B-96
16.1 PROFINET Fieldbus Interface	B-96
16.1.1 Enabling the PROFINET Interface	B-97
16.1.2 Communications CGI (comm.cgi) Options	B-99
16.1.3 XML Page Elements.....	B-99
16.1.4 Returning Default Settings	B-99
16.1.5 Replacing and Installed PROFINET Fieldbus Net Box	B-100
16.1.5.1 Replacing and Installed PROFINET Fieldbus Net Box.....	B-100
16.1.5.2 Replacement with Previously Commissioned Fieldbus Net Box	B-100
17. Advanced Topics.....	B-101
17.1 Improving Ethernet Throughput	B-101
17.1.1 Direct Connection between Net F/T and Host.....	B-101
17.1.2 Choice of Operating System	B-101
17.1.3 Increasing Operating System Performance	B-101
17.1.4 Avoid Connecting the Net F/T to a Your Organization’s Network	B-101
17.1.5 Use a Dedicated Network.....	B-101
17.2 Reducing Noise	B-102
17.2.1 Mechanical Vibration	B-102
17.2.2 Electrical Interference.....	B-102
17.3 Detecting Failures (Diagnostics)	B-102

17.3.1	Detecting Sensitivity Changes.....	B-102
17.4	Scheduled Maintenance	B-102
17.4.1	Periodic Inspection	B-102
17.5	A Word about Resolution	B-103
17.6	Connecting to Specific Industrial Robots.....	B-103
17.6.1	ABB Robotics	B-104
17.6.2	Denso Robotics	B-104
17.6.3	Fanuc Robotics	B-104
17.6.4	Kuka Robotics	B-105
17.6.5	Motoman Robotics	B-105
18.	Troubleshooting	B-106
18.1	System Status Code.....	B-106
18.2	Status Word	B-108
18.3	Questions and Answers.....	B-109
18.3.1	Errors with Force and Torque Readings	B-110
19.	General Specifications.....	B-111
19.1	Environmental	B-111
19.1.1	Storage and Operating Temperatures	B-111
19.2	Transducer Data Filtering	B-111
19.3	Electrical Specifications (Power Supply).....	B-113
19.3.1	Communications.....	B-113
19.3.1.1	Ethernet Interface	B-113
19.3.1.2	CAN Interface	B-114
19.3.2	Mating Connectors	B-114
19.3.3	Standard Threshold Relay.....	B-114
19.3.4	Solid-State Threshold Relay.....	B-114
19.3.5	NetBox Transducer Cabling	B-115
19.4	Net Box Weight.....	B-115
20.	Drawings	B-116
20.1	9105-NETB Drawing	B-116
20.2	9105-NETBA Drawing.....	B-117
20.3	9105-NETB-PN2 Drawing	B-118

Glossary

Term	Definitions
Accuracy	See Measurement Uncertainty.
Active Configuration	The configuration the system is currently using.
Calibration	The factory-supplied data used by Net F/T so it can report accurate transducer readings. Calibrations apply to a given loading range.
CAN	Controller Area Network (CAN) is a low level communication protocol used in some networks, including DeviceNet. The Net F/T system has a simple CAN protocol that can be used to read force and torque values.
CGI	Common Gateway Interface (CGI) is the method of using web URLs to communicate data and parameters back to a web device.
Compound Loading	Any force or torque load that is not purely in one axis.
Configuration	User-defined settings that include which force and torque units are reported, which calibration is to be used, and any tool transformation data.
Coordinate Frame	See Point of Origin.
DeviceNet™	A Fieldbus communication network used mostly by devices in industrial settings, that communicates using CAN. DeviceNet is a trademark of ODVA.
DeviceNet Compatibility Mode	A feature of the Net F/T that allows it to respond like a certified DeviceNet device.
DHCP	Dynamic Host Configuration Protocol (DHCP) is an automatic method for Ethernet equipment to obtain an IP address. The Net F/T system can obtain its IP address using DHCP on networks that support this protocol.
Dup_MAC_ID test	The Duplicate MAC ID test is performed by a DeviceNet node (device) at power up to verify its MAC ID (device address) is not in use by another device.
EtherNet/IP™	EtherNet/IP (Ethernet Industrial Protocol) is a Fieldbus communication network, used mostly by devices in industrial settings, that communicates using Ethernet. EtherNet/IP is a trademark of ControlNet International Ltd. used under license by ODVA.
Ethernet Network Switch	Ethernet network switches are electronic devices that connect multiple Ethernet cables to an Ethernet network while directing the flow of traffic.
Fieldbus	A generic term referring to any one of a number of industrial computer networking standards. Examples include: CAN, Modbus, and PROFINET.
FS	Full-Scale.
F/T	Force and Torque.
Fxy	The resultant force vector comprised of components Fx and Fy.
Hysteresis	A source of measurement caused by the residual effects of previously applied loads.
IP Address	An IP Address (Internet Protocol Address) is an electronic address assigned to an Ethernet device so that it may send and receive Ethernet data. IP addresses may be either manually selected by the user or automatically assigned by the DHCP protocol.
IPv4	IPv4 (Internet Protocol Version 4) describes IP addresses using four bytes, usually expressed in the dot-decimal notation, such as, 192.168.1.1 for example.
Java™	Java is a programming language often used for programs on web pages. The Net F/T demo is a Java application. Java is a registered trademark of Sun Microsystems, Inc.
MAC Address	MAC Addresses (Media Access Control Addresses) are the unique addresses given to every Ethernet device when it is manufactured, to be used as an electronic Ethernet serial number.
MAC ID	Media Access Code Identifier (MAC ID) is a unique number that is user assigned to each DeviceNet device on a DeviceNet network. Also called Node Address.
Maximum Single-Axis Overload	The largest amount of pure load (not compound loading) that the transducer can withstand without damage.
MAP	The Mounting Adapter Plate (MAP) is the transducer plate that attaches to the fixed surface or robot arm.

Term	Definitions
Measurement Uncertainty	The maximum expected error in measurements, as specified on the calibration certificate.
Net Box	The component that contains the power supply and network interfaces of the Net F/T system.
Node Address	See MAC ID.
ODVA™	ODVA (Open DeviceNet Vendors Association, Inc.) is an organization that defines DeviceNet, EtherNet/IP, and other industrial networks. ATI Industrial Automation is a member of ODVA. ODVA is a registered trademark of Open DeviceNet Vendors Association, Inc.
Overload	The condition where more load is applied to the transducer than it can measure. This will result in saturation.
PoE	Power-over-Ethernet, or PoE, is a method of delivering electrical power to a PoE-compatible Ethernet device through the Ethernet cable. This simplifies installation of the Ethernet device since a separate power supply is not needed. The Net F/T system is PoE compatible.
Point of Origin	The location on the transducer from which all forces and torques are measured. Also known as the Coordinate Frame.
PROFINET	An Ethernet-based fieldbus used in factory automation.
Quantization	The process of converting a continuously variable transducer signal into discrete digital values. Usually used when describing the change from one digital value to the next increment.
RDT	Raw Data Transfer (RDT) is a fast and simple Net F/T protocol for control and data transfer via UDP.
Resolution	The smallest change in load that can be measured. This is usually much smaller than accuracy.
Saturation	The condition where the transducer has a load outside of its sensing range.
Sensor System	The assembly consisting of all components from the transducer to the Net Box.
TAP	Tool Adapter Plate (TAP) is the transducer surface that attaches to the load to be measured.
TCP	Transmission Control Protocol (TCP) is a low-level method of transmitting data over Ethernet. TCP provides a slower, more reliable delivery of data than UDP.
Thresholding	A Net F/T function that performs a simple arithmetic comparison of a user-defined threshold to the loading on a transducer axis.
Tool Transformation	A method of mathematically shifting the measurement coordinate system to translate the point of origin and/or rotate its axes.
Transducer	Transducer is the component that converts the sensed load into electrical signals.
Txy	The resultant torque vector comprised of components Tx and Ty.
UDP	UDP (User Datagram Protocol) is a low-level method of transmitting data over Ethernet. While UDP is faster than TCP, unlike TCP lost UDP data is not resent.

1. Safety

The safety section describes general safety guidelines to be followed with this product, explanation of the notification found in this manual, and safety precaution that apply to the product. More specific notification are embedded within the sections of the manual where they apply.

1.1 Explanation of Notifications

The notifications included here are specific to the product(s) covered by this manual. It is expected that the user heed all notifications from the robot manufacturer and/or the manufacturers of other components used in the installation.



DANGER: Notification of information or instructions that if not followed will result in death or serious injury. The notification provides information about the nature of the hazardous situation, the consequences of not avoiding the hazard, and the method for avoiding the situation.



WARNING: Notification of information or instructions that if not followed could result in death or serious injury. The notification provides information about the nature of the hazardous situation, the consequences of not avoiding the hazard, and the method for avoiding the situation.



CAUTION: Notification of information or instructions that if not followed could result in moderate injury or will cause damage to equipment. The notification provides information about the nature of the hazardous situation, the consequences of not avoiding the hazard, and the method for avoiding the situation.

NOTICE: Notification of specific information or instructions about maintaining, operating, installation, or setup of the product that if not followed could result in damage to equipment. The notification can emphasize but is not limited to specific grease types, good operating practices, or maintenance tips.

1.2 General Safety Guidelines

The customer should verify that the transducer selected is rated for maximum loads and moments expected during operation. Refer to F/T Transducer Manual (9620-05-Transducer Section—Installation and Operation Manual) or contact ATI Industrial Automation for assistance. Particular attention should be paid to dynamic loads caused by robot acceleration and deceleration. These forces can be many times the value of static forces in high acceleration or deceleration situations.

1.3 Safety Precautions



CAUTION: Do not remove any fasteners or disassemble transducers without a removable mounting adapter plate. These include Nano, Mini, IP-rated, and some Omega transducers. This will cause irreparable damage to the transducer and void the warranty. Leave all fasteners in place and do not disassemble the transducer.



CAUTION: Do not probe any openings in the transducer. This will damage the instrumentation.



CAUTION: Do not exert excessive force on the transducer. The transducer is a sensitive instrument and can be damaged by applying force exceeding the single-axis overload values of the transducer and cause irreparable damage. Small Nano and Mini transducers can easily be overloaded during installation. Refer to the F/T Transducer manual (9620-05-Transducer Section) for specific transducer overload values.

2. System Overview

The Network Force/Torque (Net F/T) sensor system is a multi-axis force and torque sensor system that simultaneously measures forces Fx, Fy, and Fz and torques Tx, Ty, and Tz. The Net F/T system communicates via EtherNet/IP, CAN Bus, Ethernet, and is compatible with DeviceNet. Optional fieldbus interfaces are also available. The Net F/T's web pages make it easy to set up and monitor.

The Net F/T system supports the following features:

2.1 Multiple Calibrations

The Net F/T can hold up to sixteen different transducer calibrations and each can have a different sensing range. The different calibrations are created with different load scenarios during the calibration process at the factory and stored in the Net F/T.

Multiple calibrations allow you to use a larger calibration for coarse adjustments and smaller calibrations for fine adjustments, or to use the same transducer in two or more very different loading regimes. Contact ATI Industrial Automation for information on obtaining additional transducer calibrations.

The calibration to use is determined by the calibration selected in the active configuration.

2.2 Multiple Configurations

The Net F/T also holds up to sixteen different user configurations. Each configuration is linked to a user-selected calibration and may have its own tool transformation. Configurations are useful when the Net F/T is used in a variety of tasks. The currently active configuration is user selected on the Net F/T's Settings web page.

2.3 Force and Torque Values

The Net F/T outputs scaled numbers, or counts, that represent the loading of each force and torque axis. The number of counts per force unit and counts per torque unit is specified by the calibration. If you wish to use different force and torque units (i.e., your transducer is calibrated to use pounds and pound-inches, but you wish to use Newtons and Newton-meters), you can change the output units on the Net F/T's Configurations web page.

2.4 System Status Code

Each Net F/T output data record contains a system status code which indicates the health of the transducer and the Net Box. See [Section 18.1—System Status Code](#) for details.

2.5 Thresholding

The Net F/T is capable of monitoring the force and torque levels of each axis and setting an output code if a reading crosses a threshold you define. The Net F/T can hold up to sixteen thresholds, and each threshold can be enabled and disabled individually or as a group. You can set up thresholding on the Net F/T's Thresholding web page.

2.6 Tool Transformations

The Net F/T is capable of measuring the forces and torques acting at a point other than the factory-defined point-of-origin (also known as the sensing reference frame origin). This change of reference is called a tool transformation. You specify tool transformations for each configuration on the Net F/T's Configurations web page.

2.7 Multiple Interfaces

The Net F/T system communicates via EtherNet/IP, CAN bus, Ethernet, and is compatible with DeviceNet. Each of these interfaces can be enabled and disabled on the Net F/T's Communications web page.

2.8 Power Supply

The Net F/T system accepts power through PoE (Power-over-Ethernet) or from a DC power source with an output voltage between 11 V and 24 V.

3. Getting Started

This section gives instructions for setting up the Net F/T system.

3.1 Unpacking

- Check the shipping container and components for damage that occurred during shipping. Any damage should be reported to ATI Industrial Automation.
- Check the packing list for omissions.
- Standard components of a Net F/T system are:
 - Net F/T Transducer
 - Transducer cable (which may be integral to the transducer)
 - Net Box
 - ATI Industrial Automation CD containing software, calibration documents, and manuals (including this manual).
- Optional components:
 - Power supply: Plugs into a 100–240 VAC (50–60 Hz) power outlet and supplies power to the Net Box through the Pwr/CAN connector
 - Ethernet switch supporting Power-over-Ethernet: Provides network connection and supplies power over the Ethernet connector
 - RJ45 to M12 Ethernet cable adapter
 - Mini to Micro (M12) DeviceNet adapter (for the Pwr/CAN connector)
 - DeviceNet cabling (for the Pwr/CAN connector)
 - Ethernet cabling
 - Robot-grade transducer cables of different lengths.

3.2 System Components Description

The Net F/T sensor system is a multi-axis force and torque sensor system that simultaneously measures forces F_x , F_y , F_z , and torques T_x , T_y , and T_z . The Net F/T system provides EtherNet/IP, CAN bus, and Ethernet communication interfaces and is compatible with DeviceNet.


In [Figure 3.1](#), the main components of the Net F/T system are displayed.

The **Net F/T Transducer** converts the force and torque loads into electrical signals and transmits them over the transducer cable. With the exception of very tiny transducers, like the Nano and Mini series, the signals are digital. The Nano and Mini series transducers are too small for on-board electronics and transmit analog signals.

The **Transducer Cable** is detachable and replaceable on transducers that use digital transmission. On other transducers, like the tiny Nano and Mini series, the transducer cable is an integral part of transducer and cannot be detached.

The **Net Box** is an IP65-rated aluminum housing that contains the power supplies and network interfaces. A digital-input version of the Net Box (NETB) is used with digital transducers while an analog-input version of the Net Box (NETBA) is used with analog transducers.

Figure 3.1—Net F/T System Components




3.2.1 F/T Transducer

The transducer is a compact, rugged, monolithic structure that senses forces and torques.

The F/T transducer is commonly used as a wrist transducer mounted between a robot and a robot end-effector. *Figure 3.2* shows a sample transducer.

For further information not in this section, refer to F/T Transducer Manual (9620-05-Transducer Section—Installation and Operation Manual.)

Figure 3.2—Sample Transducer (Omega160)



NOTICE: The transducer is designed to withstand extremely high overloading because of its construction using strong materials and quality silicon strain gages.

3.2.2 Transducer Cable

The Transducer Cable delivers power from the Net Box to the transducer and transmits the transducer's strain gage data back to the Net Box.

Transducers with on-board electronics (ATI Industrial Automation part number prefix 9105-NET) are connected to the Net Box (ATI Industrial Automation part number prefix 9105-NETB) via industry standard M12 Micro DeviceNet cabling. Any DeviceNet-compatible cable with correct gender M12 Micro connectors can be used, but non-IP rated transducers are not compatible with right-angled connectors. ATI Industrial Automation supplies a robotic grade high-flex transducer cable with each Net F/T system. Many other DeviceNet cable choices are available to address different requirements. In case of special requirements, contact ATI Industrial Automation or an industrial cable manufacturer (see www.turck.com, www.woodhead.com, and others) for available products.



WARNING: Transducers are not compatible with DeviceNet. Do not attempt to directly connect a transducer to a DeviceNet network. Transducers must be connected to a Net Box.

ATI's 9105-C-MTS-MS cables can be connected to each other to make a multi-section cable.

NOTICE: If a transducer is accidentally connected to a DeviceNet network, neither the transducer nor the network will be physically harmed. Communication errors may occur on the DeviceNet network while the transducer is connected.

Transducers that do not have on-board electronics (ATI Industrial Automation part number prefix 9105-TW) usually have integral cabling. Those that require cabling must use an ATI Industrial Automation cable specifically made for these transducers. Transducers without the on-board electronics connect to Net Box version 9105-NETBA.

The transducer can be used in a variety of applications that will affect how best to route the cable and determine the proper bending radius to use. Some applications will allow the transducer and the cable to remain in a static condition, other applications require the transducer to be in a dynamic condition that requires the cable to be subjected to repetitive motion. It is important not to expose the transducer cable connectors to this repetitive motion, and properly restrain the cable close to the transducer connection. Refer to (9620-05 Transducer Section) manual for proper cable routing and bending radius instructions.



CAUTION: Do not subject the transducer cable connector to the repetitive motion of the robot or other device. Subjecting the connector to the repetitive motion will cause damage to the connector. Restrain the cable close to the connector to keep the repetitive motion of the robot from affecting the cable connector.

3.2.3 Net Box

The primary function of the Net Box is to process and communicate the transducer's force and torque readings to the user's equipment. Communication can be done through Ethernet, EtherNet/IP, and CAN Bus. The Net Box also responds to DeviceNet commands sent over the CAN Bus connection.

The Net Box should be mounted in an area that it is not exposed to temperatures outside of its working range (see [Section 19.1—Environmental](#)). It is designed to be used indoors in a non-dynamic, non-vibratory environment and may be mounted in any orientation. It is designed to meet IP65 ingress protection.

The Net Box should be grounded through at least one of the four mounting tabs.

The Net Box receives power through either a standard PoE (Power-over-Ethernet) switch or the Pwr/CAN connector.


3.3 Connecting the System Components

3.3.1 Connecting the Transducer to the Net Box

The Net F/T system normally ships with an off-the-shelf standard M12 DeviceNet cable to connect the transducer to the Net Box.

Plug the female M12 connector of this cable into the male M12 socket of the transducer. Then tighten its sleeve clockwise to lock the connector. See [Section 19.3.2—Mating Connectors](#) for recommended connector torque levels.

Figure 3.3—Connecting Transducer Cable to Transducer and Net Box



Plug the male M12 connector into the female M12 socket marked Transducer. Then turn its sleeve in a clockwise direction until tightened to lock it to the socket. See [Section 19.3.2—Mating Connectors](#) for recommended connector torque levels.

To avoid disturbed transducer signals, especially in a noisy environment and when using long transducer cables, it is highly recommended to provide a low impedance ground connection for the transducer body.

3.3.2 Providing Power to the Net F/T

There are two ways to provide power to a standard Net F/T. Net F/Ts with an optional fieldbus interface do not support PoE and must use an external power source (Method 2).

3.3.2.1 Method 1: Providing Power with PoE


NOTICE: Power-over-Ethernet is not supported by Net F/Ts that have an optional fieldbus.

The Net F/T's Power over Ethernet input is compatible with IEEE 802.3af (Power over Ethernet) specification and uses Mode A to receive power. Mode B requires eight Ethernet conductors and is not supported.

The Net F/T system optionally ships with a PoE Ethernet switch. ATI Industrial Automation part number 9105-POESWITCH-1 (see [Figure 3.4](#)), which provides PoE (Power-over-Ethernet) on four ports with RJ45 receptacles. Any PoE enabled device can get its power supply and communication signals from one of these ports. Any non-PoE device connected to these ports will receive an Ethernet connection without the power delivery. The Net F/T system accepts PoE and thus only needs one cable connection to function on an Ethernet network.

- Connect the PoE switch to its external AC power supply.
- Connect the AC power supply to the AC mains. The PWR LED should turn on and glow green.
- Connect the PoE switch to your Ethernet network and connect the Net Box via RJ45 cable to one of the PoE ports. See [Section 3.3.3—Connecting to Ethernet](#) for information on making an Ethernet connection.

Figure 3.4—Connecting to the Ethernet




Once the Net Box is connected to the PoE switch, it should start up, first with red and green blinking LEDs. After approximately 20 seconds all LEDs should be green.

NOTICE: If power is not provided to the Pwr/CAN connection then CAN bus baud rate, CAN bus base address, and DeviceNet MAC IDs are not correctly reported and communications over the Pwr/CAN connector are not available.

3.3.2.2 Method 2: Providing Power to Pwr/CAN Input

Instead of supplying power with the PoE option, you can use the 11 V to 24 V DC power input of the M12 Pwr/CAN connector. See [Section 19.3.2—Mating Connectors](#) for recommended connector torque levels.


Figure 3.5—Pwr/CAN Micro Connector (view from male pin side)



The Net F/T may ship with an optional power adapter (ATI PN 9105-NETPS) that directly connects to the Pwr/CAN connector and delivers sufficient power for the Net F/T system.

Instead of using this power adapter, you can connect to your own DC power source as long as you provide sufficient voltage and current (see [Section 19.3.2—Mating Connectors](#) for details) to the V+, V- inputs of the Pwr/CAN connector. ATI Industrial Automation offers an optional M12 female connector with screw terminals (ATI PN 1510-2312000-05) for field wiring to connect to your power source. Please note that although the connector provides access to CAN_H, CAN_L, and Drain connections, these pins should be left unconnected if they are not being used for CAN communications.

Figure 3.6—DC Power Source Connection (Using Pwr/CAN Connector)




3.3.3 Connecting to Ethernet

This section describes how to physically connect to Ethernet. See [Section 3.4—IP Address Configuration for Ethernet](#) for information on configuring your Net F/T's Ethernet settings and [Section 3.5—Connecting to Ethernet using a Windows Computer](#) for information on configuring a Windows XP or Windows Vista computer.

An industrial M12-4 Type-D Connector is provided for Ethernet connection. See [Section 19.3.2—Mating Connectors](#) for recommended connector torque levels. The Net F/T system optionally ships with an off-the-shelf M12 Industrial Ethernet cable and/or an M12 to RJ45 adapter. The adapter allows the use of standard office-grade Ethernet cables with RJ45 connectors.

Figure 3.7—Ethernet M12-4, Type-D Connector (view from female pin side)



There are two ways that the Net Box can connect to Ethernet.


NOTICE: To achieve the best Ethernet performance (and to reduce the likelihood of losing data), we recommend connecting the Net Box directly to the host computer, as described in Option 2.

3.3.3.1 Option 1: Connect to an Ethernet Network

Use the M12 to RJ45 adapter to connect a standard RJ45 Ethernet cable to the Net Box. Be certain to tighten the sleeve fully clockwise to lock the connector.

Plug the other end of the Ethernet cable into the port of an Ethernet switch. See [Figure 3.8](#) for a proposed setup.

Figure 3.8—Connecting to Ethernet




3.3.3.2 Option 2: Connect directly to a Computer's Ethernet Interface

The Net F/T system is connected directly to a computer's Ethernet port via a cable and is not connected to an Ethernet switch. Use the M12 to RJ45 adapter to connect a standard RJ45 Ethernet cable to the Net box. The most basic configuration would be a point-to-point connection between a computer's Ethernet interface and the Net F/T's Ethernet interface (see [Figure 3.9](#)). In this case, power has to be provided via the Pwr/CAN connector (see [Section 3.3.2.2—Method 2: Providing Power to Pwr/CAN Input](#) for details). This configuration has the lowest latency and lowest chance of lost data packages and provides the best high-speed connection.

If necessary, the computer may be connected to an Ethernet network via a second Ethernet port on the computer. Note that most computers do not have a second Ethernet port and one may need to be installed. Doing so is outside the scope of this document. Contact your IT department for assistance.

Figure 3.9—Point-to-Point Ethernet Connection



3.4 IP Address Configuration for Ethernet

The Net F/T system's IP address settings are only loaded upon power up, consequently the Net F/T must be power cycled for new IP address setting changes to be used. There are three methods the Net F/T system's IP address can be configured.

Method 1: Set IP address 192.168.1.1 by setting DIP switch 9 to the ON position.

Method 2: Set IP address to a static value stored on the Net F/T's Communication Settings web page (DIP switch 9 must be in the OFF position). This method is described in [Section 3.5—Connecting to Ethernet using a Windows Computer](#).

Method 3: Let a DHCP server take care of the IP address assignment (DIP switch 9 must be in the OFF position). This option can be enabled in the Net F/T's web pages (see [Section 3.5—Connecting to Ethernet using a Windows Computer](#) for details). To use this method, a DHCP server must be present in the network. This is usually the case in company networks.

The Net F/T is shipped with DHCP enabled and the static IP address set to 192.168.1.1. The static IP address is automatically used if the network does not support DHCP. DHCP will not be used if a LAN connection is absent during power up.

3.5 Connecting to Ethernet using a Windows Computer

Most of the Ethernet configuration is performed via the Net F/T's web pages. To initially access the web pages, you will need to configure your Net F/T to work on your network by getting it assigned an IP address and telling it some basic information about your network.

For purposes of this initial connection, your computer will be connected directly to the Net F/T and disconnected from your LAN. You will be temporarily giving your computer a fixed IP address of 192.168.1.100. It is important that the Ethernet cable to the Net F/T is disconnected from your computer during this step.


NOTICE: If your computer has multiple connections to Ethernet, such as a LAN connection and a wireless connection, be sure to select the LAN that will be connected to the Net F/T.

1. Unplug the Ethernet cable from the LAN port on your computer.
2. Open your computer's Internet Protocol (TCP IP) Properties window. Follow the instructions below for your computer's operating system.

3.5.1 Windows Vista and Windows 7

- a. From the Start menu, select Control Panel.
- b. For Vista, click on Control Panel Home.
- c. Click on the Network and Internet icon.
- d. Click on the Network and Sharing Center icon.
- e. For Vista, click on the Manage Network Connections task link. For Windows 7, click on the Local Area Connection link.
- f. For Vista, right-click on Local Area Connection and select the Properties button. For Windows 7, click on the Properties button.
- g. Select Internet Protocol Version 4 (TCP/IPv4) connection item and click on the Properties button.


Figure 3.10—Windows Vista and Windows 7 Networking Information



3.5.2 Windows XP


- a. From the Start menu, select Control Panel.
- b. Open the Network Connections icon from within the Control Panel. If your Control Panel says Pick a category at the top, you will need to first click on the Network and Internet Connections icon.
- c. Click on the Network Connections icon.
- d. Right-click on Local Area Connection and select Properties.
- e. Select Internet Protocol (TCP/IP) connection item and click on the Properties button.

Figure 3.11—Windows XP Networking Information



3. Record the values and settings shown in the properties window. You will need these later to return your computer to its original configuration.
4. Select the Use the following IP address button.
5. In the IP address: field, enter 192.168.1.100.
6. In the Subnet mask: field, enter 255.255.255.0.
7. Click on the OK button.
8. Click on the Local Area Connection Properties window's Close button.
9. Connect the Net F/T system to your computer's LAN connection using an Ethernet cable. You may need to wait a short while so your computer has time to recognize the connection.
10. Enter the address 192.168.1.1 in your browser to view the Net F/T's Welcome page.

Figure 3.12—The Net F/T's Welcome Page



11. On the left side of the page are menu buttons that link to various pages. Click on the Communications button.

Figure 3.13—The Net F/T's Communications Page (with Fieldbus Option)

System Status: Healthy

Communications

These settings control how the Net F/T communicates with external equipment. Most settings require the Net F/T to be powered off and then back on before they take effect.

To save the values, you must click **Apply**.

Ethernet Network Settings

DIP switch 9 must be off to enable IP Address Mode. If DIP switch 9 is on, then the IP address is set to 192.168.1.1 regardless of the IP Address Mode settings below. A LAN connection must be present at power up for DHCP to function. If DHCP is enabled and no DHCP server is found, then the static IP address will be used.

IP Address Mode:	<input checked="" type="radio"/> DHCP <input type="radio"/> Static IP see above note regarding DIP switch 9
Static IP Address:	192.168.1.1
Static IP Subnet Mask:	255.255.255.0
Static IP Default Gateway:	0.0.0.0
EtherNet/IP Protocol:	<input checked="" type="radio"/> Enabled <input type="radio"/> Disabled
Ethernet/IP O2T Data:	<input checked="" type="radio"/> Enabled <input type="radio"/> Disabled
Ethernet/IP Data Format:	<input checked="" type="radio"/> 32-bit Signed Data <input type="radio"/> 16-bit Unsigned Data
Ethernet MAC Address:	00:16:BD:00:0D:11

Fieldbus Module Settings

The fieldbus module is not supported in this product.

Fieldbus Module Firmware:

Fieldbus Module Enabled:	<input type="radio"/> Enabled <input checked="" type="radio"/> Disabled
--------------------------	---

CAN Network Settings

If power is not provided to the Pwr/CAN connector, then CAN Bus Base Address, DeviceNet MAC ID, and Baud Rate are not correctly reported and communications over the Pwr/CAN connector are not available.

Protocol:	<input checked="" type="radio"/> CAN Bus <input type="radio"/> DeviceNet
CAN Bus Base Address:	432 set by DIP switches 1 to 6
DeviceNet MAC ID:	54 set by DIP switches 1 to 6 (inaccurate without DeviceNet connection)
Baud Rate:	125 kHz set by DIP switches 7 and 8

Raw Data Transfer (RDT) Settings

RDT data is routed through the local network and does not get routed through the default gateway.

RDT Interface:	<input checked="" type="radio"/> Enabled <input type="radio"/> Disabled demo application requires RDT to be enabled
RDT Output Rate (1 to 7000):	7000 Hz value may be rounded up; see manual for details
RDT Buffer Size (1 to 40):	10
Multi-Unit Synchronization:	<input type="radio"/> Enabled <input checked="" type="radio"/> Disabled
Multi-Unit Id (1 to 9):	1

Modbus TCP Settings

Modbus Server	<input type="radio"/> Enabled <input checked="" type="radio"/> Disabled
Modbus Client	<input checked="" type="radio"/> Enabled <input type="radio"/> Disabled
Modbus Client's Tx Interval (ms)	10
Modbus Client's Server IP Address:	192.168.1.250
Modbus Client's Server Write Register:	0
Modbus Client's Server Read Register	27

Apply **Cancel**

12. Select your IP address mode.

- a. If your IT department gave you settings for a static IP address, enter the appropriate values for the IP address, subnet mask, and default gateway, then press the Apply button. Power cycle the Net Box (if you are using PoE, just unplug the Net Box from PoE switch and then plug it back in). Skip to step 13.
- b. If your IT department gave you settings for DHCP, press the Enabled radio button next to DHCP and then press the Apply button at the bottom. Power cycle the Net Box (if you are using PoE, just unplug the Net Box from the PoE switch and then plug it back in).

Next, determine the IP address assigned to the Net F/T by following the instructions in [Section 6.1—Finding Net F/Ts on the Network](#).

NOTICE: IP addresses assigned by a DHCP server are not permanent and may change if the Net F/T is disconnected from the network for a period of time. Contact your IT department for more information.

13. Open up the TCP/IP properties of your local area connection again. Restore the settings to where they were before you reconfigured them (use the values you recorded in Step 3).
14. Open up a new web browser window, enter the IP address you gave (or the DHCP server has assigned to the Net F/T) the Net F/T system into the browser's address bar, and press Enter. The Net F/T's Welcome page should display again. You can now communicate with the Net F/T over your network without needing to configure the communications settings again.

NOTICE: If the Net FT Configuration Utility found the Net F/T, but the internet browser is unable to open the found IP address, you may need to clear previous device entries from the computer's ARP table by restarting the computer or, if you have administrative privileges, by going to the computer's Start menu, selecting Run..., and entering "arp -d *".

This should only be necessary if another device previously occupied the same IP address that the Net F/T is now using.

3.6 Connecting to an Ethernet-based Fieldbus

Net F/Ts with an optional fieldbus module connect to the fieldbus via the Net F/T's standard Ethernet connection. Although the fieldbus uses the same Ethernet connection as the Net F/T uses for its standard communications, the fieldbus option has its own MAC address and its own IP address. The fieldbus's MAC address is shown as MAC ID 2 on the connector side of the Net Box.

To be used, the fieldbus module option must be enabled on the Net F/T's Communications page.

3.7 Connecting to DeviceNet (using DeviceNet-Compatibility Mode)

The Net F/T system has a DeviceNet compatibility mode which allows operation over a DeviceNet network. The DeviceNet-compatibility mode fully implements all DeviceNet commands. The DeviceNet MAC ID address and baud rate settings follow [Section 3.9—DIP Switches and Termination Resistor](#). For protocol information, refer to [Section 13—DeviceNet-Compatibility Mode Operation](#).

The Net F/T Pwr/CAN connector matches standard DeviceNet connectors and connections. The Pwr/CAN connector mates to a standard female DeviceNet M12 connector.

3.8 Connecting the Net Box to a CAN Bus Network

The Net F/T supports a basic CAN protocol. The CAN Bus base address and baud rate settings follow [Section 3.9—DIP Switches and Termination Resistor](#). For protocol information refer to [Section 15—CAN Bus Operation](#).

3.9 DIP Switches and Termination Resistor


The configuration DIP switches and termination resistor are located inside of the Net Box where they are safely protected from outside debris and liquids. The cover of the Net Box must be removed to gain access to these.

Before opening the Net Box, make sure that the box is not powered and that you and the Net Box are electrically grounded.

To remove the cover, fully loosen each of the four screws that fasten the cover to the Net Box chassis. The cover can then be removed by lifting it straight up and off of the chassis.

The internal electronics have a clear shield to help protect them from debris or errant tool movements. There are access holes in the shield for the DIP switches and termination resistor jumper.

Figure 3.14—Net Box DIP Switches, Termination Resistor and LEDs



Before replacing the Net Box cover, you must ensure that no debris or liquids are in the chassis. To replace the Net Box cover, place the cover back on the chassis (verify that the window is above the LEDs and DIP switches) and tighten the four screws until each is snug.


3.9.1 Termination Resistor

By default, the Net Box ships with a CAN bus termination resistor installed. Remove the termination jumper if you want to disable the internal termination resistor. To remove the termination resistor, you will need to use a pair of tweezers or pliers to pull the jumper off. Safely store the jumper somewhere in case you need to re-enable the termination resistor.

3.9.2 Node Address

By default, the Net Box ships with a CAN Bus base address of 432 and DeviceNet MAC ID of 54. These are defined by the DIP switch settings (see [Figure 3.15](#) for details).

Figure 3.15—Net Box DIP Switches, Termination Resistor and LEDs



Use *Table 3.1* and *Table 3.2* as an aid for finding the switch settings to set the desired address. The numbers on the left side of the colons are the desired MAC ID while the numbers on the right side represent the switch settings for switches 1 through 6 to select the MAC ID. The number 1 represents a switch in the ON position and the number 0 represents a switch in the OFF position.

NOTICE: The Net F/T can operate in either the CAN Bus protocol or the DeviceNet-Compatibility Mode protocol, but not both protocols. The desired protocol can be enabled on the Net F/T's Communications web page.

Both protocols use the same DIP switches to set their address. Be sure to use the correct address table for your protocol.

Table 3.1—CAN Bus Base Address Switch Settings

	123456		123456		123456		123456
0:	000000	128:	000010	256:	000001	384:	000011
8:	100000	136:	100010	264:	100001	392:	100011
16:	010000	144:	010010	272:	010001	400:	010011
24:	110000	152:	110010	280:	110001	408:	110011
32:	001000	160:	001010	288:	001001	416:	001011
40:	101000	168:	101010	296:	101001	424:	101011
48:	011000	176:	011010	304:	011001	432:	011011
56:	111000	184:	111010	312:	111001	440:	111011
64:	000100	192:	000110	320:	000101	448:	000111
72:	100100	200:	100110	328:	100101	456:	100111
80:	010100	208:	010110	336:	010101	464:	010111
88:	110100	216:	110110	344:	110101	472:	110111
96:	001100	224:	001110	352:	001101	480:	001111
104:	101100	232:	101110	360:	101101	488:	101111
112:	011100	240:	011110	368:	011101	496:	011111
120:	111100	248:	111110	376:	111101	504:	111111

Table 3.2—DeviceNet MAC ID Address Switch Settings							
	123456		123456		123456		123456
0:	000000	16:	000010	32:	000001	48:	000011
1:	100000	17:	100010	33:	100001	49:	100011
2:	010000	18:	010010	34:	010001	50:	010011
3:	110000	19:	110010	35:	110001	51:	110011
4:	001000	20:	001010	36:	001001	52:	001011
5:	101000	21:	101010	37:	101001	53:	101011
6:	011000	22:	011010	38:	011001	54:	011011
7:	111000	23:	111010	39:	111001	55:	111011
8:	000100	24:	000110	40:	000101	56:	000111
9:	100100	25:	100110	41:	100101	57:	100111
10:	010100	26:	010110	42:	010101	58:	010111
11:	110100	27:	110110	43:	110101	59:	110111
12:	001100	28:	001110	44:	001101	60:	001111
13:	101100	29:	101110	45:	101101	61:	101111
14:	011100	30:	011110	46:	011101	62:	011111
15:	111100	31:	111110	47:	111101	63:	111111

Setting DIP switches 1 through 8 to ON will enable both DeviceNet MAC ID and baud rate to be set by software. If switches 7 or 8 are OFF then the DeviceNet MAC ID will not be set by software.

3.9.3 Baud Rate

By default, the Net Box ships with a baud rate of 500 kbps. This setting is defined by the DIP switch settings (see [Figure 3.15](#) for details).

Use [Table 3.3](#) as an aid for finding the switch settings for the baud rate used by DeviceNet and CAN Bus.


Table 3.3—Baud Rate Switch Settings	
Baud Rate	78
125 kbps:	00
250 kbps:	10
500 kbps:	01
Selected by software:	11

3.10 Baud Rate


The status LEDs indicate the general health and connectedness of the Net F/T. [Table 3.4](#) and [Table 3.5](#) describe the possible LED states and meanings.

Figure 3.16—Status LEDs

a) Standard Net Box



b) Net Box with Fieldbus Module Option



3.11 Power-Up Cycle

With the transducer connected to the Net Box and the Net Box connected to an Ethernet network, the following should happen when you apply power to the Net Box:

- For the standard Net Box, all status LEDs blink green then red once in this order: MS, NS DN, NS EN, LS EN, Sat, and Xdcr. For the fieldbus Net Box, the LEDs blink green once then red once in this order: MS, EN1, NS/BF, Sat, and Xdcr. The EN2 LED does not blink in the sequence.
- Next the Xdcr LED glows red and the MS LED blinks red. The LS EN LED blinks green if the Net Box is connected to the Ethernet network.
- Approximately 20 seconds after power up, the MS and Xdcr LEDs should display green. This signals that the data acquisition system is now functioning.
- Refer to [Section 18—Troubleshooting](#) if the Net F/T does not power up as described above.

Table 3.4—Standard Net Box Status LED Descriptions

Status LED Function	Name on PCB	LED State	Description
Module Status	MS	Off	No power
		Green	Correct operation
		Flashing Red	Minor fault such as incorrect or inconsistent configuration
DeviceNet Compatibility-Mode Network Status	NS DN	Off	Pending duplicate MAC ID test or DeviceNet protocol not selected (or no power)
		Flashing Green	No connection to DeviceNet network
		Solid Green	DeviceNet master connected
		Flashing Red	DeviceNet I/O connection(s) timed out
EtherNet/IP Network Status	NS EN	Off	EtherNet/IP is disabled or no IP address (or no power)
		Flashing Green	IP address is assigned, but no connection to EtherNet/IP network
		Green	EtherNet/IP network connected
		Flashing Red	EtherNet/IP connection(s) timed out
Ethernet Link Status	LS EN	Off	No link (or no power).
		Green	Link
		Solid Amber	Port disabled
		Flashing Green	Port activity
		Flashing Amber	Ethernet data collision
		Red	Major on-board Ethernet fault
Transducer Saturation	Sat	Off	Transducer load is appropriate (or no power)
		Red	Transducer has too much load and is saturated. This causes system load outputs to be invalid.
Sensor Link Status	Xdcr	Green	Data acquisition system functioning properly.
		Red	Data acquisition system error or power-up sequence is being executed.

Table 3.5—Fieldbus Net Box Status LED Descriptions

Status LED Function	Name on PCB	LED State	Description	
Module Status	MS	Off	No power	
		Green	Correct Operation	
		Flashing Red	Minor fault such as incorrect or inconsistent configuration	
Ethernet Link Status	EN1	Off	No Ethernet link (or no power)	
		Green	Ethernet link established	
		Flashing Green	Ethernet activity	
Fieldbus Option Status	EN2	Off	Fieldbus disabled (or no power)	
		Green	Fieldbus connected	
		Flashing Amber	Fieldbus activity	
		Amber		
Network Status/Bus Failure	NS/BF	The NS/BF LED displays only the status of the highest priority bus connected. The priorities are as follows, in order of highest to lowest: Fieldbus, EtherNet/IP, DeviceNet.		
		Off	Bus	Description
			PROFINET	Network connected (or no power)
			EtherNet/IP	No IP address assigned or network disabled (or no power)
		Green	DeviceNet	Pending duplicate MAC ID test or network disabled (or no power)
			Bus	Description
			PROFINET	N/A
			EtherNet/IP	Network connected
		Flashing Green	DeviceNet	DeviceNet master connected
			Bus	Description
			PROFINET	N/A
			EtherNet/IP	IP address assigned without connecting to network
		Flashing Red	DeviceNet	No connection to network
			Bus	Description
			PROFINET	Duplicate IP address found
			EtherNet/IP	Duplicate IP address found or EtherNet/IP network
		Red	DeviceNet	Network error
Transducer Saturation	Sat	Off	Transducer load is appropriate (or no power)	
		Red	Transducer has too much load and is saturated. This causes system load outputs to be invalid	
Transducer Link Status	Xdcr	Green	Data acquisition system functioning properly	
		Red	Data acquisition system error or power-up sequence is being executed	

4. Web Pages

The Net F/T's web pages provide full configuration options for the Net F/T sensor system. There are several pages, which can be selected by the menu bar toward the top of the webpage.

The Net F/T's web pages use simple HTML and browser scripting and the pages do not require any plug-ins. If browser scripting is disabled some non-critical user interface features are not available. The demo program is written in Java and requires Java to be installed on the computer.

The system status is displayed on all pages near the top of the page. This is the system status at the time the page was loaded. To display the current system status the page must be reloaded. Possible system status conditions are listed in [Section 18.1—System Status Code](#).

Figure 4.1—Menu Bar




4.1 Welcome Page (index.htm)

By entering the Net F/T IP address into the browser address field, you will get to the Net F/T home page, the Welcome page.

The Welcome page gives a quick overview of the Net F/T's main functions. The bottom of the page lists the active configuration and the calibration used by this configuration.

Figure 4.2—Welcome Page



4.2 Snapshot Page (rundata.htm)

This page allows you to view the current transducer loading, the maximum and minimum peaks (if peak monitoring is enabled on the Settings page), and the status of thresholding conditions.

The information displayed on this page is static and does not update after the page is loaded. To see current information the page must be reloaded.

Figure 4.3—Snapshot Page

The screenshot shows the ATI Industrial Automation Snapshot Page. The top header includes the ATI logo, "INDUSTRIAL AUTOMATION", "ISO 9001 Registered", and "Engineered Products for Robotic Productivity". The top right corner shows "Net F/T Force/Torque Sensor" and an image of a sensor. The left sidebar has a menu with options: Welcome, Snapshot (selected), Demo, Settings, Thresholding, Configurations, Communications, System Info, and ATI Web Site. The main content area is titled "Loading Snapshot" and contains the following sections:

- System Status:** Healthy
- Transducer Loading Snapshot (User Units):**

Force/Torque	Fx	Fy	Fz	Tx	Ty	Tz
Data:	42.175	47.405	-54.23	2.2527	-1.348	3.3286
Minimum Peaks:	2147.4	2147.4	2147.4	2147.4	2147.4	2147.4
Maximum Peaks:	-2147	-2147	-2147	-2147	-2147	-2147
- Transducer Loading Snapshot (Counts):**

Force/Torque	Fx	Fy	Fz	Tx	Ty	Tz
Data:	42180100	47371426	-54355365	2250059	-1347521	3327667
Minimum Peaks:	2147483647	2147483647	2147483647	2147483647	2147483647	2147483647
Maximum Peaks:	-2147483648	-2147483648	-2147483648	-2147483648	-2147483648	-2147483648
- Strain Gage Data:**

Biased Gage Data:	G0 -3423	G1 -1895	G2 -5420	G3 -16559	G4 516	G5 -6404
Unbiased Gage Data:	G0 -3428	G1 -1889	G2 -5415	G3 -16547	G4 521	G5 -6406

Range: -32768 to +32767
- Thresholding Status:**

Thresholds Breached:	0x00000000 statements bitmapped into lower two bytes
Thresholds Output:	0x00
Threshold Latched:	0 <input type="button" value="Reset Latch"/>

At the bottom right of the main content area is a "Refresh Page" button.

Transducer Loading Snapshot (User Units):

- Force/Torque Data: Displays the force and torque data scaled in the user units selected in the Configurations page. If any strain gages are saturated, these values will be invalid and displayed in red with a line through them.
- Minimum Peaks: Displays the minimum peak values captured scaled in the user units selected in the Configurations page.
- Maximum Peaks: Displays the maximum peak values captured scaled in the user units selected in the Configurations page.

Transducer Loading Snapshot (Counts):

- Force/Torque Data: Displays the force and torque data scaled with the Counts per Force and Counts per Torque displayed in the Configurations page. If any strain gages are saturated, these values will be invalid and displayed in red with a line through them.
- Minimum Peaks: Displays the minimum peak values captured scaled with the Counts per Force and Counts per Torque displayed in the Configurations page.
- Maximum Peaks: Displays the maximum peak values captured scaled with the Counts per Force and Counts per Torque displayed in the Configurations page.
- Reset Peaks button: Clears the captured peaks and reloads the Snapshot page.
- Bias button: Tares the force and torque values at the current readings and reloads the Snapshot page. This sets the current load level as the new zero point. This can be undone by setting the Software Bias Vector to all zeros on the Settings page.

Strain Gage Data:

- Biased Gage Data: Displays the transducer's strain gages minus the software bias vector.
- Unbiased Gage Data: Displays the transducer's raw strain gage information for easy troubleshooting of saturation errors. Saturated strain gage values are displayed in red.

NOTICE: When saturation occurs, the reported force and torque values are invalid.

NOTICE: Individual strain-gage values do not correspond to individual force and torque axes.

NOTICE: The transducer readings on this page are captured as the web page requests them. It is possible that the readings towards the bottom of the page come from later F/T data records than the readings towards the top of the page.

Thresholding Status:

- Thresholds Breached: Indicates which threshold conditions are or have been true since the last reset latch function execution. Each bit in the lower two bytes of this hexadecimal number represents a thresholding statement. *Table 4.1* shows the bit pattern representing each thresholding statement number. The Thresholds Breached value is the result of or'ing the bit patterns for all true statements together. The Thresholds Breached value is cleared to zero by the reset latch function.

Table 4.1—Bit Patterns for Thresholds Breached							
#:	Bit Pattern	#:	Bit Pattern	#:	Bit Pattern	#:	Bit Pattern
0:	0x00000001	4:	0x00000010	8:	0x00000100	12:	0x00001000
1:	0x00000002	5:	0x00000020	9:	0x00000200	13:	0x00002000
2:	0x00000004	6:	0x00000040	10:	0x00000400	14:	0x00004000
3:	0x00000008	7:	0x00000080	11:	0x00000800	15:	0x00008000

- Thresholds Output: Displays the Thresholds Output value set by bitwise or'ing the Output Codes of all true thresholding statements.
- Threshold Latched: Displays a one if any threshold conditions are or have been true. The Threshold Latched value is cleared to zero by the reset latch function.
- Reset Latch button: Clears any threshold latching and reloads the Snapshot page. If no threshold conditions remain true then Thresholds Breached, Thresholds Output, and Threshold Latched will all be set to zero and the System Status: Threshold Level Latched condition will be cleared.
- Refresh Page button: Reloads the Snapshot page with updated values. This is the same as using the browser's reload or refresh command.

4.3 Demo Page (demo.htm)

This page allows you to download the Java Demo Application, which is described in [Section 5—Java Demo Application](#).


Figure 4.4—Demo Page



4.4 Settings Page ([setting.htm](#))

This page allows you to choose the active configuration and to specify certain global settings that are effective across all configurations, such as filtering, peak monitoring, and the bias (offset) vector. Changes on this page are not implemented until the Apply button is clicked.

Figure 4.5—Settings Page



- Active Configuration: Selects one of sixteen configurations to be applied to the force and torque readings. See [Section 4.6—Configurations Page \(config.htm\)](#) for more information on configurations.
- Low-Pass Filter Cutoff Frequency: Selects the cutoff frequency for low-pass filtering. Selecting No Filter disables low-pass filtering. See [Section 19.2—Transducer Data Filtering](#) for filter information.
- Peaks Monitoring: If enabled, each axis's lowest and highest F/T values will be saved as minimum and maximum peaks. The Reset Peaks button clears the peaks. You can find the Reset Peaks button on the Snapshot web page.
The Peak Measurement feature can be useful for crash detection and during teaching or finding out how close the application gets to the transducer's limits.
- Software Bias Vector: This is the bias offset applied to the transducer strain gage readings. Clicking the Bias button on the Snapshot web page will change these values. This bias may be removed by setting the software bias vector to all zeros.
Note that the strain gage readings do not have a one to one correspondence to force and torque readings.
- User Authentication: Allows you to set a user name and password for accessing all pages of the Net F/T except the “Welcome” screen. The password can be reset by flipping DIP switch 9 on and off 5 times with no more than two seconds between two consecutive “on” flips, which blanks out the password field and disables the user authentication until a password is entered.

4.5 Thresholding Page (moncon.htm)

This page allows you to set up threshold conditions. Threshold conditions compare the transducer readings to simple user-defined threshold statements. When threshold monitoring is enabled and a sample is read that satisfies one or more of the active threshold conditions, the user-defined output code for all threshold conditions satisfied by that sample are bitwise or'ed together to form the threshold output (in practice, it is very unlikely that more than one threshold sample will be satisfied in a single sample). The threshold monitoring latch is then set, and threshold monitoring is then paused until a command to reset the threshold monitoring latch is received. The threshold output is available on the Snapshot page.

Each threshold condition can be configured for:

- the axis to monitor
- the type of comparison to perform
- the threshold value to use for the comparison
- the output code to send when the comparison is true

Figure 4.6—Thresholding Page

System Status: Healthy

Thresholding

When **Threshold Monitoring** is enabled, the Net F/T compares transducer force and torque values to the **Threshold Conditions** that are turned on. The **Output Codes** for all true conditions are combined to form the **Thresholds Output**.

The **Units** column displays the force or torque counts value in user units. To update the **Units** column, click **Apply**.

To save the values, you must click **Apply**.

Thresholding Settings

When **Relay Trigger Item Any condition is true** is selected, the **Thresholds Output** is the result of a bitwise-OR operation on valid **Output Codes**. When **All conditions are true** is selected, a bitwise-AND operation is performed.

Threshold Monitoring: Enabled Disabled

Relay Trigger: Any condition is true All conditions are true

Relay Behavior: Momentary Latching Reset Latch

Relay Momentary Minimum-On Time: 1 ×0.1 seconds only applies when **Relay Behavior** is set to **Momentary**

WARNING: In systems without the solid-state relay option, setting this value to 0 could cause premature relay failure due to excessive activation.

Threshold Conditions:	N	On/Off	If	Axes	Comparison	Counts	Units	Output Code
0	<input type="radio"/>	<input checked="" type="radio"/>	If	Fx	>	-400031744	-400.03 N	Then 0x00
1	<input type="radio"/>	<input checked="" type="radio"/>	If	Fx	>	0	0 N	Then 0x00
2	<input type="radio"/>	<input checked="" type="radio"/>	If	Fx	>	0	0 N	Then 0x00
3	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
4	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
5	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
6	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
7	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
8	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
9	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
10	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
11	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
12	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
13	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
14	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00
15	<input type="radio"/>	<input checked="" type="radio"/>	If		>	0	0 N	Then 0x00

Counts range: -2147483648 to +2147483647; Output code range: 0x00 to 0xFF

Status of Thresholds: Use the **Get Statuses** button to update this static display of threshold statuses. Threshold numbers are crossed out if the threshold is unsatisfied. The On/Off setting for the threshold is ignored in this display.

Get Statuses **Apply** **Cancel**

In case of any enabled threshold condition becoming true, the following will occur:

- The threshold's output code is updated.
- Bit 16 of the system status code (see [Section 18.1—System Status Code](#)) will be set to one.
- The threshold relay will close, connecting pin 3 to pin 4 of the Threshold Relay connector (see Figure 4.7—Standard Net Box Threshold Relay Connector Pin Assignment (Male-pin side view)).

Bit 16 and the threshold relay will hold these states until a reset latch command is sent. The reset latch command can be sent by clicking the Reset Latch button on the Snapshot web page. See [Section 4.2—Snapshot Page \(rundata.htm\)](#) for additional information.

Threshold Condition Elements:

N: Statement number.

On / Off: Selects which statements are to be included in the processing of threshold conditions.

Axis: Selects the axis to be used in the comparison statement. Available axes are:

Table 4.2—Thresholding Statement Axis Selections

Menu Value	Description
blank	Statement disabled
Fx	Fx axis
Fy	Fy axis
Fz	Fz axis
Tx	Tx axis
Ty	Ty axis
Tz	Tz axis

Comparison: Selects the type of comparison to perform. Available comparisons are:

Table 4.3—Thresholding Statement Comparison Selections

Menu Value	Description
>	Greater Than
<	Less Than

Counts: The loading level to be compared to the transducer reading. This value is displayed in the units of the active configuration after the Apply button is clicked.

To determine the Counts value to use from a value in user units, multiply the value in user units by Counts per Force (or Counts per Torque if appropriate).

Example:

Desired Loading Level 6.25 N

Force Units: N (from Configurations page)

Counts per Force value 1000000 (from Configurations page)

$$\begin{aligned} \text{Counts} &= \text{Desired Loading Level} \times \text{Counts per Force} \\ &= 6.25 \text{ N} \times 1000000 \text{ counts/N} \\ &= 6250000 \text{ counts} \end{aligned}$$

NOTICE: Comparison levels are stored as counts and only change when the user inputs new counts values. Changing the configuration or the force units or the torque units will not change or adjust the counts values.

Units:	Displays the counts value in the units of the active configuration. This value is only updated after the Apply button is clicked.
Output Code:	When this statement's comparison is found true, this 8-bit value will be bitwise or'ed with the Output Code values of all other true statements to form the threshold output. Any set bits remain latched until Reset Latch is called. If no statements have been true the threshold output will be zero.
	The value is displayed in hexadecimal in the format 0x00. Output codes may be entered in the hexadecimal format or they may be entered in decimal.
Reset Latch button:	Clears any threshold latching and reloads the Thresholding page. If no threshold conditions remain true then Thresholds Breached, Thresholds Output, and Threshold Latched will all be set to zero and the System Status: Threshold Level Latched condition will be cleared.

4.5.1 Threshold Relay

The threshold relay closes its contacts when Threshold Latched is true. This allows external electrical equipment to react when this occurs. Possible uses include control of E-stop circuits.

Relay operation is determined by the Relay Trigger, Relay Behavior, and Relay Momentary Minimum-On Time settings.

For increased reliability, it is best to monitor both the normally open (NO) and normally closed (NC) relay contacts. This allows detection of some cabling or relay issues.

The threshold relay contacts (NC, NO, and COM) are protected against overload by a resettable fuse, see [Section 19.3.3—Standard Threshold Relay](#) for electrical specifications.

4.5.1.1 Standard Net Box Threshold Relay

The standard Net Box threshold relay is a mechanical relay used on 9105-NETB, and 9105-NETBA. (The fieldbus Net Box has the solid-state relay described in [Section 4.5.1.2—Fieldbus Net Box and Optional Solid State Threshold Relay](#)).

Figure 4.7—Standard Net Box Threshold Relay Connector Pin Assignment (Male-pin side view)




Table 4.4—Solid-State Relay Connector Pin Descriptions

Pin	Name	Description
1	NO	Normally open connection
3	NC	Normally closed connection
4	Com	Common



CAUTION: The solid-state relay connections are polarity dependent. A reverse-polarity connection could cause high current flow and damage the Net Box or user equipment.

Figure 4.8—Example Circuit for Standard Net Box Threshold Relay Monitoring





Figure 4.9—Example Circuit for a Relay Interface



The standard threshold relay contacts (NC, NO, and Com) are protected against overload by a self-resetting fuse. The maximum guaranteed fuse hold current is 50 mA.

The relay will completely close its contacts within 6 ms.

4.5.1.2 Fieldbus Net Box and Optional Solid State Threshold Relay

The solid-state relay is standard on 9105-CUSTOM-253, 9105-NETB-ZE3, 9105-NETB-PN and 9105-NETB-PN2, 9105-NETBA-PN and 9105-NETBA-PN2.

The optional solid-state threshold relay has a quicker activation time than the standard threshold relay and no moving parts to wear out.

Figure 4.10—Optional Solid State Relay Connector Pin Assignments (male-pin side view)




Figure 4.11—Solid-State Relay Equivalent Output Circuit





Table 4.5—Solid-State Relay Connector Pin Descriptions

Pin	Name	Description
1	SSR-	Solid-State Relay negative connection
3	SSR+	Solid-State Relay positive connection
4	-	unused

The solid-state relay can operate at up to 30 VDC and at a maximum current of 35 mA. The relay can turn on within 500 µs of a trigger load. The output is reverse polarity protected to up to 1 A ($V_r = 1.5$ V), 47 V. The maximum delay from threshold condition trigger to relay conduction is 500 µs.

Figure 4.12—Example Connections to Solid-State Relay



4.6 Configurations Page (config.htm)

This page allows you to specify the output parameters of the sensor system. Up to sixteen configurations can be defined. Changing configurations allows a different transducer calibration and tool transformation to be used. Changes on this page are not implemented until the Apply button is clicked.

Figure 4.13—Configurations Page

ATI INDUSTRIAL AUTOMATION
ISO 9001 Registered
Engineered Products for Robotic Productivity

Net F/T
Force/Torque Sensor

System Status: **Healthy**

Configurations

User-defined configurations are displayed on this page. Use the *View Configuration* drop-down list and the *Go* button to display another configuration.

Each configuration loads a transducer calibration. A configuration can select the measurement system used for Force Units and Torque Units. A configuration can also apply a tool transformation to the output data.

After you have created a configuration, you can enable it on the [Settings](#) page.

To save the values, you must click *Apply*.

View Configuration: #1 - 18510c

Configuration #1 (Active configuration)

Configuration Name:	18510c	Maximum of 32 characters				
Calibration Select:	#1 - FT18510					
Calibration Type:	SI-130-10					
Force Units:	N					
Torque Units:	Nm					
Counts per Force:	1000000					
Counts per Torque:	1000000					
Calibrated Sensing Range (Units):	Fx	Fy	Fz	Tx	Ty	Tz
	130	130	400	10	10	10
Calibrated sensing range values apply to the factory origin (without tool transformation).						
Scaling Factor for DeviceNet and CAN:	Fx	Fy	Fz	Tx	Ty	Tz
	12208	12208	12208	306	306	306
Tool Transform Distance Units:	in					
Tool Transform Angle Units:	degrees					
Tool Transform:	Dx	Dy	Dz	Rx	Ry	Rz
	0	0	0	0	0	0
Using a tool transformation will change how transducer readings are reported and change the apparent sensing ranges and apparent resolutions.						
User-defined Field #1:	empty	Maximum of 16 characters				
User-defined Field #2:	empty	Maximum of 16 characters				

View Configuration: Selects the configuration to be viewed and edited. Clicking the Go button updates the page with the selected configuration.

Configuration Name: Defines a name for the configuration.

- Calibration Select: Selects the transducer calibration to use for this configuration. A transducer will have at least one calibration. (Many Net F/T systems will only have one calibration available; an Empty Calibration Selected error will occur if an invalid calibration is selected.)
If a different calibration is selected, the values displayed in fields Calibration Type, Counts per Force, Counts per Torque, Calibrated Sensing Range and Scaling Factor for DeviceNet and CAN will not be updated until the Apply button is clicked.
- Calibration Type: Displays the calibration associated with the selected calibration. If a new calibration is selected, this field will not be updated until the Apply button is clicked.
- Force Units: Selects the force measurement units to use. Available force measurement units are:

Table 4.6—Force Unit Selections	
Menu Value	Description
lbf	Pound-force
N	Newtons
klbf	Kilopound-force
kN	Kilonewton
kgf	Kilogram-force
gf	Gram-force

If new force units are selected, the values displayed in fields Counts per Force and Calibrated Sensing Range are not updated until the Apply button is clicked.

- Torque Units: Selects the torque measurement units to use. Available torque measurement units are:

Table 4.7—Torque Unit Selections	
Menu Value	Description
lbf-in	Pound-force-inch
lbf-ft	Pound-force-feet
Nm	Newton-meter
Nmm	Newton-millimeter
kgf-cm	Kilogram-force-centimeter
kNm	Kilonewton-meter

If new torque units are selected, the values displayed in fields Counts per Torque and Calibrated Sensing Range are not updated until the Apply button is clicked.

- Counts per Force: Force values in counts are equal to the force values in selected units multiplied by this factor. The application program has to divide each force counts value by the Counts per Force value to obtain the real force data. See [Section 10.3—Calculating F/T Values for RDT](#) information and [Section 14.2—Calculating F/T Values for CIP](#) information.

If a new Force Units has been selected, this field will not be updated until the Apply button is clicked.

Counts per Torque: Torque values in counts are equal to the torque values in selected units multiplied by this factor. The application program has to divide each torque counts value by the Counts per Torque value to obtain the real torque data. See [Section 10.3—Calculating F/T Values for RDT](#) information and [Section 14.2—Calculating F/T Values for CIP](#) information.

If a new Torque Units has been selected, this field will not be updated until the Apply button is clicked.

Calibrated Sensing Range: The transducer is calibrated up to these values in the selected force and torque measurement units. This applies to single-axis load conditions at the factory origin (no tool transformation). For complex load conditions, refer to the F/T Transducer Manual (9620-05-Transducer Section—Installation and Operation Manual).

If a new calibration is selected, a new force unit is select, or a new torque unit is selected, this field will not be updated until the Apply button is clicked.

Scaling Factor for DeviceNet and CAN: In order to reduce the amount of data transmitted via DeviceNet or CAN Bus, the force and torque values are reduced to 16 bits using this factor. See [Section 14.2.2—DeviceNet](#) and [Section 15.5—Calculating F/T Values for CAN](#).

Tool Transform Distance Units: This is the distance units used for the distance vector in the tool transformation (see Tool Transform below for details). Available transform distance units are:

Table 4.8—Tool Transform Distance Unit Selections	
Menu Value	Description
In	inch
ft	foot
mm	millimeter
cm	centimeter
m	meter

Changing the Tool Transform Distance Units does not change or rescale the tool transform values.

Tool Transform Angle Units: This is the angular units used for the rotation vector in the tool transformation (see Tool Transform below for details). Available transform angle units are:

Table 4.9—Tool Transform Angle Unit Selections	
Menu Value	Description
degrees	degrees (°)
radians	radians

Changing the Tool Transform Angle Units does not change or rescale the tool transform values.

Tool Transform:

Tool transform offsets are defined here. To keep the transducer's point of origin at the factory-defined location these values need to be all zero. Descriptions of the values and the order in which the values are applied to the factory-defined point of origin are as follows:

Table 4.10—Torque Unit Selections		
Column	Description	Order
Dx	Distance to move X axis	1
Dy	Distance to move Y axis	2
Dz	Distance to move Z axis	3
Rx	Rotation angle about X axis	4
Ry	Rotation angle about Y axis	5
Rz	Rotation angle about Z axis	6

Forces and torques are by default reported with respect to the factory point of origin [*The factory point of origin places the X, Y, and Z axes as shown on the transducer drawings in the F/T Transducer Manual (9620-05-Transducer Section—Installation and Operation Manual)*]. The tool transformation function allows measurement of the forces and torques at some point other than the origin of the transducer. Tool transformations are particularly useful when this point is chosen as the point-of-contact between the robotic end-effector (tool) and the object being worked. A tool transformation can translate the reported origin a distance (Dx, Dy and Dz) from the factory origin and also rotate the reported origin (Rx, Ry and Rz) about the factory origin. A tool transformation allows a coordinate frame to be created that aligns resolved force/torque components with the natural axes of the task geometry.

All transducer working specifications pertain to the factory point-of-origin only. This includes the transducer's range, resolution, and accuracy. The transducer working specifications at a customer-applied point-of-origin will differ from those at the factory point of-origin.

User-defined Field #1: Defines a short note for this configuration.

User-defined Field #2: Defines a second short note for this configuration.

4.7 Communication Settings Page (comm.htm)

This page allows you to view and set system networking options. Usually these settings are set once when the system is first installed and do not need to be changed later.

For information on setting the system to work with your network refer to [Section 3—Getting Started](#).

Figure 4.14—Standard Net Box's Communications Page

The screenshot displays the ATI Industrial Automation Net F/T Force/Torque Sensor Communications Page. The left sidebar lists navigation options: Welcome, Snapshot, Demo, Settings, Thresholding, Configurations, Communications (which is selected), System Info, and ATI Web Site. The main content area has a header "System Status: Healthy".
Ethernet Network Settings: IP Address Mode is set to DHCP. Static IP Address is 192.168.1.1. Static IP Subnet Mask is 255.255.255.0. Static IP Default Gateway is 0.0.0.0. EtherNet/IP Protocol is Enabled. Ethernet/IP O2T Data is Enabled. Ethernet/IP Data Format is 32-bit Signed Data. Ethernet MAC Address is 00:16:BD:00:0D:11.
Fieldbus Module Settings: The fieldbus module is not supported in this product. Fieldbus Module Firmware is Enabled.
CAN Network Settings: If power is not provided to the Pwr/CAN connector, then CAN Bus Base Address, DeviceNet MAC ID, and Baud Rate are not correctly reported and communications over the Pwr/CAN connector are not available. Protocol is CAN Bus. CAN Bus Base Address is 432. DeviceNet MAC ID is 54. Baud Rate is 125 kHz.
Raw Data Transfer (RDT) Settings: RDT Interface is Enabled. RDT Output Rate is 7000 Hz. RDT Buffer Size is 10. Multi-Unit Synchronization is Enabled. Multi-Unit Id is 1.
Modbus TCP Settings: Modbus Server is Enabled. Modbus Client is Enabled. Modbus Client's Tx Interval (ms) is 10. Modbus Client's Server IP Address is 192.168.1.250. Modbus Client's Server Write Register is 0. Modbus Client's Server Read Register is 27.
Buttons: Apply and Cancel.

NOTICE: The Ethernet Network Settings only applies to the standard Ethernet and EtherNet/IP interfaces included in all Net Boxes. The Ethernet Network Settings do not apply to the additional fieldbus interface included in fieldbus Net Boxes.

Ethernet Network Settings:

- Ethernet/IP O2T Data If enabled, the Net F/T accepts a 4-byte output bitmap which is identical to the Profinet bitmap in [Table 16.3](#). If disabled, the Net F/T does not accept any Ethernet IP output data.
- Ethernet/IP Data Format: Changes the Ethernet/IP output data between the current 32-bit values, and 16-bit unsigned values. The 16-bit unsigned values use the same 16-bit scaling factor used by the DeviceNet, CAN, and TCP interface data (see [Figure 14.1](#)), and since they are unsigned, a “no load” value is reported as +32768 counts, a negative full-scale load is reported as approximately 0 counts, and a positive full-scale load is reported as approximately 65536 counts.
- IP Address Mode: Controls how the Net F/T determines its IP Address. If DHCP is selected, it will obtain an IP address from the Ethernet network’s DHCP server. If the Net Box does not receive an address from the DHCP server within 30 seconds after power up, it will default to use the static IP settings. If Static IP is selected, the Static IP Address and Static IP Subnet Mask will be used for the IP address.

NOTICE: DHCP-assigned addresses are not permanent and may change if the Net F/T is disconnected from the network for a period of time. Contact your IT department for more information. If this occurs, you can determine the changed IP address by following the instructions in [Section 6.1—Finding Net F/Ts on the Network](#).

Static IP addresses are often more desirable in permanent Net F/T installations because the address will not change.

- Static IP Address: Sets the static IP address. Refer to [Section 3.4—IP Address Configuration for Ethernet](#) for usage details. Contact your IT department for information on what static IP address to assign.
- Static IP Subnet Mask: Sets the subnet mask portion of the IP address. Many networks use the default 255.255.255.0. Contact your IT department for information on what static IP subnet mask to assign.
- Static IP Default Gateway: Sets the default gateway. Contact your IT department for information on what default gateway to assign.
- EtherNet/IP Protocol: Controls whether or not the Net F/T uses EtherNet/IP. EtherNet/IP is only needed for industrial networks using the EtherNet/IP protocol. Most non-industrial applications will leave EtherNet/IP disabled. DeviceNet protocol must be disabled when EtherNet/IP protocol is enabled.
- Ethernet MAC Address: The unique address given to this Net F/T at the time of manufacture. This address can be used to uniquely identify this Net F/T from other Net F/Ts and other Ethernet devices.

Fieldbus Module Settings (only displays on fieldbus Net Boxes):

- Fieldbus Module Firmware: Displays the type of fieldbus protocol supported by the fieldbus Net Box.
- Fieldbus Module Enabled: If enabled, the Net Box will support the fieldbus protocol listed in Fieldbus Module Firmware. If disabled, then that fieldbus protocol is unavailable to the network.

CAN Network Settings:

Protocol:	Controls which protocol will be used on the Pwr/CAN connector. When CAN Bus is selected the basic CAN protocol described in Section 15—CAN Bus Operation is used. When DeviceNet is selected the DeviceNet-compatibility mode protocol described in Section 13—DeviceNet-Compatibility Mode Operation is used. It is best to select CAN Bus when neither protocol is needed; otherwise a DeviceNet protocol failure will be signaled. EtherNet/IP protocol must be disabled when DeviceNet protocol is enabled.
CAN Bus Base Address:	Displays the base address to be used by the CAN bus protocol. See Section 3.9.2—Node Address for information on setting this address.
DeviceNet MAC ID:	Displays the DeviceNet MAC ID address to be used by the DeviceNet compatibility-mode protocol. See Section 3.9.2—Node Address for information on setting this address.
Baud Rate:	Displays the CAN bus baud rate used by the CAN network. See Section 3.9.3—Baud Rate for information on setting the baud rate.

NOTICE: The values displayed for CAN Bus Base Address, DeviceNet MAC ID, and Baud Rate are only valid if power is supplied to the Pwr/CAN connector. Otherwise indeterminate data is displayed.

Raw Data Transfer (RDT) Settings:

RDT Interface:	If enabled, the Net Box will be allowed to establish a point-to-point UDP connection to a host computer. This is the fastest way to read F/T data from the sensor system. In Section 10—UDP Interface Using RDT the RDT interface is described in detail. RDT data is routed through the local network and does not get routed through the default gateway.
RDT Output Rate:	The rate per second at which the Net Box will send streaming RDT data to a host. It can be adjusted in integer fractions of 7000. (e.g., 7000÷2=3500 or 7000÷3=2333). If you enter a different sample rate, the Net F/T will automatically change to the next higher possible sample rate.
RDT Buffer Size:	The RDT interface can operate in different modes. One of these is the Buffer Mode where the Net Box sends more than one data package per sample. Multiple data packages are buffered and sent in one block. This reduces the amount of overhead data to be sent with the effect of reducing the overall network traffic. The number of data sets per block is the Buffer Mode Size.
Multi-Unit Synchronization:	If enabled, the Net Box will synchronize its RDT data output with other Net F/T sensor systems on the same network. In a network with only one sensor system, this option should be disabled. Refer to Section 10.4—Multi-Unit Mode for details. Multi-Unit IDs must be assigned for this to work correctly.
Multi-Unit ID:	If Multi-Unit Synchronization is enabled, each Net F/T using multi-unit synchronization needs to have a unique ID assigned to it.

Modbus TCP Settings:

Modbus Server: The internal TCP Modbus Server is active whenever it is selected on the Modbus Setting portion of the Communications screen. The Modbus Server supports the following Modbus commands:

- Read Input Registers
- Read Holding Registers
- Write Single Register
- Write Multiple Registers
- Read/Write Multiple Registers

Modbus Client: The internal TCP Modbus Client is active whenever it is selected on the Modbus Setting portion of the Communications screen.

Every “Modbus Client’s Tx Interval” milliseconds the Modbus Client uses the Modbus Read/Write Multiple Registers command to write its internal registers 0 through 26 to the remote Modbus Server registers starting with the register number specified by “Modbus Client’s Server Write Register”. In the same command, it also reads its internal registers 27 to 42 from those in the remote Modbus Server starting with the register number specified by “Modbus Client’s Server Read Register”. The remote Modbus Server is located at the Modbus Client’s Server IP Address.

If the remote Modbus Server reports that it does not support the Modbus Read/Write Multiple Registers command, the register transfers are instead done from then on using the Read Holding Registers and the Write Multiple Registers commands.

4.7.1 TCP Modbus Register Map

Table 4.11—TCP Modbus Register Map

NetBox Register	Corresponding Robot Register	Direction (from NetBox)	Function
0	128	Out	Force X
1	129	Out	Force Y
2	130	Out	Force Z
3	131	Out	Torque X
4	132	Out	Torque Y
5	133	Out	Torque Z
6	134	Out	Status MSB
7	135	Out	Status LSB
8	136	Out	Gage 0
9	137	Out	Gage 1
10	138	Out	Gage 2
11	139	Out	Gage 3
12	140	Out	Gage 4
13	141	Out	Gage 5
14	142	Out	Force Units
15	143	Out	Torque Units
16	144	Out	Scale Factor 0
17	145	Out	Scale Factor 1
18	146	Out	Scale Factor 2
19	147	Out	Scale Factor 3
20	148	Out	Scale Factor 4
21	149	Out	Scale Factor 5
22	150	Out	Counts per Force MSW
23	151	Out	Counts per Force LSW
24	152	Out	Counts per Torque MSW
25	153	Out	Counts per Torque LSW
26	154	Out	Sequence Number
27	155	In	System Commands
28	156	In	Transform Distance Units
29	157	In	Transform Angle Units
30	158	In	Dx * 100
31	159	In	Dy * 100
32	160	In	Dz * 100
33	161	In	Rx * 100
34	162	In	Ry * 100
35	163	In	Rz * 100
36	164	In	MCEnable LSW
37	165	In	MCEnable MSW
38	166	In	WMC index
39	167	In	WMC axis
40	168	In	WMC output code
41	169	In	WMC comparison
42	170	In	WMC compare value

Note: The choice of writing NetBox registers 0 to 26 to UR registers 128 to 154 (and of reading UR registers 155 to 170 into NetBox registers 27 to 42) was arbitrary, and could have used any available set of contiguous UR registers of the same length. If you change Modbus register assignments, make sure that you make the corresponding register number changes in the Demo programs.

4.8 System Information Page (manuf.htm)

The System Information page shows a summary of the system's current state. This page is used during troubleshooting by ATI Industrial Automation. For status codes refer to [Section 18.1—System Status Code](#).

Figure 4.15—System Information Page

The screenshot displays the ATI System Information Page with the following sections:

- Header:** ATI INDUSTRIAL AUTOMATION, ISO 9001 Registered, Engineered Products for Robotic Productivity, Net F/T Force/Torque Sensor.
- Welcome:** System Status: Healthy.
- Snapshot:** Shows a summary of the system's current state.
- Demo:** Not applicable for this page.
- Settings:** Thresholding, Configurations.
- Thresholding:** Not applicable for this page.
- Configurations:** ATI Web Site.
- System Info:** Shows the following data:

	G0	G1	G2	G3	G4	G5
Strain Gage Values:	-3417	-1900	-5423	-16577	520	-6397
Bias Values:	0	0	0	0	0	0

	Fx	Fy	Fz	Tx	Ty	Tz
Force/Torque Counts:	42284806	47380709	-54208072	2254227	-1347560	3331506
Minimum Peak Counts:	2147483647	2147483647	2147483647	2147483647	2147483647	2147483647
Maximum Peak Counts:	-2147483648	-2147483648	-2147483648	-2147483648	-2147483648	-2147483648
Force/Torque Units:	42.293	47.376	-54.11	2.2546	-1.348	3.3300
Minimum Peak Units:	2147.4	2147.4	2147.4	2147.4	2147.4	2147.4
Maximum Peak Units:	-2147	-2147	-2147	-2147	-2147	-2147

	G0	G1	G2	G3	G4	G5
Fx	-50368	7705	41728	-4329266	-47267	4432620
Fy	-187934	5129974	-20789	-2484940	76627	-2537676
Fz	7748199	-321494	7748629	-393635	7845694	-279264
Tx	-3318	117937	-225627	-45366	226017	-66939
Ty	260641	-11905	-129699	106590	-130928	-96062
Tz	4878	-141352	839	-136672	2042	-140246
- Transducer:** Shows strain gage values and bias values.
- Run-time Matrix:** Shows force/torque and torque values.
- Summary of Calibrations and Configurations:**
 - Active Configuration: #1: 18510c
 - Using Calibration: #1: empty

Calibrations	Configurations
Index Serial Number	Index (Calibration Index) Description
1 FT18510	1 (1) 18510c
2 FT18509	2 (2) empty
3 FT0000	3 (1) empty
4 FT0000	4 (1) empty
5 FT0000	5 (1) 18509c
6 FT0000	6 (1) empty
7 FT0000	7 (1) empty
8 FT0000	8 (1) empty
9 FT0000	9 (1) empty
10 FT0000	10 (1) empty
11 FT0000	11 (1) empty
12 FT0000	12 (1) empty
13 FT0000	13 (1) empty
14 FT0000	14 (1) empty
15 FT0000	15 (1) empty
16 FT0000	16 (1) empty
- Digital Board:**
 - Status Word: 0x00000000
 - Ethernet MAC Address: 00:16:8D:00:00:11
 - Serial Number: 0000000
 - Firmware Revision: 2.2.55 Jun 8 2017 ATI Net F/T
 - Hardware Revision: 1.0.0
 - Diagnostic ADC Readings: 0 0 8 599 780 137 511 511
- Analog Board:**
 - Power Up Status Word: 0x0000
 - Serial Number: LOT1221
 - Firmware Revision: 2.1.2
 - Hardware Revision: 09
 - Location: tested

4.9 ATI Web Site Menu Item

This is a link to ATI Industrial Automation's web site. The Net F/T's Ethernet network must be connected to the Internet to reach this web site.


5. Java Demo Application

The Java demo application provides a simple interface to view and collect F/T data from a connected computer. The computer will need to have Java version 6.0 (runtime 1.6.0) or later installed. (Java can be downloaded from www.java.com/getjava.)

5.1 Starting the Demo

The demo can be downloaded from the Demo page. Click the Download Demo Application button and follow your browser's instructions. The file ATINetFT.jar will be downloaded. If the browser does not automatically run the downloaded file, you will need to manually open the file on your computer.


Figure 5.1—Demo Page



NOTICE: The Java Demo requires the Net F/T to have its RDT Interface enabled. RDT is enabled in the Net F/T by default. See [Section 4.7—Communication Settings Page \(comm.htm\)](#) for information on RDT settings.

The demo program opens with the following window:

Figure 5.2—Net Box IP Address Request



If the window does not appear, it may be hidden under the browser window. In this case you may have to minimize the browser window.

Enter the IP address of the Net Box. The IP address of the Net F/T is displayed on the Demo page in the paragraph above the Download Demo Application button. The main window of the Java Demo application should open.

The first time the demo is used it may trigger a firewall alert. This is a normal response for any program that uses the network. In this case it will be necessary to tell the firewall to allow the program to use network connections. If the firewall is told to block connections the utility will not be able to contact the Net F/T. In this case you may need your IT department to undo the firewall block.

Figure 5.3—Windows Vista Firewall Alert





Figure 5.4—Java Demo Application



If the demo is unable to make contact with the Net F/T the force and torque values will display zero and the Force Units and other configuration-related items will each display a question mark.

5.2 Data Display with the Demo

The main screen features a live display of the current F/T data, sequence numbers, and status code. During normal operation the application requests single records, so the RDT sequence remains constant.


5.3 Collecting Data with the Demo

To collect data, first select a file to save the data in, either by pressing the “...” button to the right of the file selection field, or by directly typing the file path into the field. Once you have selected the file, press the Start Collecting button. The application will send out a request for high-speed data to the Net F/T sensor system. You can see the RDT sequence incrementing now because the application requests more than a single record when in high-speed mode.

The measurement data are stored in comma-separated value format (CSV) so it can be read by spreadsheets and data-analysis programs. Name your file with a .CSV extension and you can open it with a double-click.

If you are planning on collecting large amounts of data, it is a good idea to understand any limitations your spreadsheet or data analysis program may have on the number of rows it can work with.

Figure 5.5—Java Demo Application while Collecting Data



To stop collecting data, click the Stop Collecting button (the Collect Streaming button changes to Stop Collecting during collections).

Information stored in the CSV file is organized as follows:

- Line 1: **Start Time.** The date and time when the measurement was started.
- Line 2: **RDT Sample Rate.** The speed (in samples per second) at which the measurement data were sent from the Net F/T to the host computer. The speed is the RDT Output Rate defined on the Communications page.
- Note: If the sample rate is changed after start of the demo program, this value will not be updated.
- Line 3: **Force Units.** This is the force unit selected on the Configuration page.

- Line 4: Counts per Unit Force. All force values Fx, Fy, Fz in the CSV file must be divided by this number to get the force values in the selected unit.
- Line 5: Torque Units. This is the torque selected on the Configuration page.
- Line 6: Counts per Unit Torque. All torque values Tx, Ty, Tz in the CSV file must be divided by this number to get the torque values in the selected unit.
- Line 7: Header Row. This row names each of the columns of CSV data.

Table 5.1—CSV File Column Headings										
Column:	A	B	C	D	E	F	G	H	I	J
Name:	Status (hex)	RDT Sequence	F/T Sequence	Fx	Fy	Fz	Tx	Ty	Tz	Time

- Column A: **Status (hex)** is the 32-bit system status code for this row. Each bit signals a certain diagnostic condition. Normally this code is zero. A non-zero status code normally means that the Net F/T system needs attention. See [Section 18.1—System Status Code](#) for a detailed description of the status code.
- Column B: RDT Sequence is a number that starts at one and is incremented with each set of data that is sent from the Net F/T to the host computer.
Elapsed measurement time can be found with using the formula:
- $$\text{Elapsed Measurement Time} = \frac{\text{RDT Sequence Number}}{\text{RDT Sample Rate}}$$
- Missing sequences indicate that data packages were lost. To avoid lost samples, see [Section 17.1—Improving Ethernet Throughput](#).
- Column C: F/T Sequence is a number that is incremented with each new F/T measurement. The Net F/T measures at a constant rate of 7000 samples per second.
- Column D: Fx is the Fx axis reading in counts.
- Column E: Fy is the Fy axis reading in counts.
- Column F: Fz is the Fz axis reading in counts.
- Column G: Tx is the Tx axis reading in counts.
- Column H: Ty is the Ty axis reading in counts.
- Column I: Tz is the Tz axis reading in counts.
- Column J: Time is the time the demo program received the data row from the Net F/T. This time stamp is created by the computer and is limited to the clock resolution of the computer.


Figure 5.6—Sample Data Opened in Spreadsheet

	A	B	C	D	E	F	G	H	I	J
1	Start Time: 10/28/08 4:45 PM									
2	RDT Sample Rate: 7000									
3	Force Units: N									
4	Counts per Unit Force: 1000000.0									
5	Torque Units: N-m									
6	Counts per Unit Torque: 1000000.0									
7	Status (hex)	RDTSequence	F/T Sequence	Fx	Fy	Fz	Tx	Ty	Tz	Time
8	0x80010000	1	3031142679	-1082088	-4344421	56145954	-512907	-2789325	27622278	Tue Oct 28 16:45:31 EDT 2008
9	0x80010000	2	3031142680	-1082080	-4344397	56146508	-512897	-2790736	27622288	Tue Oct 28 16:45:31 EDT 2008
10	0x80010000	3	3031142681	-1082060	-4343688	56146485	-513175	-2791845	27621563	Tue Oct 28 16:45:31 EDT 2008
11	0x80010000	4	3031142682	-1082341	-4342832	56147539	-513359	-2791420	27621240	Tue Oct 28 16:45:31 EDT 2008
12	0x80010000	5	3031142683	-1082371	-4342861	56148597	-512138	-2790008	27621264	Tue Oct 28 16:45:31 EDT 2008
13	0x80010000	6	3031142684	-1082385	-4342524	56148628	-511978	-2790022	27621981	Tue Oct 28 16:45:31 EDT 2008
14	0x80010000	7	3031142685	-1082389	-4342191	56148118	-512436	-2789687	27622688	Tue Oct 28 16:45:31 EDT 2008
15	0x80010000	8	3031142686	-1082363	-4341816	56149196	-512870	-2791481	27622352	Tue Oct 28 16:45:31 EDT 2008
16	0x80010000	9	3031142687	-1082350	-4342498	56149183	-513193	-2791443	27622000	Tue Oct 28 16:45:31 EDT 2008
17	0x80010000	10	3031142688	-1082658	-4343039	56148680	-513432	-2789853	27623085	Tue Oct 28 16:45:31 EDT 2008
18	0x80010000	11	3031142689	-1082649	-4343057	56148669	-514051	-2788802	27623093	Tue Oct 28 16:45:31 EDT 2008
19	0x80010000	12	3031142690	-1082364	-4342864	56147033	-513374	-2790000	27622309	Tue Oct 28 16:45:31 EDT 2008
20	0x80010000	13	3031142691	-1081778	-4342833	56145442	-513406	-2792379	27622237	Tue Oct 28 16:45:31 EDT 2008
21	0x80010000	14	3031142692	-1081805	-4343552	56144381	-513136	-2790561	27622936	Tue Oct 28 16:45:31 EDT 2008
22	0x80010000	15	3031142693	-1081820	-4344608	56142267	-513644	-2789069	27623972	Tue Oct 28 16:45:31 EDT 2008
23	0x80010000	16	3031142694	-1082089	-4345096	56141691	-513861	-2789611	27622892	Tue Oct 28 16:45:31 EDT 2008
24	0x80010000	17	3031142695	-1082344	-4345231	56143795	-513900	-2790895	27621519	Tue Oct 28 16:45:31 EDT 2008
25	0x80010000	18	3031142696	-1082342	-4345217	56143265	-513897	-2791596	27621503	Tue Oct 28 16:45:31 EDT 2008
26	0x80010000	19	3031142697	-1081777	-4345564	56142209	-513490	-2792190	27621809	Tue Oct 28 16:45:31 EDT 2008
27	0x80010000	20	3031142698	-1081488	-4346106	56141657	-513765	-2790886	27621793	Tue Oct 28 16:45:31 EDT 2008

5.4 The Errors Display of the Demo

The error list at the bottom of the screen keeps track of errors that have occurred and the times they occurred (see *Figure 5.7* for an example). Refer to *Table 18.5* if you need help with error messages. See *Section 17.1—Improving Ethernet Throughput* if there is excessive IO Exception: Receive timed out errors.

Figure 5.7—Java Demo Application with an Error Message



5.5 Developing Your Own Java Application

Experienced Java programmers can develop Net F/T applications using the files in the Java directory of the Net F/T CD. The source code for the Java demo is included in this directory.

6. Net F/T Configuration Utility


The Net F/T Configuration Utility is a Windows program that can find Net F/Ts on an Ethernet network, back up configurations to a computer, restore configurations, and display saved configuration files.

The utility's installation package is in the Utilities directory of the Net F/T CD. Install the file by opening the [NetFT_Configuration_Utility_Setup.msi](#) file. The utility will be installed in the ATI Industrial Automation item in the program lists of Windows' Start menu.

6.1 Finding Net F/Ts on the Network


Launch Net F/T Configuration Utility. Click the Find Net F/T button.

Figure 6.1—Net F/T Configuration Utility



If your system has multiple connections to Ethernet a Select Connection window will appear. If this is the case, click on the entry 192.168.1.100 and then click OK.


Figure 6.2—Selecting an Ethernet Connection



The first time the utility is used it may trigger a firewall alert. This is a normal response for any program that uses the network. In this case it will be necessary to tell the firewall to allow the program to use network connections. If the firewall is told to block connections the utility will not be able to contact the Net F/T. In this case you may need your IT department to undo the firewall block.

If the firewall alert appears it is likely that the utility will not find any Net F/Ts during that search. In this case it will be necessary to click the Find Net F/T button again and start over.


Figure 6.3—Windows Vista Firewall Alert



After a slight delay, the program will report back all Net F/Ts found on the network(s). Locate the line that has a MAC ID that matches the MAC ID printed on the Net Box and remember the IP address listed.

Note that the MAC ID listed may have a different format from the Net Box's printed label. In the following example, *Figure 6.4*, the MAC ID is 00-16-BD-00-00-00, which matches the printed label MAC ID: 0016BD000000 and the IP address is 192.168.1.1.

Figure 6.4—Net F/Ts Found



The IP address you just found is the address assigned by the DHCP server. You will be using this address to communicate with your Net F/T. Click on this line and then click on OK.

NOTICE: If the Net FT Configuration Utility found the Net F/T, but the internet browser is unable to open the found IP address, you may need to clear previous device entries from the computer's ARP table by restarting the computer or, if you have administrative privileges, by going to the computer's Start menu, selecting Run..., and entering "arp -d *".

This should only be necessary if another device previously occupied the same IP address that the Net F/T is now using.

NOTICE: IP addresses assigned by a DHCP server are not permanent and may change if the Net F/T is disconnected from the network for a period of time. Contact your IT department for more information.

6.2 Backing Up a Configuration to a Computer


The Net F/T Configuration Utility can read the configurations stored in a Net F/T and store them on the local computer. A replacement Net F/T can be easily be set up to replace a damaged Net F/T by restoring a previously backed up configuration file to the new Net F/T. The configuration file contains all user-settable Net F/T information.

To back up a Net F/T, first launch Net F/T Configuration Utility. Select the desired Net F/T using the steps in [Section 6.1—Finding Net F/Ts on the Network](#).

Next, click on the Backup Configuration button to start the process. A save file dialog window will appear. Select a location and file name for the configuration file and click OK.

The utility will take a few moments to save the information.

Figure 6.5—Backup Configuration



NOTICE: The NETBA type Net Boxes also contain calibration information for its transducer(s). This transducer calibration information is not saved by the utility. Replacement NETBA type Net Boxes will need to have the transducer calibrations loaded by another method. Contact ATI Industrial Automation for more information.

NETB type Net Boxes do not contain transducer calibration information.

6.3 Restoring a Saved Configuration


A previously-saved configuration file can be loaded into a Net F/T using the restore configuration feature.

To restore a configuration, first launch Net F/T Configuration Utility. Select the desired Net F/T using the steps in [Section 6.1—Finding Net F/Ts on the Network](#).

Next, click on the Restore Configuration button to start the process. An open file dialog window will appear. Select a location and file name of the configuration file and click OK.


A confirmation message will appear before the configuration file is loaded into the Net F/T.

Figure 6.6—Restore Confirmation



After the configuration file has been loaded, a completion message will appear. Click OK to dismiss the message. You will need to power cycle the Net F/T to finish the restoration.

Figure 6.7—Restoration Complete




6.4 Inspecting a Saved Configuration File

The Net F/T configuration utility allows you to view some of the information stored in a saved configuration file.

To view a configuration, first launch Net F/T Configuration Utility. Click the Preview Backup Configuration File button. An open file dialog window will appear. Select a location and file name of the configuration file and click OK.

A preview window will open. When finished, click Close to dismiss the window.

Figure 6.8—Backup Configuration File Preview




7. Net F/T iPad Application

The Net F/T iPad application can be down loaded from the App Store. Type in Net F/T iPad in the search field and search to find the application. Then install the application on your device.

The Net F/T iPad Application allows the users to connect to transducers in their network. The application will display 10 seconds of recorded the F/T readings in numeric and waveform line graph and can record that data to a file for additional processing.


Figure 7.1—Initial Screen



7.1 Monitoring and Data Collection


To find a Transducer connected to the network click the **Find** button a list of all available transducer will be displayed with the IP and MAC addresses in the listed. Select the desired transducer from the displayed list. The IP address of the transducer selected will be displayed to the left of the **Find** button.

Figure 7.2—Find Transducer's Connected to the Network




Select the **Connect** button to connect to the selected transducer. The iPad application will begin collecting and displaying data immediately. In the upper left corner of the display under the ATI logo the device status of the transducer will be displayed and show if there are any errors. The History view will display a waveform line graph of the data being collected. The **Bias** button will set the current load level as the new zero point. The **Reset Scale** button adjusts the display to capture the current minimum and maximum reading.

Figure 7.3—History View



Force and torque reading can be turned on and off as desired by clicking on the Fx, Fy, Fz, Tx, Ty, and Tz buttons below the Disconnect button. *Figure 7.4* shows the display with only Fx active.

Figure 7.4—Force Torque Readings



The Real Time view will display numerical values of the F/T readings.

Figure 7.5—Real Time View




7.2 Exporting Data

Once you have the data desired, click the **Disconnect** button in the upper right corner under the Find button. Click the **Export Data** Button to open the data file on your device. A pop up window will appear with a list of apps that can open the spread sheet file (CSV).

NOTICE: You must have an app loaded on you iPad in order for the pop up window to appear. If no pop up window appears, go to the App Store and download an app that can open a spread sheet file.

Select the app you wish to use to open the spread sheet. From the app you may be able to save the file to a network directory or email the file.

Figure 7.6—Export Data



The measurement data is stored in comma-separated value format (CSV) so it can be read by spreadsheets and data-analysis programs. Name your file with a .CSV extension. If you are planning on collecting large amounts of data, it is a good idea to understand any limitations your spreadsheet or data analysis program may have on the number of rows it can work with.

Figure 7.7—Sample CSV Data File Opened in a Spread Sheet

A	B	C	D	E	F	G	H	I	J
1 Start Time: 1/28/2013 4:24 PM									
2 RDT Sample Rate: 7000									
3 Force Units: N									
4 Counts Per Unit Force: 0.224809									
5 Torque Units: N·m									
6 Counts Per Unit Torque: 8.85075									
7									
8 Status (hex)	RDTSequence	F/T Sequence	Fx	Fy	Fz	Tx	Ty	Tz	Time
9 0x0	41	17433244	209.0664	0	62.27509	1.12985	12.54131	-1.12985	16:24:46.654
10 0x0	42	17433261	209.0664	0	62.27509	1.016863	12.54131	-1.12985	16:24:46.656
11 0x0	43	17433278	209.0664	0	62.27509	1.016863	12.54131	-1.12985	16:24:46.658
12 0x0	44	17433295	209.0664	0	57.82687	1.016863	12.42833	-1.12985	16:24:46.661
13 0x0	45	17433312	209.0664	0	62.27509	1.016863	12.54131	-1.12985	16:24:46.663
14 0x0	46	17433329	213.5146	0	62.27509	1.016863	12.65429	-1.12985	16:24:46.666
15 0x0	47	17433346	213.5146	0	62.27509	1.016863	12.54131	-1.12985	16:24:46.668
16 0x0	48	17433363	213.5146	0	62.27509	1.016863	12.54131	-1.12985	16:24:46.671
17 0x0	49	17433380	213.5146	0	62.27509	1.016863	12.54131	-1.12985	16:24:46.673
18 0x0	50	17433397	209.0664	-4.44822	57.82687	1.016863	12.42833	-1.12985	16:24:46.675
19 0x0	51	17433414	204.6181	0	53.37684	1.016863	12.42833	-1.42483	16:24:46.678
20 0x0	52	17433431	209.0664	0	57.82687	0.903876	12.54131	-1.12985	16:24:46.680
21 0x0	53	17433448	209.0664	0	62.27509	1.016863	12.54131	-1.12985	16:24:46.683
22 0x0	54	17433465	209.0664	0	62.27509	1.016863	12.65429	-1.12985	16:24:46.685
23 0x0	55	17433482	213.5146	-4.44822	62.27509	1.016863	12.65429	-1.12985	16:24:46.688
24 0x0	56	17433499	213.5146	0	66.7233	1.12984	12.54131	-1.01686	16:24:46.690
25 0x0	57	17433516	209.0664	0	57.82687	1.016863	12.42833	-1.12985	16:24:46.692

7.3 Data Collection Settings

Data Collection

Data collection can be turned ON or OFF if desired.

High Speed Data Collection

When high speed data collection is turned on the visual output is disabled.
Use this function when only interested in collecting F/T data reading and not monitoring the transducer.

Autoscale

The autoscale function can be turned ON or OFF. The autoscale function adjusts the waveform line graph to capture the current minimum and maximum reading from the transducer.


Auto-Update Header Info

Automatically updates the header information every 10 seconds.

Robust Transmit Mode


Transmits more packets than required. For use on noisy networks where packet loss occurs frequently.

Figure 7.8—Data Collection Settings 1



- | | |
|-------------------------|---|
| Display Dropped Packets | Displays how many packets are dropped. |
| Reset Settings | Clears all stored settings and IP addresses. |
| Stored IP Address | Displays the stored IP address. |
| Version | Displays the Net F/T iPad application software version. |

Figure 7.9—Data Collection Settings 2



8. Common Gateway Interface (CGI)

The Net F/T can be configured over Ethernet using the standard HTTP get method, which sends configuration variables and their values in the requested URL.

Each variable is only settable from the CGI page which is responsible for that variable. The following tables list each CGI page and the settable variables associated with it.

URLs are constructed using the syntax:

http://<netFTAddress>/<CGIPage.cgi>?<firstVariableAssignment><&nextVariableAssignment>

where:

http://	indicates an HTTP request
<netFTAddress>	is the Ethernet address of the Net F/T system
/	a separator
<CGIPage.cgi>	the name of the CGI page that holds the variables you will be accessing
?	a separator marking the start of variable assignments
<firstVariableAssignment>	a variable assignment using the format described below
<&nextVariableAssignment>	a variable assignment using the format described below, but the variable name is proceeded by an ampersand. This variable assignment is optional and may be repeated for multiple variables.

Variables are assigned new values using the syntax:

variableName=newValue

where:

variableName	is the name of the variable to be assigned
=	indicates assignment
newValue	is the value to be assigned to the variable. Text for text variables should not be enclosed in quotes. To include the ampersand character in text for a text variable use %26. Floating point numbers are limited to twenty characters.

Example:

http://192.168.1.1/setting.cgi?setcfgsel=2&setuserfilter=0&setpke=1

tells the Net F/T at IP address 192.168.1.1 to set CGI variables *setcfgsel* to 2, *setuserfilter* to 0, and *setpke* to 1.

The maximum length of these URLs may be determined by a number of factors external to the Net F/T. Exceeding the maximum length may result in an error or variables being incorrectly set.

8.1 Settings CGI (setting.cgi)

This CGI allows you to specify certain global settings such as low-pass filter selection, peak monitoring enable, software bias vector, and active configuration selection. See [Section 4.4—Settings Page \(setting.htm\)](#) for related information.

Table 8.1—setting.cgi Variables

Variable Name	Allowed Values	Description							
setcfgsel	integers: 0 to 15	Sets the active configuration. Note that the value used by <code>setcfgsel</code> is one less than the configuration numbers displayed on the web pages.							
setuserfilter	integers: 0 to 12	Sets the cutoff frequency of the low-pass filtering as follows:							
		Value	Cutoff	Value	Cutoff	Value	Cutoff		
		0	no filter	5	35 Hz	10	2000 Hz		
		1	838 Hz	6	18 Hz	11	2500 Hz		
		2	326 Hz	7	8 Hz	12	3000 Hz		
		3	152 Hz	8	5 Hz				
		4	73 Hz	9	1500 Hz				
setpke	integers: 0 or 1	Enable (value = 1) or disable (value = 0) peak logging							
setbiasn	integers: -32768 to 32767	Sets the offset value for strain gage n . For example, <code>setbias3=0</code> would zero the bias of the fourth strain gage (Strain gages are enumerated starting at zero.)							

8.2 Thresholding CGI (moncon.cgi)

This CGI defines and controls thresholding statements. Thresholding statements can be turned off or on and need to have an axis, a comparison type, a comparison counts value, and an output code defined.

Table 8.2—moncon.cgi Variables

Variable Name	Allowed Values	Description		
setmce	Integers: 0 or 1	Enable (value = 1) or disable (value = 0) all threshold statement processing.		
mcen	Integers: 0 or 1	Enable (value = 1) or disable (value = 0) threshold statement <i>n</i> .		
mcxn	Integers: -1 to 5	Selects the axis evaluated by threshold statement <i>n</i> .	Value	Description
		-1	Statement disabled	blank
		0	Fx axis	Fx
		1	Fy axis	Fy
		2	Fz axis	Fz
		3	Tx axis	Tx
		4	Ty axis	Ty
		5	Tz axis	Tz
mcvn	Integers: -2147483648 to +2147483647	Sets the counts value to compare the current axis value by threshold statement <i>n</i> .		
mcon	Hexadecimal: 0x00 to 0xFF	Sets the output code for threshold statement <i>n</i> .		

where *n* is an integer ranging from 0 to 15 representing the threshold statement index

8.3 Configurations CGI (config.cgi)

This CGI allows you to specify the output parameters of the sensor system. Any of the sixteen configurations can be defined. Changing configurations allows you to change which transducer calibration to use and what tool transformations to apply to that calibration.

When using config.cgi the cfgid value specifies which configuration is targeted. For example, <http://<netFTAddress>/config.cgi?cfgid=3&cfgnam=test123> sets the name of the fourth configuration (which is at index 3) to test123.

See [Section 4.6—Configurations Page \(config.htm\)](#) for related information.

Table 8.3—config.cgi Variables

Variable Name	Allowed Values	Description		
cfgid	integers: 0 to 15	Zero-based index of the configuration to be set during this CGI call. This variable is required for all calls to config.cgi.		
cfgnam	Text string of up to 32 characters	Sets the configuration name.		
cfgcalsel	integers: 0 to 15	Sets the calibration used by the configuration.		
cfgfu	Integers: 1 to 6	Sets the force units used by the configuration. This value determines the <i>Counts per Force</i> and <i>Max Ratings</i> values on the config.htm user web page.		
		Value	Description	Menu Value
		1	Pound-force	lbf
		2	Newtons	N
		3	Kilopound-force	klbf
		4	Kilonewton	kN
		5	Kilogram-force	kgf
		6	Gram-force	gf
cfgtu	Integers: 1 to 6	The torque units used by the configuration. This value determines the <i>Counts per Torque</i> and <i>Max Ratings</i> values on the config.htm user web page.		
		Value	Description	Menu Value
		1	Pound-force-inch	lbf-in
		2	Pound-force-feet	lbf-ft
		3	Newton-meter	Nm
		4	Newton-millimeter	Nmm
		5	Kilogram-force-centimeter	kgf-cm
cfgtdu	Integers: 1 to 5	The distance measurement units used by the configuration's tool transformation.		
		Value	Description	Menu Value
		1	inch	in
		2	foot	ft
		3	millimeter	mm
cfgtau	Integers: 1 or 2	The rotation units used by the configuration's tool transformation.		
		Value	Description	Menu Value
		1	degrees (°)	degrees
cfgtx0	Floating point	Sets the tool transformation distance Dx. Distance must be in cfgtdu distance units.		

Table 8.3—config.cgi Variables

Variable Name	Allowed Values	Description
cfgtx1	Floating point	Sets the tool transformation distance Dy. Distance must be in <i>cfgtdu</i> distance units.
cfgtx2	Floating point	Sets the tool transformation distance Dz. Distance must be in <i>cfgtdu</i> distance units.
cfgtx3	Floating point	Sets the tool transformation rotation Rx. Rotation must be in <i>cfgtau</i> angular units.
cfgtx4	Floating point	Sets the tool transformation rotation Ry. Rotation must be in <i>cfgtau</i> angular units.
cfgtx5	Floating point	Sets the tool transformation rotation Rz. Rotation must be in <i>cfgtau</i> angular units.
cfgusra	Text string of up to 16 characters	Stores text in user-defined field #1.
cfgusrb	Text string of up to 16 characters	Stores text in user-defined field #2.

8.4 Communications CGI (comm.cgi)

This CGI sets the networking options of the Net Box. Refer to [Section 4.7—Communication Settings Page \(comm.htm\)](#) for more information on the parameters.

Table 8.4—comm.cgi Variables

Variable Name	Allowed Values	Description	
comnetdhcp	Integers: 0 or 1	Sets DHCP behavior.	
		Value	Description
		0	Use DHCP if available on network
comnetip	Any IPV4 address in dot-decimal notation	Sets the static IP address to be used when DHCP is disabled.	
		Sets the subnet mask to be used when DHCP is disabled.	
comnetgw	Any IPV4 address in dot-decimal notation	Sets the gateway to be used when DHCP is disabled.	
comeipe	Integers: 0 or 1	Enable (value = 1) or disable (value = 0) EtherNet/IP protocol. Basic CAN protocol must be selected when EtherNet/IP protocol is enabled.	
mcxn	Integers: -1 to 5	Selects CAN bus protocol.	
		Value	Description
		0	Basic CAN protocol
		1	DeviceNet compatibility-mode protocol
		EtherNet/IP protocol must be disabled when DeviceNet protocol is selected.	
comrdte	Integers: 0 or 1	Enable (value = 1) or disable (value = 0) RDT interface.	
comrdtrate	1 to 7000	Sets the RDT output rate in Hertz. The actual value used may be rounded up; see Section 4.7—Communication Settings Page (comm.htm) for details.	
comrdtbsiz	Integers: 1 to 40	RDT Buffer Mode buffer size.	
comrdtmsyn	Integers: 0 or 1	Enable (value = 1) or disable (value = 0) multi-unit synchronization.	
comrdtmuid	Integers: 0 to 9	Multi-unit synchronization index.	

9. System Settings XML Pages

The Net F/T's current settings can be retrieved in XML format using standard Ethernet HTTP requests. This enables programs to read system settings such as the Counts per Force value. The Net F/T's Java demo application uses data provided in these XML pages to correctly scale displayed data.

In the following tables, the data types of XML elements are as follows:

Table 9.1—Types Used by XML Elements	
Data Type	Description
DINT	Signed double integer (32 bit)
ENABL	Boolean using <i>Enabled</i> to represent 1 and <i>Disabled</i> to represent 0
HEX n	Hexadecimal number of n bits, prefixed with <i>0x</i> .
INT	Signed integer (16 bit)
REAL	Floating-point number (32 bit)
SINT	Signed short integer (8 bit)
STRING n	String of n characters
UDINT	Unsigned double integer (32 bit)
UINT	Unsigned integer (16 bit)
USINT	Unsigned short integer (8 bit)

The values of all data types are presented as an ASCII strings.

Arrays are represented if the suffix $[i]$ is attached to the data type, where i indicates the number of values in the array. Array values in an XML element may be separated by a semicolon, comma, or space.

9.1 System and Configuration Information (netftapi2.xml)

The XML page netftapi2.xml retrieves the system setup and active configuration. To retrieve information about other configurations, those configurations must be made active prior to the request.

A configuration index can be specified when requesting this configuration information. This is done by appending $?index=n$ to the request, where n is the index of the desired configuration. If a configuration index is not specified the active configuration will be assumed.

For example, to retrieve configuration information for the second configuration the requested page would be netftapi2.xml? $?index=1$.

The reference column in [Table 9.2](#) indicates which .htm page and .cgi function access this element. Refer to the corresponding entry in [Section 4—Web Pages](#) or [Section 8—Common Gateway Interface \(CGI\)](#) for related information.

Table 9.2—XML Elements in netftapi2.xml

XML Element	Data Type	Description	Reference
runstat	HEX32	System status code	—
runft	DINT[6]	Force and torque values in counts	rundata
runpkmx	DINT[6]	Maximum peak values in counts	rundata
runpkmn	DINT[6]	Minimum peak values in counts	rundata
runsg	INT[6]	Strain gage values	rundata
runmcb	HEX32	Thresholds breached	rundata
runmco	HEX8	Thresholds output	rundata
runmcl	USINT	Threshold latched	rundata
setcfgsel	USINT	Active configuration	setting
setuserfilter	USINT	Low-pass filter cutoff frequency menu selection	setting
setpke	USINT	Peak monitoring processing status	setting
setbias	DINT[6]	Software bias vector	setting
setmce	USINT	Threshold processing status	moncon
mce	USINT[16]	Threshold statements' individual enabling	moncon
mcx	USINT[16]	Threshold statements' selected axes	moncon
mcc	USINT[16]	Threshold statements' comparisons	moncon
mcv	DINT[16]	Threshold statements' counts values for comparison	moncon
mco	HEX8[16]	Threshold statements' output codes	moncon
cfgnam	STRING32	Name of active configuration	config
cfgcalsel	USINT	Calibration used by active configuration	config
cfgcalsn	STRING8	Serial number of active configuration's calibration	config
cfgfu	USINT	Force units used by active configuration	config
scfgfu	STRING8	Name of force units used by active configuration	config
cfgtu	USINT	Torque units used by active configuration	config
scfgtu	STRING8	Name of torque units used by active configuration	config
cfgcpf	DINT	Counts per force as determined by the active configuration settings	config
cfgcpt	DINT	Counts per torque as determined by the active configuration settings	config
cfgmr	REAL[6]	Calibrated sensing ranges in units as determined by the active configuration settings	config
cfgtdu	USINT	Tool transformation distance units used by active configuration	config
scfgtdu	STRING16	Name of tool transformation distance units used by active configuration	config
cfgtau	USINT	Tool transformation rotation units used by active configuration	config
scfgtau	STRING8	Name of tool transformation rotation units used by active configuration	config
cfgtx	REAL[6]	Tool transformation distances and rotations applied by active configuration	config
cfgusra	STRING16	User-defined field #1 for the active configuration	config
cfgusrb	STRING16	User-defined field #2 for the active configuration	config
comnetdhcp	ENABL	DHCP behavior setting	comm

Table 9.2—XML Elements in netftapi2.xml

XML Element	Data Type	Description		Reference
comnetip	STRING15	Static IP address		comm
comnetmsk	STRING15	Static IP subnet mask		comm
comnetgw	STRING15	Static IP gateway		comm
comeipe	ENABL	EtherNet/IP protocol setting		comm
nethwaddr	STRING17	Ethernet MAC Address		comm
comdnte	ENABL	CAN bus protocol setting		comm
comdntmac	USINT	DeviceNet MAC ID		comm
comdntbaud	USINT	CAN network baud rate:		comm
		Value	Baud Rate	
		0	125 kHz	
		1	250 kHz	
		2	500 kHz	
		3	SoftSet	
comrdte	ENABL	RDT interface setting		comm
comrdtrate	UDINT	RDT output rate		comm
comrdtbsiz	USINT	RDT Buffer Mode buffer size		comm
comrdtmsyn	ENABL	Multi-unit synchronization setting		comm
comrdtmuid	USINT	Multi-unit synchronization index		comm
mfgdighwa	STRING17	Ethernet MAC Address		manuf
mfgdigsn	STRING8	Digital board serial number		manuf
mfgdigver	STRING8	Digital board firmware revision		manuf
mfgdigrev	STRING8	Digital board hardware revision		manuf
mfganasn	STRING8	Analog board serial number		manuf
mfganarev	STRING8	Analog board hardware revision		manuf
mfgtxdmdl	STRING16	Analog board location		manuf
netip	STRING15	IP address in use		–
runrate	UDINT	Internal sample rate for strain gage collection		–

9.2 Calibration Information (netftcalapi.xml)

The XML page netftcalapi.xml retrieves information about a specific calibration. Retrieved calibration information has not been modified by any of the Net F/T's configuration settings.

A calibration index can be specified when requesting this calibration information. This is done by appending ?index=n to the request, where n is the index of the desired calibration. If a calibration index is not specified the currently-used calibration will be assumed.

For example, to retrieve calibration information for the third calibration the requested page would be *netftcalapi.xml?index=2*.

Table 9.3—XML Elements in netftcalapi.xml		
XML Element	Data Type	Calibration Information
calsn	STRING8	Serial number
calpn	STRING32	Calibration type
caldt	STRING20	Calibration date
calfu	USINT	Force units (refer to config.cgi variable cfgfu for values)
scalfu	STRING8	Name of force units
caltu	USINT	Torque units used (refer to config.cgi variable cfgtu for values)
scaltu	STRING8	Name of torque units
calmr	REAL[6]	Calibrated sensing ranges in calfu and caltu units
calcpf	DINT	Counts per force unit
calcpt	DINT	Counts per torque unit
calsf	DINT[6]	Scaling factor for DeviceNet and CAN
calusra	STRING16	Calibration note field #1
calusrb	STRING16	Calibration note field #2

10. UDP Interface Using RDT

The Net F/T can output data at up to 7000 Hz over Ethernet using UDP. This method of fast data collection is called Raw Data Transfer (RDT). If the overhead of DeviceNet or EtherNet/IP is too much for your project, or you need extra speed in your data acquisition, RDT provides an easy method to get the forces, torques, and status codes of the Net F/T system.

NOTICE: Multi-byte values must be transferred to the network high byte first and with the correct number of bytes. Some compilers align structures to large field sizes, such as 32- or 64-bit fields, and send an incorrect number of bytes. C compilers usually provide the functions *hton()*, *htonl()*, *ntohs()*, and *ntohl()* that can automatically handle these issues.

10.1 RDT Protocol

There are six commands in the RDT protocol. These are listed in *Table 10.1*. Any command received by the Net F/T will take precedence over any previously-received commands.

Table 10.1—RDT Commands

Command	Command Name	Command Response
0x0000	Stop streaming	none
0x0002	Start high-speed real-time streaming	RDT record(s)
0x0003	Start high-speed buffered streaming	RDT record(s)
0x0004	Start multi-unit streaming (synchronized)	RDT record(s)
0x0041	Reset Threshold Latch	none
0x0042	Set Software Bias	none

The three streaming modes are further described in *Table 10.2*.

Table 10.2—Streaming Modes

Mode	Command	Speed	Situation Best Suited To
0x0002	Start high-speed real-time streaming	Fast (up to 7000 Hz)	Real-time response applications.
0x0003	Start high-speed buffered streaming	Fast (up to 7000 Hz), but comes in bursts (buffers)	Collecting data at high speed, but not responding to it in real-time. Buffer size is set on the Communication Settings web page. See Section 4.7—Communication Settings Page (comm.htm) .
0x0004	Start multi-unit streaming (synchronized)	Slower, depending on the number of sensor systems involved	Multi-unit synchronization. The multi-unit ID number is set on the Communication Settings web page.

To start the Net F/T outputting RDT messages, you first send an RDT request to it. The Net F/T listens for RDT requests on UDP port 49152. It also sends the RDT output messages from this port.



CAUTION: A dedicated Ethernet network should be used for the streaming of Net F/T data. Net F/T RDT streaming modes can send large amounts of data to the Ethernet connection, which can disrupt other communications on the network. See [Section 17.1—Improving Ethernet Throughput](#).



CAUTION: To reduce the possibility of network problems, especially when on a shared network, Net F/T RDT streaming modes should only be used at high output rate when absolutely necessary.

NOTICE: All Net F/T RDT streaming modes continue to stream until a Stop Streaming command (0x0000) is received. If the client that requested the data is removed from the network (disconnected, powered down, out of wireless range, etc.) before it sends a Stop Streaming command, the Net F/T will continue to stream data to the network even though there is no recipient.

All RDT requests use the following RDT request structure:

```
{  
    Uint16 command_header = 0x1234;      // Required  
    Uint16 command;                  // Command to execute  
    Uint32 sample_count;            // Samples to output (0 = infinite)  
}
```

Set the command field of the RDT request to the command from [Table 10.1](#). Set sample_count to the number of samples to output. If you set sample_count to zero, the Net Box will output continuously until you send an RDT request with command set to zero.

RDT records sent in response to an RDT request have this structure:

```
{  
    Uint32 rdt_sequence; // RDT sequence number of this packet.  
    Uint32 ft_sequence; // The record's internal sequence number  
    Uint32 status;      // System status code  
  
    // Force and torque readings use counts values  
    Int32 Fx;          // X-axis force  
    Int32 Fy;          // Y-axis force  
    Int32 Fz;          // Z-axis force  
    Int32 Tx;          // X-axis torque  
    Int32 Ty;          // Y-axis torque  
    Int32 Tz;          // Z-axis torque  
}
```

rdt_sequence: The position of the RDT record within a single output stream. The RDT sequence number is useful for determining if any records were lost in transit. For example, in a request for 1000 records, rdt_sequence will start at 1 and run to 1000. The RDT sequence counter will roll over to zero for the increment following $4294967295 (2^{32}-1)$.

ft_sequence: The internal sample number of the F/T record contained in this RDT record. The F/T sequence number starts at 0 when the Net F/T is powered up and increments at the internal sample rate (7000 per sec). Unlike the RDT sequence number, ft_sequence does not reset to zero when an RDT request is received. The F/T sequence counter will roll over to zero for the increment following $4294967295 (2^{32}-1)$

status: Contains the system status code at the time of the record.

Fx, Fy, Fz, Tx, Ty, Tz: The F/T data as counts values.

If using buffered mode, then the number of RDT records received in a UDP packet will be equal to the RDT buffer size displayed on the Communications page. See [Section 4.7—Communication Settings Page \(comm.htm\)](#) for a description of RDT Buffer Size.

10.2 Extended RDT Requests

Extended RDT requests have the following structure:

```
{  
    uint16 hdr;           /* Always set to 0x1234 */  
    uint16 cmd;          /* The command code, with high bit set to '1'. */  
    uint32 count;         /* The number of samples to send in response. */  
    uint32 ipaddr_dest;  /* The ip address to send the response to. */  
    uint16 port_dest;    /* The port to send the response to. */  
}
```

The extended RDT request format is used when you want the Net F/T to send the UDP F/T data to a different IP address than the IP address the request comes from. This is useful, for example, if you wish to have the Net F/T stream data to a multicast address so multiple clients can receive the stream at once.

The command codes used in the Extended RDT format are the same as the command codes in normal RDT requests, except that the high bit is set to a ‘1’. For example, the command code 2, for high-speed streaming, is changed to 0x8002 for use with the Extended RDT request packet structure.

For example, to request high speed streaming to the multicast address 224.0.5.128, port 28250, you would send a UDP packet with the following data:

```
{ 0x12, 0x34, 0x80, 0x02, 0x00, 0x00, 0x00, 224, 0, 5, 128, 0x6e, 0x5a };
```

Your clients can then subscribe to the UDP multicast IP address 224.0.5.128, and receive the streaming data on port 28250. Consult your client system’s documentation for information on how to subscribe to a multicast IP address.

10.3 Calculating F/T Values for RDT

To obtain the real force and torque values, each force output value has to be divided by the Counts per Force and each torque output value has to be divided by the Counts per Torque factor. The Counts per Force and Counts per Torque factors can be obtained from netftapi2.xml page. See cfgcpf and cfgcpt in [Section 9.1—System and Configuration Information \(netftapi2.xml\)](#).

10.4 Multi-Unit Mode

This mode allows multiple Net F/T systems to be used in unison. Multi-unit synchronization starts the sampling of all systems at approximately the same moment in time and then coordinate their transmissions to prevent communication collisions. Communications will remain coordinated for a time and then multi-unit synchronization will need to be stopped and restarted to resynchronize.

10.5 Multiple Clients

The RDT protocol is designed to respond to one client only. If a second client sends a command, the Net F/T will respond to the new client. Multiple clients could repeatedly request single packets, minimizing problems. (The Java demo operates in this manner.)

10.6 Notes on UDP and RDT Mode

RDT communications use UDP, with its minimal overhead, to maximize throughput. Unlike TCP, UDP does not check if a package was actually received.

In some Ethernet network configurations this can lead to the loss of RDT data sets. By checking the RDT sequence number of each set, it can be determined if a data set was lost. The RDT sequence number of each data set sent will be one greater than the last data set sent for that RDT request. If a received data set's RDT sequence number is not one greater than the last received data set, then a loss of data has occurred (the program must also account for rollover of the RDT sequence number).

The likelihood of data loss highly depends on the Ethernet network configuration and there are ways to reduce the probability of data loss to almost zero. Refer to Section 17.1—Improving Ethernet Throughput for details.

If there are multiple Net F/Ts on the same network, data collisions between Net F/Ts and the subsequent data losses can be eliminated by using the Net F/T's multi-unit synchronization function.

The maximum data latency, measured from the beginning of data acquisition to when the last data bit is sent to the Ethernet network, is less than 28 μ s.

The Net F/T only supports one UDP connection at a time.

10.7 Example Code

Example C code can be found on the ATI website at http://www.ati-ia.com/Products/ft/software/net_ft_software.aspx and on the product CD.

11. TCP Interface

11.1 General

The TCP interface listens on TCP port 49151. All commands are 20 bytes in length. All responses begin with the two byte header 0x12, 0x34.

11.2 Command Codes

READFT	=	0,	/* Read F/T values. */
READCALINFO	=	1,	/* Read calibration info. */
WITETRANSFORM	=	2,	/* Write tool transformation. */
WRITETHRESHOLD	=	3,	/* Write monitor condition. */

11.3 Read F/T Command

```
{\n    uint8          command;      /* Must be READFT (0) . */\n    uint8          reserved[15]; /* Should be all 0s. */\n    uint16         MCEnable;     /* Bitmap of MCs to enable. */\n    uint16         sysCommands;  /* Bitmap of system commands. */\n}
```

Each bit position 0-15 in MCEnable corresponds to the monitor condition at that index. If the bit is a '1', that monitor condition is enabled. If the bit is a '0', that monitor condition is disabled.

Bit 0 of sysCommands controls the Bias. If bit 0 is a '1', the system is biased. If bit 0 is a '0', no action is taken.

Bit 1 of sysCommands controls the monitor condition latch. If bit 1 is a '1', the monitor condition latch is cleared, and monitor condition evaluation begins again. If bit 1 is a '0', no action is taken.

11.4 Read F/T Response

```
{  
    uint16 header;          /* always 0x1234. */  
    uint16 status;          /* Upper 16 bits of status code. */  
    int16 ForceX;           /* 16-bit Force X counts. */  
    int16 ForceY;           /* 16-bit Force Y counts. */  
    int16 ForceZ;           /* 16-bit Force Z counts. */  
    int16 TorqueX;          /* 16-bit Torque X counts. */  
    int16 TorqueY;          /* 16-bit Torque Y counts. */  
    int16 TorqueZ;          /* 16-bit Torque Z counts. */  
}
```

The status code is the upper 16 bits of the 32-bit status code described in the Net F/T user manual.

The force and torque values in the response are equal to (actual ft value * calibration counts per unit / 16-bit scaling factor). The counts per unit and scaling factor are read using the read calibration information command.

11.5 Read Calibration Info Command

```
{  
    uint8 command;           /* Must be READCALINFO (1). */  
    uint8 reserved[19];      /* Should be all 0s. */  
}
```

11.6 Read Calibration Info Response

```
{  
    uint16 header;          /* always 0x1234. */  
    uint8 forceUnits;       /* Force Units. */  
    uint8 torqueUnits;      /* Torque Units. */  
    uint32 countsPerForce; /* Calibration Counts per force unit. */  
    uint32 countsPerTorque; /* Calibration Counts per torque unit. */  
    uint16 scaleFactors[6]; /* Further scaling for 16-bit counts. */  
}
```

The status code is the upper 16 bits of the 32-bit status code described in the Net F/T user manual.

The force and torque values in the response are equal to (actual ft value * calibration counts per unit / 16-bit scaling factor). The counts per unit and scaling factor are read using the read calibration information command.

The force unit codes are:

- 1: Pound
- 2: Newton
- 3: Kilopound
- 4: Kilonewton
- 5: Kilogram
- 6: Gram

The torque unit codes are:

- 1: Pound-inch
- 2: Pound-foot
- 3: Newton-meter
- 4: Newton-millimeter
- 5: Kilogram-centimeter
- 6: Kilonewton-meter

11.7 Write Tool Transform Command

```
{  
    uint8 command;           /* Must be WRITETRANSFORM (2). */  
    uint8 transformDistUnits; /* Units of dx,dy,dz */  
    uint8 transformAngleUnits; /* Units of rx,ry,rz */  
    int16 transform[6];       /* dx, dy, dz, rx, ry, rz */  
    uint8 reserved[5];        /* Should be all zeroes. */  
}
```

The 'transform' elements are multiplied by 100 to provide good granularity with integer numbers.

The distance unit codes are:

- 1: Inch
- 2: Foot
- 3: Millimeter
- 4: Centimeter
- 5: Meter

The angle unit codes are:

- 1: Degrees
- 2: Radians.

The response is a standard Write Response.

11.8 Write Monitor Condition Command

```
{  
    uint8 command;           /* Must be WRITETHRESHOLD. */  
    uint8 index;             /* Index of monitor condition. 0-31. */  
    uint8 axis;              /* 0 = fx, 1 = fy, 2 = fz, 3 = tx, 4 = ty, 5 = tz.  
*/  
    uint8 outputCode;         /* Output code of monitor condition. */  
    int8 comparison;          /* Comparison code. 1 for "greater than" (>), -1  
for "less than" (<). */  
    int16 compareValue;        /* Comparison value, divided by 16 bit Scaling  
factor. */  
}
```

The 'transform' elements are multiplied by 100 to provide good granularity with integer numbers.

The distance unit codes are:

11.9 Write Response

```
{  
    uint16 header;           /* Always 0x1234. */  
    uint8 commandEcho;        /* Echoes command. */  
    uint8 status;              /* 0 if successful, nonzero if not. */  
}
```

12. EtherNet/IP Operation

12.1 Overview

The Net F/T operates as a Server on the EtherNet/IP network. It supports Class 3 Connected Explicit Messaging, UCMM Explicit Messaging, and Class 1 Connected Cyclic I/O Messaging. It supports one input-only connection and does not support a listen-only connection. The Net F/T does not support any Client functionality.

EtherNet/IP uses the CIP protocol described in [Section 12—EtherNet/IP Operation](#).

EtherNet/IP Protocol must be enabled on the Communications page to use EtherNet/IP.

Table 12.1—Class 1 Connection Information Parameters				
	Instance	Size (bytes)	RT Transfer Format	Connection Type
Configuration	128	0	n/a	n/a
Input (Target to Originator)	100	28	Modeless	Point-to-Point
Output (Originator to Target) Ethernet/IP O2T Data Disabled	102	0	Modeless	Point-to-Point
Output (Originator to Target) Ethernet/IP O2T Data Disabled	102	4	Run/Idle	Point-to-Point

12.2 Module and Network Status LED

The module status LED is identified on the Net Box as MS. It provides device status for power and proper operation. The EtherNet/IP network status LED is identified on the Net Box as NS EN. Refer to [Figure 3.16](#) and [Table 3.4](#) for an outline of the LED operation.

13. DeviceNet-Compatibility Mode Operation

13.1 Overview

The Net F/T operates as a Group 2-Only Server on the DeviceNet network. It supports Explicit Messaging and Polled I/O messaging for the predefined master/Slave Connection set. The Net F/T DeviceNet Node does support the Unconnected Message Manager (UCMM).

DeviceNet-compatibility mode uses the CIP protocol described in [Section 14—EtherNet/IP and DeviceNet CIP Model](#).

To use the Net F/T's DeviceNet-Compatibility Mode, DeviceNet must be selected on the Communications page and power must be present on the Pwr/CAN connector.

13.2 MAC ID

The MAC ID is set by either hardware or software configuration to a value from 0 to 63. In order for the MAC ID to be set by software, DIP switch positions 1 through 8 must be ON. If the MAC ID is set by software, the baud rate must also be set by software. For more information refer to [Section 3.9.2—Node Address](#) and [Table 3.2](#). The factory set MAC ID is 54.

13.3 Baud Rate

Baud Rate is set by either hardware or software configuration to 125 kbps, 250 kbps or 500 kbps. The baud rate will be set by software when DIP switch positions 7 and 8 are ON. For more information refer to [Section 3.9.3—Baud Rate](#) and [Table 3.3](#). The factory set baud rate is 500 kbps.

13.4 Module and Network Status LED

The module status LED is identified on the Net Box as MS. It provides device status for power and proper operation. The DeviceNet network status LED is identified on the Net Box as NS DN. Refer to [Figure 3.16](#) and [Table 3.4](#) for an outline of the LED operation.

13.5 EDS File

The DeviceNet EDS (Electronic Data Sheet) file for the system can be found in the \EDS directory on the system CD.

14. EtherNet/IP and DeviceNet CIP Model

14.1 Overview

The Net F/T operates as a Group 2-Only Server on the DeviceNet network. It supports Explicit Messaging and Polled I/O messaging for the predefined Master/Slave Connection set. The Net F/T DeviceNet Node does support the Unconnected Message Manager (UCMM).

The Net F/T operates as a Server on the EtherNet/IP network. It supports Class 3 Connected Explicit Messaging, UCMM Explicit Messaging and Class 1 Connected Cyclic I/O Messaging. The Net F/T does not support any Client functionality.

EtherNet/IP and DeviceNet protocols cannot be enabled at the same time.

Table 14.1—Name and Data Value	
Name	Data Value
Vendor Number	555
Device Type	0
Product Code Number	1
Product Name	ATI Industrial Automation F/T

Table 14.2—DeviceNet Input Bitmap	
WORD (16-bit)	Name
0	Status word, bits 16 through 31
1	Fx (16-bit)
2	Fy (16-bit)
3	Fz (16-bit)
4	Tx (16-bit)
5	Ty (16-bit)
6	Tz (16-bit)

Table 14.3—EtherNet/IP Input Bitmap	
DWORD (32-bit)	Name
0	Status word (32-bit)
1	Fx (32-bit)
2	Fy (32-bit)
3	Fz (32-bit)
4	Tx (32-bit)
5	Ty (32-bit)
6	Tz (32-bit)

There is no output data if the Ethernet/IP O2T Data option on the Communications page (Section 4.8) is disabled.

Table 14.4—Ethernet/IP Output Mapping

Byte	BitNumber	Name	Description/Function
0	0	Bias	Perform tare function to zero out any load reading
	1	Reset Latch	Reset threshold latch
	2	reserved	reserved
	3	reserved	reserved
	4	reserved	reserved
	5	reserved	reserved
	6	reserved	reserved
	7	reserved	reserved
1	0	Config Select bit 0	Selects a Net F/T configuration, from 0 to 15
	1	Config Select bit 1	
	2	Config Select bit 2	
	3	Config Select bit 3	
	4	reserved	reserved
	5	reserved	reserved
	6	reserved	reserved
	7	reserved	reserved
2	0-7	Threshold high	Threshold enable mask, high byte
3	0-7	Threshold low	Threshold enable mask, low byte

14.2 Calculating F/T Values for CIP

14.2.1 EtherNet/IP

For 16-bit format: To obtain the real force and torque values, a “no load” value is reported as +32768 counts, a negative full-scale load is reported as approximately 0 counts, and a positive full-scale load is reported as approximately 65536 counts. Each received force value has to be divided by (*Counts per Force ÷ Scaling Factor for DeviceNet and CAN*) for the axis and each received torque value has to be divided by (*Counts per Torque ÷ Scaling Factor for DeviceNet and CAN*) for the axis.

NOTICE: Be sure to use the scaling factors from the appropriate configuration. This is usually the active configuration.

For 32-bit format: To obtain the real force and torque values, each force output value has to be divided by the Counts per Force and each torque output value has to be divided by the Counts per Torque factor.

The Counts per Force and Counts per Torque factors can be obtained from the Configurations web page. See [Section 4.6—Configurations Page \(config.htm\)](#) for more information.

14.2.2 DeviceNet


In order to reduce the amount of data transmitted over DeviceNet, the force and torque values are reduced to 16 bits using the Scaling Factor for DeviceNet and CAN values (see [Figure 14.1](#)) before they are transmitted.

To obtain the force and torque values in user units, each received force value has to be divided by (*Counts per Force ÷ Scaling Factor for DeviceNet and CAN*) for the axis and each received torque value has to be divided by (*Counts per Torque ÷ Scaling Factor for DeviceNet and CAN*) for the axis.

NOTICE: Be sure to use the scaling factors from the appropriate configuration. This is usually the active configuration.

The Counts per Force, Counts per Torque, and Scaling Factor for DeviceNet and CAN factors can be found on configurations web page. For more information, see [Section 4.6—Configurations Page \(config.htm\)](#).

Figure 14.1—Scaling Factors for DeviceNet and CAN



14.3 Object Model

14.3.1 Data Types

The following is a description of all of the data types used in the object model:

Table 14.5—Data Types	
Data Type	Description
BOOL	Boolean
BYTE	Bit String (8-bit)
DINT	Signed Double Integer (32-bit)
DWORD	Bit String (32-bit)
INT	Signed Integer (16-bit)
REAL	Floating Point
SHORT_STRING	Character string (1 byte per character, 1 byte length indicator)
SINT	Signed Short Integer (8-bit)
STRING	Character String (1 byte per character)
UDINT	Unsigned Double Integer (32-bit)
UINT	Unsigned Integer (16-bit)
USINT	Unsigned Short Integer (8-bit)
WORD	Bit String (16-bit)

14.3.2 EtherNet/IP

To obtain the real force and torque values, each force output value has to be divided by the Counts per Force and each torque output value has to be divided by the Counts per Torque factor.

Table 14.6—Name and Data Value				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Revision	UINT	N/A	Get
2	Max Instance	UINT	6	Get
3	Number of Instances	UINT	6	Get
100	Bias	USINT	N/A	Set

Bias – any set to non-zero value will bias, a set to zero will unbias the transducer readings.

Table 14.7—Instance Attributes (Instance 1–6)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Raw Gage Reading	INT	N/A	Get
2	Gage Bias	INT	N/A	Get/Set

Instances 1–6 correspond to Gages 0–5 respectively.

Table 14.8—Instance Attributes (Instance 1–6)			
Service Codes	Implemented for		Service Name
	Class Level	Instance Level	
0x0E	Yes	Yes	Get_Attribute_Single
0x10	No	Yes	Set_Attribute_Single

Instances 1–6 correspond to Gages 0–5 respectively.

14.3.3 Transducer Force/Torque Object (0x65—6 Instances)

Table 14.9—Class Attributes (Instance 0)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Revision	UINT	1	Get
2	Max Instance	UINT	6	Get
3	Number of Instances	UINT	6	Get

Table 14.10—Instance Attributes (Instance 1–6)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1 ¹	Resolved Axis Data (32-bit)	DINT	N/A	Get
2	Resolved Axis Data (16-bit) (for DeviceNet)	INT	N/A	Get
3	Minimum Peak	DINT	N/A	Get/Set ²
4	Maximum Peak	DINT	N/A	Get/Set ²

Instances 1, 2, 3, 4, 5, 6 correspond to axis Fx, Fy, Fz, Tx, Ty, Tz respectively.

- If 16-bit unsigned data is enabled, the upper 16 bits always remain 0 and the lower 16-bits are the unsigned 16-bit F/T data.
- Any set attribute value will reset the specified peak value.

Table 14.11—Common Services				
Service Codes	Implemented for		Service Name	
	Class Level	Instance Level		
0x0E	Yes	Yes	Get_Attribute_Single	
0x10	No	Yes	Set_Attribute_Single	

14.3.4 Transducer Force/Torque Object (0x65—6 Instances)

Table 14.12—Class Attributes (Instance 0)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Revision	UINT	1	Get

Table 14.13—Instance Attributes (Instance 1–6)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Thresholds Breached	DWORD	N/A	Get
2	Thresholds Output Result	BYTE	N/A	Get
3	Threshold Latched	BOOL	N/A	Get/Set†

†Threshold Latched – any set attribute value will reset value to FALSE.

Table 14.14—Common Services				
Service Codes	Implemented for		Service Name	
	Class Level	Instance Level		
0x0E	Yes	Yes	Get_Attribute_Single	
0x10	No	Yes	Set_Attribute_Single	

14.3.5 System Status Object (0x67—1 Instance)

Table 14.15—Class Attributes (Instance 0)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Revision	UINT	1	Get

Table 14.16—Instance Attributes (Instance 1)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Status Code (32-bit)	DWORD	N/A	Get
2	Status Code (16-bit)†	WORD	N/A	Get

†This attribute is sized for DeviceNet.

Table 14.17—Common Services				
Service Codes	Implemented for		Service Name	
	Class Level	Instance Level		
0x0E	Yes	Yes	Get_Attribute_Single	

14.3.6 Configurations Object (0x71—16 Instances)

Table 14.18—Instance Attributes (Instance 1–16)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Configuration Name	SHORT_STRING[32]	N/A	Get/Set
2	Calibration Selection (0 to 15)	USINT	N/A	Get/Set
3	Calibration Selection's Calibration Type	SHORT_STRING[32]	N/A	Get
4	User Force Units†	BYTE	N/A	Get/Set
5	User Torque Units‡	BYTE	N/A	Get/Set
6	User Transform – Dx	REAL	N/A	Get/Set
7	User Transform – Dy	REAL	N/A	Get/Set
8	User Transform – Dz	REAL	N/A	Get/Set
9	User Transform – Rx	REAL	N/A	Get/Set
10	User Transform – Ry	REAL	N/A	Get/Set
11	User Transform – Rz	REAL	N/A	Get/Set
12	User Transform Distance Units††	BYTE	N/A	Get/Set
13	User Transform Angle Units‡‡	BYTE	N/A	Get/Set
14	User Counts per Unit Force	UINT	N/A	Get
15	User Counts per Unit Torque	UINT	N/A	Get

† Refer to cfgfu in [Section 8.3—Configurations CGI \(config.cgi\)](#) for force units.

‡ Refer to cfgtu in [Section 8.3—Configurations CGI \(config.cgi\)](#) for torque units.

†† Refer to cfgtdu in [Section 8.3—Configurations CGI \(config.cgi\)](#) for tool transformation distance units.

‡‡ Refer to cfgtau in [Section 8.3—Configurations CGI \(config.cgi\)](#) for tool transformation angle units.

Table 14.18—Instance Attributes (Instance 1–16)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
16	User Max Rating – Fx	REAL	N/A	Get
17	User Max Rating – Fy	REAL	N/A	Get
18	User Max Rating – Fz	REAL	N/A	Get
19	User Max Rating – Tx	REAL	N/A	Get
20	User Max Rating – Ty	REAL	N/A	Get
21	User Max Rating – Tz	REAL	N/A	Get
100	User Defined Field #1	SHORT_STRING[16]	N/A	Get/Set
101	User Defined Field #2	SHORT_STRING[16]	N/A	Get/Set

† Refer to cfgfu in [Section 8.3—Configurations CGI \(config.cgi\)](#) for force units.
 ‡ Refer to cfgtu in [Section 8.3—Configurations CGI \(config.cgi\)](#) for torque units.
 †† Refer to cfgtdu in [Section 8.3—Configurations CGI \(config.cgi\)](#) for tool transformation distance units.
 ‡‡ Refer to cfgtau in [Section 8.3—Configurations CGI \(config.cgi\)](#) for tool transformation angle units.

Table 14.19—Common Services			
Service Codes	Implemented for		Service Name
	Class Level	Instance Level	
0x0E	Yes	Yes	Get_Attribute_Single
0x10	No	Yes	Set_Attribute_Single

14.3.7 Transducer Force/Torque Object (0x65—6 Instances)

Table 14.20—Class Attributes (Instance 0)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Revision	UINT	1	Get

Table 14.21—Instance Attributes (Instance 1–6)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Thresholds Breached	DWORD	N/A	Get
2	Thresholds Output Result	BYTE	N/A	Get
3	Threshold Latched	BOOL	N/A	Get/Set†

Table 14.22—Common Services				
Service Codes	Implemented for		Service Name	
	Class Level	Instance Level		
0x0E	Yes	Yes	Get_Attribute_Single	
0x10	No	Yes	Set_Attribute_Single	

14.3.8 Thresholding Settings Object (0x73—32 Instances)

Table 14.23—Class Attributes (Instance 0)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Revision	UINT	1	Get
2	Max Instance	UINT	32	Get
3	Number of Instances	UINT	32	Get

Table 14.24—Instance Attributes (Instance 1–32)				
Attribute ID	Name	Data Type	Default Data Value	Access Rule
1	Enable/Disable	BOOL	N/A	Get/Set
2	Axis Number†	SINT	N/A	Get/Set
3	Comparison‡	SINT	N/A	Get/Set
4	Counts Value	DINT	N/A	Get/Set
5	Output Code	BYTE	N/A	Get/Set

† Refer to mcxn in [Section 8.2—Thresholding CGI \(moncon.cgi\)](#) for axis information.
‡ Refer to mccn in [Section 8.2—Thresholding CGI \(moncon.cgi\)](#) for comparison information.

Table 14.25—Common Services				
Service Codes	Implemented for		Service Name	
	Class Level	Instance Level		
0x0E	Yes	Yes	Get_Attribute_Single	
0x10	No	Yes	Set_Attribute_Single	

15. CAN Bus Operation

15.1 Overview

The Net F/T supports a basic CAN protocol to allow reading of force/torque data and system status word over CAN without the need for a DeviceNet scanner.

The CAN Bus base address and Baud Rate settings are configured using the DIP switches. Refer to [Section 3.9—DIP Switches and Termination Resistor](#) for additional information.

To use the Net F/T's CAN bus protocol, CAN Bus must be selected on the Communications page and power must be present on the Pwr/CAN connector.

15.2 Protocol Description

A request data message sent to the Net F/T initiates copying of the current set of force and torque data into an output buffer and the subsequent transmission of the output buffer.

Depending on the request message identifier (REQUEST LONG or REQUEST SHORT), the Net F/T either sends 32-bit values packed into four messages or 16-bit values packed into two messages.

Values are in little endian format (least-significant byte first). For example, a 16-bit value received as 0x56 0x02 represents 0x0256. Signed numbers use 2's complement format. The 32-bit value received as 0x0F 0xCF 0xDA 0xDA 0xFD represents 0xFDDACF0F, which is a negative number (because the highest bit is set). Its decimal value is -35991793.

If a data request message is received during an ongoing transmission, the ongoing transmission will be terminated and the new request processed.

15.3 Base Address and Communication Format

The CAN Bus base address is set by DIP switches 1 through 6. For more information refer to [Section 3.9.2—Node Address](#) and [Table 3.1](#). The factory set base address is 432.

Table 15.1—Request Long Data

Message to Net F/T	Response from Net F/T	CAN Identifier	Data length in bytes	1st–4th data bytes	5th–8th data bytes	Comment
Request Long Data	-	Base Address	1	0x01 (BYTE)	N/A	Sends a copy of force and torque data in long format (an ongoing transmission will be terminated)
-	Fx and Tx data	Base Address +1	8	Fx value (DINT)	Tx value (DINT)	X-axis force and torque values in long format
-	Fy and Ty data	Base Address +2	8	Fy value (DINT)	Ty value (DINT)	Y-axis force and torque values in long format.
-	Fz and Tz data	Base Address +3	8	Fz value (DINT)	Tz value (DINT)	Z-axis force and torque values in long format.
-	Status and sample number	Base Address +4	8	system status (DINT)	sample number (DINT)	System status word and sample number in long format.

Table 15.2—Request Short Data

Message to Net F/T	Response from Net F/T	CAN Identifier	Data length in bytes	1st–4th data bytes	5th–8th data bytes	Comment
Request Long Data	-	Base Address	1	0x02 (BYTE)	N/A	Sends a copy of force and torque data in short format (an ongoing transmission will be terminated)
-	Fx, Tx, Fy, and Tx data	Base Address +5	8	Fx value (INT) Tx value (INT)	Fy value (INT) Ty value (INT)	X-axis force and torque values and Y-axis force and torque in short format
-	Fz and Tz data, Status, and sample number	Base Address +6	8	Fz value (INT) Tz value (INT)	system status (INT) sample number (INT)	Z-axis force and torque values, system status word, and sample in short format.

Table 15.3—Bias Command

Message to Net F/T	Response from Net F/T	CAN Identifier	Data length in bytes	1st–4th data bytes	5th–8th data bytes	Comment
Bias	-	Base Address	1	0x04 (BYTE)	N/A	Zeros the force and torque readings at the current loading level.

Table 15.4—Clear Threshold Latch Command

Message to Net F/T	Response from Net F/T	CAN Identifier	Data length in bytes	1st–4th data bytes	5th–8th data bytes	Comment
Clear Threshold Latch	-	Base Address	1	0x08 (BYTE)	N/A	Clears the threshold latch so it can respond to subsequent conditions.

15.4 Baud Rate

Baud Rate is set by either hardware or software configuration to 125 kbps, 250 kbps or 500 kbps. The baud rate will be set by software when DIP switch positions 7 and 8 are ON. For more information refer to [Section 3.9.3—Baud Rate](#) and [Table 3.3](#). The factory set baud rate is 500 kbps.

15.5 Calculating F/T Values for CAN

The Net F/T multiplies each force and torque value with a factor before it is sent over the CAN interface. This allows for sending force and torque values with the full resolution. The application program has to divide each force and torque value with a specific factor to obtain the real data.

Refer to [Table 14.2](#) for 16-bit data handling and [Table 14.3](#) for 32-bit data handling.

16. Fieldbus Operation

Operational information about the additional fieldbus included in some Net Boxes is described below.

16.1 PROFINET Fieldbus Interface

A Net Box with the -PN option provides a PROFINET interface for access to the F/T data and for control of certain functions. The standard EtherNet/IP and DeviceNet interfaces may be used simultaneously while using the PROFINET interface.

Although the Net Box's PROFINET interface shares the standard Ethernet port, it has its own MAC address and IP address. The fieldbus's MAC address is shown as MAC ID 2 on the connector side of the Net Box.

NOTICE: The PROFINET interface does not support DHCP. The Net Box's GSDML file details the PROFINET capabilities of the Net Box.

Unlike the Net F/T's other interfaces to tool transformations, the TCP interface uses scaled integer values to define distances and rotations.

The following table lists the PROFINET interface parameters employed in the –PN Net Box:

Table 16.1—PROFINET Interface Parameters	
Parameter	Description
DCP	supported
Used Protocols (subset)	UDP, IP, ARP, ICMP (Ping)
Topology recognition	LLDP, SNMP V1, MIB2, physical device
VLAN- and priority tagging	yes
Context Management	by CL-RPC
Minimum cycle time	2ms
Minimum F/T data update rate	20Hz
Baud rate	100 MBit/s
Data transport layer	Ethernet II, IEEE 802.3

A GSDML file is available for the ATI website at

http://www.ati-ia.com/Products/ft/software/net_ft_software.aspx or can be requested via email at info@ati-ia.com. The ATI part number for the GSDML file is 9031-05-1021 and has the description “Net F/T PROFINET GSDML.file.”

16.1.1 Enabling the PROFINET Interface

The PROFINET fieldbus interface can be enabled and disabled using the Communications web page. See the Fieldbus Module Settings portion of [Section 4.7—Communication Settings Page \(comm.htm\)](#) for details.

Table 16.2—PROFINET Interface Parameters			
16-bit Word	Data Type	Name	Description/Function
0	INT	Status	Status word, bits 16 through 31
1	INT	Fx	Force in X-direction, 16-bit format
2	INT	Fy	Force in Y-direction, 16-bit format
3	INT	Fz	Force in Z-direction, 16-bit format
4	INT	Tx	Torque about X-axis, 16-bit format
5	INT	Ty	Torque about Y-axis, 16-bit format
6	INT	Tz	Torque about Z-axis, 16-bit format
7	UINT	Sequence	Incremented each time a dataset is sent

Input word 0, Status, contains bits 16 through 31 of the Net F/T's System Status Code. See [Section 18.1—System Status Code](#) for more details on the contents.

Input words 1–6 contain values representing force and torque vectors Fx, Fy, Fz, Tx, Ty, and Tz. In order to reduce the amount of data transmitted over PROFINET, they are reduced to 16 bits using the Scaling Factor for DeviceNet and CAN values (see [Figure 14.1](#)) before they are transmitted.

To obtain the force and torque values in user units, each received force value has to be divided by (Counts-per-Force ÷ Scaling Factor for DeviceNet and CAN) for the axis and each received torque value has to be divided by (Counts-per-Torque ÷ Scaling Factor for DeviceNet and CAN) for the axis.

The Counts-per-Force, Counts-per-Torque, and Scaling Factor for DeviceNet and CAN factors can be found on configurations web page. For more information, see [Section 4.6—Configurations Page \(config.htm\)](#).

Table 16.3—Output Mapping

Byte	BitNumber	Name	Description/Function
0	0	Bias	Perform tare function to zero out any load reading
	1	Reset Latch	Reset threshold latch
	2	reserved	reserved
	3	reserved	reserved
	4	reserved	reserved
	5	reserved	reserved
	6	reserved	reserved
	7	reserved	reserved
1	0	Config Select bit 0	Selects a Net F/T configuration, from 0 to 15
	1	Config Select bit 1	
	2	Config Select bit 2	
	3	Config Select bit 3	
	4	reserved	reserved
	5	reserved	reserved
	6	reserved	reserved
	7	reserved	reserved
2	0-7	Threshold high	Threshold enable mask, high byte
3	0-7	Threshold low	Threshold enable mask, low byte

Output byte 0, bit 0 performs a bias function when it is set to one. See the bias button information in [Section 4.2—Snapshot Page \(rundata.htm\)](#) for details on this function. Bit 0 should be set to one for at least 100 ms to ensure the bias is executed. Then it should be returned to zero.

Output byte 0, bit 1 performs a reset threshold latch function when it is set to one. See the reset latch button information in [Section 4.5—Thresholding Page \(moncon.htm\)](#) for details on this function. Bit 1 should be set to one for at least 100 ms to ensure a reset latch is executed. Then it should be returned to zero.

Output byte 0, bits 2–7 are reserved and should not be used.

Output byte 1, bits 0–3 select the active configuration (0 through 15) to be used. There is a delay of up to one second before the newly-selected configuration becomes usable. During the change of configuration s, the Net F/T does not supply valid force and torque data. See the active configuration information in [Section 4.4—Settings Page \(setting.htm\)](#) for details on active configuration.

Output byte 1, bits 4–7 are reserved and should not be used.

Output bytes 2 and 3 form a 16-bit threshold enable mask that enables and disables threshold conditions. Each bit, 0–15, of the threshold enable mask maps directly to its corresponding threshold condition number N. A value of one enables the corresponding condition while a value of zero disables the condition. See [Section 4.5—Thresholding Page \(moncon.htm\)](#) for more information on thresholding.

NOTICE: When Fieldbus Module Enabled is set to Enabled (on the Communications Settings page), active configuration selection and thresholding statement selection is controlled by the PROFINET output data. While enabled, these values are not controlled by Net Box web pages or CGI interface.

16.1.2 Communications CGI (comm.cgi) Options

The PROFINET Fieldbus Net Box can have the PROFINET function enabled and disabled via CGI. The following function is available in the comm.cgi in addition to those shown in [Table 8.4](#):

Table 16.4—PROFINET Interface Parameters		
Variable Name	Allowed Values	Description
fieldbusenabled	Integers: 0 or 1	Enable (value=1) or disable (value=0) the PROFINET fieldbus interface.

16.1.3 XML Page Elements

The PROFINET Fieldbus Net Box has two additional XML elements included in the netftapi2.xml page output. The following elements are available in the netftapi2.xml page in addition to those shown in [Table 9.2](#):

Table 16.5—Additional netftapi2.xml XML Elements			
XML Element	Data Type	Description	Reference
fieldbusenabled	ENABL	PROFINET interface setting	comm
fieldbusfirmware	STRING64	PROFINET interface firmware version	comm

16.1.4 Returning Default Settings

The PROFINET Station Name and the PROFINET IP address can be cleared to default settings. This is useful when already-configured devices need to be moved or replaced in the PROFINET network. To return the PROFINET fieldbus Net Box to default PROFINET settings, the power must be on and the fieldbus module must already be enabled (see [Section 4.7—Communication Settings Page \(comm.htm\)](#)). The PROFINET network connection should be disconnected to ensure the Net Box does not automatically get recommissioned. The steps are:

1. Remove the Net Box cover (see [Section 3.9—DIP Switches and Termination Resistor](#)).
2. Move DIP switch 10 to the ON position.
3. Once the MS LED is blinking red, return DIP switch 10 to the OFF position.
4. Replace the Net Box cover.
5. Disconnect power. The PROFINET Station Name and IP address will be reset when power is reapplied.

NOTICE: Returning to the PROFINET default settings does not affect the standard Ethernet and EtherNet/IP settings.

16.1.5 Replacing and Installed PROFINET Fieldbus Net Box

Replacing an installed PROFINET Fieldbus Net Box can easily be done if the Topology of the PROFINET network was properly defined with the PROFINET engineering tool and the PROFINET controller supports automatic device replacement.

16.1.5.1 Replacing and Installed PROFINET Fieldbus Net Box

1. Remove the power and network connections of the PROFINET Fieldbus Net Box that is to be replaced. Mechanically unmount the Net Box if necessary.
2. Mount the replacement PROFINET Fieldbus Net Box and connect the power and PROFINET network connections to it.
3. The new Net Box will automatically be assigned the name and IP address of the former Net Box.
4. After a few seconds, the NS/BF LED will turn solid green and the Net Box will be correctly operating on the network.

16.1.5.2 Replacement with Previously Commissioned Fieldbus Net Box

1. Remove the power and network connections of the PROFINET Fieldbus Net Box that is to be replaced. Mechanically unmount the Net Box if necessary.
2. Mount the replacement PROFINET Fieldbus Net Box and connect the power to it. Do not make the network connection.
3. Follow the steps in *Section 16.1.4—Returning Default Settings* to remove the previous commission.
4. Connect the PROFINET Fieldbus Net Box to the PROFINET network.
5. The new Net Box will automatically be assigned the name and IP address of the former Net Box.
6. After a few seconds, the NS/BF LED will turn solid green and the Net Box will be correctly operating on the network.

17. Advanced Topics

17.1 Improving Ethernet Throughput

In an optimum network setup, the Net F/T's RDT data will arrive at the host computer with no loss of data

If you observe lost data samples, you may do one or all of the following:

17.1.1 Direct Connection between Net F/T and Host

To achieve the best Ethernet performance (and avoiding the loss of data packages), we recommend connecting the Net Box directly to the host computer. If you need to use a switch, then try to use only one switch between sensor system and host. Avoid going through several switches or going through a hub.

17.1.2 Choice of Operating System

The Windows operating system periodically performs housekeeping processes that can require a significant amount of processing power over a short amount of time. During these intervals, a loss of data can occur because Windows does not treat UDP data with a high enough priority. If a loss of data is not acceptable for your application, then the use of a real-time operating system is recommended.

17.1.3 Increasing Operating System Performance

The following items may also help you increase the performance of your computer system so it can best respond to the Net F/T's fast data rates:

Disable software firewall. One way to improve the Ethernet performance is not to have any software firewall activated. In some cases, this may require help from IT personnel.

Disable file and printer sharing. The processes associated with file and printer sharing can slow down an operating system's response to Ethernet data and may lead to lost data.

Disable unnecessary network services. Unnecessary network services and protocols can slow down an operating system's response to Ethernet data and may lead to lost data. For the best UDP performance, it may be necessary to turn off every network service except for TCP/IP.

Use an Ethernet traffic snooper. An Ethernet traffic snooper can be invaluable in detecting that there are processes using up Ethernet bandwidth and potentially slowing down the response of your computer's operating system. This is an advanced technique that your IT department may need to perform. The free software program Wireshark (www.wireshark.org) is commonly used for this type of investigation.

Use a dedicated computer. A dedicated measurement computer isolated from the company network will not be burdened by the company network processes.

Use the Net F/T's multi-unit synchronization capability if there are multiple Net F/Ts on the same network. This will eliminate data collisions from Net F/Ts transmitting at the same time.

17.1.4 Avoid Connecting the Net F/T to a Your Organization's Network

Being connected to a network requires the periodic access to the Ethernet interface by processes other than your measurement application. This can lead to loss of Net F/T UDP data.

17.1.5 Use a Dedicated Network

Placing the Net F/T on a dedicated Ethernet network with no other devices on the network, other than the host computer, will remove data collisions and give the best network performance.

17.2 Reducing Noise

17.2.1 Mechanical Vibration

In many cases, perceived noise is actually a real fluctuation of force and/or torque, caused by vibrations in the tooling or the robot arm. The Net F/T system offers digital low-pass filters that can dampen frequencies above a certain threshold. If this is not sufficient, you may want to add a digital filter to the application software.

17.2.2 Electrical Interference

Check the Net F/T's ground connections if you observe interference by motors or other noise-generating equipment.

Consider using the Net F/T's digital low pass filters if sufficient grounding is not possible or does not reduce the noise.

Verify that you are using a Class 1 power supply, which has an earth ground connection.

17.3 Detecting Failures (Diagnostics)

17.3.1 Detecting Sensitivity Changes

Sensitivity checking of the transducer can also be used to measure the transducer system's health. This is done by applying known loads to the transducer and verifying the system output matches the known loads. For example, a transducer mounted to a robot arm may have an end-effector attached to it.

If the end-effector has moving parts, they must be moved in a known position. Place the robot arm in an orientation that allows the gravity load from the end-effector to exert load on many transducer output axes.

Record the output readings.

Position the robot arm to apply another load, this time causing the outputs to move far from the earlier readings.

Record the second set of output readings.

Find the differences from the first and second set of readings and use it as your sensitivity value.

Even if the values vary somewhat from sample set to sample set, they can be used to detect gross errors. Either the resolved outputs or the raw transducer voltages may be used (the same must be used for all steps of this process).

17.4 Scheduled Maintenance

17.4.1 Periodic Inspection

For most applications, there are no parts that need to be replaced during normal operation. With industrial-type applications that continuously or frequently move the system's cabling, you should periodically check the cable jacket for signs of wear. These applications should implement the procedures discussed in [Section 17.3—Detecting Failures \(Diagnostics\)](#) to detect any failures.

The transducer must be kept free of excessive dust, debris, or moisture. Applications with metallic debris (i.e., electrically-conductive) must protect the transducer from this debris. Transducers without specific factory-installed protection are to be considered unprotected. The internal structure of the transducers can become clogged with particles and will become uncalibrated or even damaged.

17.5 A Word about Resolution

ATI's transducers have a three sensing beam configuration where the three beams are equally spaced around a central hub and attached to the outside wall of the transducer. This design transfers applied loads to multiple sensing beams and allows the transducer to increase its sensing range in a given axis if a counterpart axis has reduced (see 9620-05-Transducer Section—Installation and Operation Manual).


The resolution of each transducer axis depends on how the applied load is spread among the sensing beams. The best resolution occurs in the scenario when the quantization of the gages is evenly distributed as load is applied. In the worst case scenario, the discrete value of all involved gages increases at the same time. The typical scenario will be somewhere between these two.

F/T resolutions are specified as typical resolution, defined as the average of the worst and best case scenarios. Because both multi-gage effects can be modeled as a normal distribution, this value represents the most commonly perceived, average resolution. Although this misrepresents the actual performance of the transducers, it results in a close (and always conservative) estimate.

17.6 Connecting to Specific Industrial Robots

Many industrial robots connect to the Net F/T over its EtherNet/IP connection. When connecting to the Net F/T using EtherNet/IP, the Net F/T's EtherNet/IP protocol must be enabled and its DeviceNet protocol must be disabled (by enabling CAN bus protocol). This can be done on the Net F/T's Communications page (comm.htm).

Figure 17.1—Enabling EtherNet/IP on the Communications Page (comm.htm)



The following information will be necessary to configure the connection to the Net F/T:

Table 17.1—Net F/T EtherNet/IP Configuration Information

Item	Decimal Value	Hexadecimal Value
Vendor Code	555	0x022B
Product Type	0	0x0
Product Code	1	0x1
Major Revision	1	0x1
Minor Revision	20	0x14
Configuration Instance	128	0x80
Target to Originator (input) Instance	100	0x64
Originator to Target (output) Instance	102	0x66
Input Size (bytes)	28	0x1C
Output Size (byte) I/O Output is unused	0	0x0

17.6.1 ABB Robotics

ABB robot controller firmware versions 5.14 and later support EtherNet/IP connections to the Net F/T.

17.6.2 Denso Robotics

Denso RC7 robot controllers with EtherNet/IP support connections to the Net F/T.


17.6.3 Fanuc Robotics

Fanuc robot controllers with an EtherNet/IP scanner installed can communicate with the Net F/T. Details about the Fanuc EtherNet/IP scanner can be found in the Fanuc manual FANUC Robotics SYSTEM R-30iA EtherNet/IP Setup and Operations Manual MAROCENTET04081E REV B Version 7.40.

Fanuc R30iA robot controller configuration. See Section 4.2.4—Advanced EtherNet/IP Scanner Configuration in the Fanuc manual for additional information:

- Set the robot as the EtherNet/IP scanner (Client).
- In the robot controller's scan list, set the Connection Type for the Net F/T to Input-Only.
- For TCP communications, set the Transport Type to UNICAST in order to use the Socket Messaging. For UDP communications, set the robot controller's Transport Type to MULTICAST.
- If the controller's word size is set to 16-BIT WORDS, then set the input size to 14 or for 8-BIT BYTES, then set the input size to 28. Pages 4–7 and 4–8 of the Fanuc manual discuss input and output sizes and how to set 8-bit or 16-bit words.
- The Output Run/Idle header must be turned off (set to Heartbeat).

Figure 17.2—Example Configuration Settings



Some Karel programming is because the Fanuc robot controller does not support the following types of data:

- DINT (Double Integer)
- EtherNet/IP data of 32 bits. Two words of 16 bits (high and low) will need to be combined to use 32 bits.
- Two's complement.

17.6.4 Kuka Robotics

Kuka robots with the KUKA.ForceTorqueControl package connect to the Net F/T and provide the robot with real-time force control.

17.6.5 Motoman Robotics

A Motoman robot controller with an EtherNet/IP add-on board is required for connections to the Net F/T.

18. Troubleshooting

This section includes answers to some issues that might arise when setting up and using the Net F/T system. The question or problem is listed followed by its probable answer or solution. They are categorized for easy reference.

The information in this section should answer many questions that might arise in the field. Customer service is available to users who have problems or questions addressed in the manuals.

Note

Please read the manual before calling customer service. Before calling, have the following information available:

1. Serial number (e.g., FT01234)
2. Transducer model (e.g., Nano17, Gamma, Theta, etc.)
3. Calibration (e.g., US-15-50, SI-65-6, etc.)
4. Accurate and complete description of the question or problem
5. Computer and software information. Operating system, PC type, drivers, application software, and other relevant information about your configuration.

If possible, be near the F/T system when calling.

How to Reach Us

ATI Industrial Automation

1031 Goodworth Drive
Apex, NC 27539 USA
www.ati-ia.com

Application Engineering

Tel: +1.919.772.0115, Option 2, Option 2
Fax: +1.919.772.8259
E-mail: ft_support@ati-ia.com

18.1 System Status Code

This section includes answers to some issues that might arise when setting up and using the Net F/T system. The question or problem is listed followed by its probable answer or solution. They are categorized for easy reference.

The Net F/T performs many diagnostic checks during operation and reports results in a 32-bit system status code. Each F/T record includes this system status code. The bit patterns for all present error conditions are or'd together to form the system status code. If any error condition is present then bit 31 of the system status code is set.

Bit 16 is set if a threshold is latched. This bit does not indicate a system error.

The system status code should be:

0x00000000 if no errors and no threshold statements are breached

0x80010000 if no errors and a threshold statement is breached.

Any other code signals means there is a serious error. Table 16.1–System Status Code Bit Assignments describes possible errors and their bit assignments.

Table 18.1—System Status Code Bit Assignments		
Bit	Bit Pattern	Description
31	0x80000000	Error bit (set if any error condition exists)
30	0x40000000	CPU or RAM error
29	0x20000000	Digital board error
28	0x10000000	Analog board error
27	0x08000000	Serial link communication error
26	0x04000000	Program memory verification error
25	0x02000000	Halted due to configuration errors
24	0x01000000	Settings validation error
23	0x00800000	Configuration settings incompatible with transducer calibration
22	0x00400000	Network communication failure
21	0x00200000	CAN communication error
20	0x00100000	RDT communication error
19	0x00080000	EtherNet/IP protocol failure
18	0x00040000	DeviceNet-compatibility mode protocol failure
17	0x00020000	Transducer Saturation or A/D operation error
16	0x00010000	Threshold latched
15	0x00008000	reserved
14	0x00004000	Watchdog timeout error
13	0x00002000	Stack check error
12	0x00001000	Serial EEPROM I2C communications failure
11	0x00000800	Serial flash SPI communications failure
10	0x00000400	Analog board watchdog timeout error
9	0x00000200	Excessive strain gage excitation current
8	0x00000100	Insufficient strain gage excitation current
7	0x00000080	Artificial analog ground out of range
6	0x00000040	Analog Board power supply too high
5	0x00000020	Analog Board power supply too low
4	0x00000010	Serial link data unavailable
3	0x00000008	Reference voltage or power monitoring error
2	0x00000004	Internal temperature error
1	0x00000002	HTTP protocol failure
0	0x00000001	reserved
—	0x00000000	Healthy

18.2 Status Word

The status word is a bitmap which contains information about the errors that can occur in various subsystems of the Digital F/T sensor.

Table 18.2—Status Word Bit Assignments	
Bit	Description
0	Watchdog reset – the analog board was reset by the watchdog timer.
1	Excitation voltage too high
2	Excitation voltage too low
3	Artificial analog ground out of range (above 0.007V).
4	Power supply too high (> 25V).
5	Power supply too low (< 10 V).
6	Not used.
7	Error accessing stored settings in EEPROM – EEPROM hardware did not respond.
8	Invalid configuration data (baud rate).
9	Strain gauge bridge supply current too high (> 3V on current sense).
10	Not used (was Strain gauge bridge supply current too low)
11	Thermistor too high (> 100C (1.5V on thermistor)).
12	Thermistor too low. (< -40C (0.1V on thermistor)).
13	Not used (was DAC reading out of range)
14	Not used.
15	Any error sets this bit.

18.3 Questions and Answers

Table 18.3—Powering Up

Question/Problem	Answer/Solution
Xdcr LED stays red after the twenty second power up phase	Check transducer cable connections. Verify transducer cable is not damaged. There may be an internal error in the Net Box.
Xdcr LED is red for the first twenty seconds after power up then turns green	This is normal operation.
The LS EN (Ethernet Link Status) is not green or flashing green	Check Ethernet cable connections.

Table 18.4—Communications

Question/Problem	Answer/Solution
What IP address is assigned to the Net F/T?	See Section 6.1—Finding Net F/Ts on the Network .
How can the Net F/T system be set to the default IP address of 192.168.1.1	Set DIP switch 9 to the ON position (see Section 3.9—DIP Switches and Termination Resistor). The Net F/T must be power cycled for the new setting to be used.
DHCP is not assigning an IP address	Ethernet LAN must be connected during power up. DHCP is not selected as the IP Address Mode on the Communications page. The DHCP server waits more than thirty seconds to respond.
Browser cannot find the Net F/T on Ethernet network even though the Net F/T configuration utility reports an IP address	Clear the Windows computer's ARP table to remove memory of a previous device that used the same IP address as the Net F/T by restarting the computer or, if you have administrative privileges, by going to the computer's Start menu, selecting Run..., and entering "arp -d *".
Incorrect CAN Bus Base Address, DeviceNet MAC ID, and/or Baud Rate reported	Power must be present on the Pwr/CAN connector to correctly report these values.
System status reports DeviceNet Protocol Failure when using DeviceNet	DeviceNet is not available unless power is present on the Pwr/CAN connector.

Table 18.5—Java Demo

Question/Problem	Answer/Solution
Demo displays zeros for force and torque values and question marks for configuration data	Check IP address and restart demo.
Excessive IO exception: Receive timed out errors	The Ethernet connection was interrupted. Check Ethernet cabling and Net F/T power.
Error message: IO exception: <path and file name> (The process cannot access the file because it is being used by another process)	Selected file for data is in use by another program. Close file or change file name and press Collect Streaming again.
The message Could not find the main class. Program will exit appears in a window titled Java Virtual Machine Launcher.	Computer requires a newer version of Java. Java may be downloaded from www.java.com/getjava .

Table 18.6—Web Pages

Question/Problem	Answer/Solution
The Invalid Request page appears	One or more entries on the previous web page were invalid or out of range. Go back to the previous page and review the last entry. Make only one change at a time to make debugging easier.
The HTTP 1.0 401 Error - Unauthorized page appears	You tried to access one of the protected pages of the web server. These pages are reserved for ATI Industrial Automation maintenance.

18.3.1 Errors with Force and Torque Readings

Bad data from the transducer's strain gages can cause errors in force/torque readings. These errors can result in problems with threshold monitoring, transducer biasing, and accuracy. Listed below are the basic conditions of bad data. Use this to troubleshoot your problem. In most cases, problems can be seen better while looking at the raw strain gage data, displayed on the Snapshot page. See [Section 4.2—Snapshot Page \(rundata.htm\)](#) for more details.

Table 18.7—Errors with Force and Torque Readings

Question/Problem	Answer/Solution
Sat LED glows red (transducer saturation)	Saturation occurs if the transducer is loaded beyond its maximum measurement range or in the event of an electrical failure within the system. The error status will stay on until the saturation error stops. When the data from a raw decimal strain gage reads the positive or negative maximums (nominally -32768 or +32767), that gage is saturated. This sets the saturation error bit in the system status code (see Section 18.1—System Status Code) and causes the Sat LED to turn red.
Noise	Jumps in raw strain gage readings (with transducer unloaded) greater than 80 counts is considered abnormal. Noise can be caused by mechanical vibrations and electrical disturbances, possibly from a poor ground. It can also indicate component failure within the system. See Section 17.2—Reducing Noise .
Drift	After a load is removed or applied, the raw gage reading does not stabilize, but continues to increase or decrease. This may be observed more easily in resolved data mode using the bias command. Drift is caused by temperature change, mechanical coupling, or internal failure. Mechanical coupling is caused when a physical connection is made between the tool plate and the transducer body (i.e., filings between the tool adapter plate and the transducer body). Some mechanical coupling is common, such as hoses and wires attached to a tool.
Hysteresis	When the transducer is loaded and then unloaded, gage readings do not return quickly and completely to their original readings. Hysteresis is caused by mechanical coupling (explained in Drift section) or internal failure.

Table 18.8—Connection to Specific Equipment

Equipment Connection	Details
Fanuc robot controllers using EtherNet/IP	Set robot controller connection type to Input Only and set the robot controller as the EtherNet/IP scanner (client). When using Socket Messaging, set the transport type to Multicast for UDP or Unicast for TCP.

19. General Specifications

19.1 Environmental

The standard F/T system is designed to be used in standard laboratory or light-manufacturing conditions. Transducers with an IP60 designation are able to withstand dusty environments. Transducers with an IP65 designation can be washed down with fresh water. Transducers with an IP68 designation can be submerged in up to 10 m of fresh water.

The Net Box is rated to IP65.

19.1.1 Storage and Operating Temperatures

The Net Box can be stored and used at varying temperatures.

Table 19.1—Net Box Storage and Operating Temperatures

Storage Temperature, °C	Operating Temperature, °C
-40 to +100	-20 to +70

NOTICE: These temperature ranges specify the storage and operation ranges in which the system can survive without damage. They do not take accuracy into account. See ATI Industrial Automation manual 9620-05-Transducer Section for transducer environmental information.

When mated with appropriate connectors, the 9105-Net Box can be used in wet environments. The 9105-NETB Net Box can only be used in humidity up to 95% RH, non-condensing.

19.2 Transducer Data Filtering

Figure 19.1 shows the frequency response of the transducer's data acquisition hardware and various filtering options. The graph does not include the effects of any mechanical filtering (which occurs in any spring and mass system).

Figure 19.1—Data Acquisition Subsystem Frequency Response (typical)





Figure 19.2 shows the group delays that various levels of low-pass filtering add to the signals. These delays do not show the Ethernet delays in your network or computer. With no filtering enabled, the Net F/T delivers F/T data to its Ethernet port with a delay of 286 µS.

Figure 19.2—Filtering Group Delays (calculated)



19.3 Electrical Specifications (Power Supply)

Table 19.2—Power Supply Requirements

Power Source†	Minimum Voltage	Maximum Voltage	Maximum Power Consumption
Power over Ethernet‡	36 V	57 V	6 W
Pwr/CAN	11 V	25 V	6 W

† Power is drawn from only one power source at a time.
‡ Conforms to IEEE 802.3af, class 0, receiving power from data lines. Uses Mode A to receive power. Mode B is not supported.

A 9105-NET-GAMMA- transducer and its on-board electronics account for 2.4 W of the systems power consumption. Other transducer models consume less power.

19.3.1 Communications

19.3.1.1 Ethernet Interface

The Ethernet interface is 10/100 Mbit and features both negotiation and auto crossover. It can support up to four TCP connections and one UDP connection.

The EtherNet/IP interface supports one input-only connection and does not support a listen-only connection. It does not support any Client functionality.

19.3.1.2 CAN Interface

The CAN interface supports 125 kbps, 250 kbps, and 500 kbps (see [Section 3.9.3—Baud Rate](#)). A switchable termination resistor is available (see [Section 3.9.1—Termination Resistor](#)).

19.3.2 Mating Connectors

Table 19.3—Mechanical Specifications of Mating Connectors			
Connector	Mating Type	Recommended Torque	Maximum Torque
Ethernet	M12 D-Coded, 4-Pin, male	0.8 Nm to 1.0 Nm	3.0 Nm
Threshold Relay	M8 3-Pin, female	0.5 Nm to 0.6 Nm	1.0 Nm
Pwr/CAN	M12 5-Pin, female	0.8 Nm to 1.0 Nm	3.0 Nm
NETB Transducer	M12 5-Pin, male	0.8 Nm to 1.0 Nm	3.0 Nm
NETBA Transducer	Circular, female	0.7 Nm	

19.3.3 Standard Threshold Relay

The standard threshold relay contacts (NC, NO, or COM) are protected against overload by a resettable fuse. The relay will turn on within 6 ms.


Table 19.4—Standard Threshold Relay Specifications		
	Maximum Rating	Maximum Load
Current	50 mA	10 μ A
Voltage	42 VDC, 30 VAC	10 mVDC

19.3.4 Solid-State Threshold Relay

The optional solid state threshold relay contacts (SSR+ and SSR-) are protected against reverse voltage by a zener diode. The relay will turn on within 500 μ s.

Table 19.5—Solid-State Relay Specifications	
	Maximum Load
Current	35 mA
Voltage	30 VDC

Figure 19.3—Solid-State Relay Voltage Drop vs. Current



19.3.5 NetBox Transducer Cabling

Normally the NetBox is connected to the Transducer via an industry-standard DeviceNet cordset. In cases where this type of cordset cannot be used, the following must be observed:

- Cable specifications for DeviceNet Thick Cabling are ideal.
- The RS485+ and RS485- lines must form a twisted pair.
- The cable capacities should be low enough to work with 1.25 Mbps.
- The total resistance of each conductor should be no more than 0.5Ω

Figure 19.4—Netbox's Transducer Cable Connector (female Pins)





Figure 19.5—Transducer's Transducer Cable Connector (male pins)




19.4 Net Box Weight

Table 19.6—Net Box Weight


Condition	Weight
Without Mounting Plate	0.8 kg (1.8 lbs)
With Mounting Plate	1.1 kg (2.4 lbs)

20. Drawings

20.1 9105-NETB Drawing



20.2 9105-NETBA Drawing



20.3 9105-NETB-PN2 Drawing

