

**SECTION 08 1113  
HOLLOW METAL DOORS AND FRAMES**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Non-fire-rated hollow metal doors and frames.

**1.02 RELATED REQUIREMENTS**

- A. Section 08 7100 - Door Hardware.
- B. Section 09 9123 - INTERIOR PAINTING: Field painting.

**1.03 REFERENCE STANDARDS**

- A. ADA Standards - 2010 ADA Standards for Accessible Design; 2010.
- B. ANSI/SDI A250.4 - Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames and Frame Anchors; 2022.
- C. ANSI/SDI A250.8 - Specifications for Standard Steel Doors and Frames (SDI-100); 2023.
- D. ANSI/SDI A250.10 - Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames; 2020.
- E. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- F. ASTM A1008/A1008M - Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Required Hardness, Solution Hardened, and Bake Hardenable; 2021a.
- G. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2023.
- H. BHMA A156.115 - Hardware Preparation in Steel Doors and Frames; 2016.
- I. ICC A117.1 - Accessible and Usable Buildings and Facilities; 2017.
- J. NAAMM HMMA 805 - Recommended Selection and Usage Guide for Hollow Metal Doors and Frames; 2012.
- K. NAAMM HMMA 830 - Hardware Selection for Hollow Metal Doors and Frames; 2002.
- L. NAAMM HMMA 831 - Hardware Locations for Hollow Metal Doors and Frames; 2011.
- M. NAAMM HMMA 840 - Guide Specifications For Receipt, Storage and Installation of Hollow Metal Doors and Frames; 2017.
- N. NAAMM HMMA 860 - Guide Specifications for Hollow Metal Doors and Frames; 2018.
- O. NAAMM HMMA 861 - Guide Specifications for Commercial Hollow Metal Doors and Frames; 2014.

**1.04 SUBMITTALS**

- A. See Section 01 3000 - Administrative Requirements for submittal procedures.
- B. Product Data: Materials and details of design and construction, hardware locations, reinforcement type and locations, anchorage and fastening methods, and finishes.
- C. Shop Drawings: Details of each opening, showing elevations, glazing, frame profiles, and any indicated finish requirements.
- D. Manufacturer's Certificate: Certification that products meet or exceed specified requirements.

**1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Provide hollow metal doors and frames from SDI Certified manufacturer: <https://steeldoors.org/sdi-certified/#sle>.

- B. Maintain at project site copies of reference standards relating to installation of products specified.

## **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Comply with NAAMM HMMA 840 or ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
- B. Protect with resilient packaging; avoid humidity build-up under coverings; prevent corrosion and adverse effects on factory applied painted finish.

## **PART 2 PRODUCTS**

### **2.01 MANUFACTURERS**

- A. Hollow Metal Doors and Frames:
  - 1. Ceco Door, an Assa Abloy Group company; \_\_\_\_\_: [www.assaabloydss.com/#sle](http://www.assaabloydss.com/#sle).
  - 2. Premier Steel Doors and Frames; F Series Commercial Frames: [www.trustpremier.com/#sle](http://www.trustpremier.com/#sle).
  - 3. Steelcraft, an Allegion brand: [www.allegion.com/us](http://www.allegion.com/us).
  - 4. Substitutions: See Section 01 6000 - Product Requirements.

### **2.02 PERFORMANCE REQUIREMENTS**

- A. Requirements for Hollow Metal Doors and Frames:
  - 1. Steel Sheet: Comply with one or more of the following requirements; galvanized steel complying with ASTM A653/A653M, cold-rolled steel complying with ASTM A1008/A1008M, or hot-rolled pickled and oiled (HRPO) steel complying with ASTM A1011/A1011M, commercial steel (CS) Type B, for each.
  - 2. Accessibility: Comply with ICC A117.1 and ADA Standards.
  - 3. Exterior Door Top Closures: Flush end closure channel, with top and door faces aligned.
  - 4. Typical Door Face Sheets: Flush.
  - 5. Glazed Lights: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings. Style: Manufacturer's standard.
  - 6. Hardware Preparations, Selections and Locations: Comply with NAAMM HMMA 830 and NAAMM HMMA 831 or BHMA A156.115 and ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
  - 7. Zinc Coating for Typical Interior and/or Exterior Locations: Provide metal components zinc-coated (galvanized) and/or zinc-iron alloy-coated (galvanized) by the hot-dip process in accordance with ASTM A653/A653M, with manufacturer's standard coating thickness, unless noted otherwise for specific hollow metal doors and frames.
    - a. Based on NAAMM HMMA Custom Guidelines: Provide at least A25/ZF75 (galvanized) for interior applications, and at least A60/ZF180 (galvanized) or G60/Z180 (galvanized) for corrosive locations.
- B. Combined Requirements: If a particular door and frame unit is indicated to comply with more than one type of requirement, comply with the specified requirements for each type; for instance, an exterior door that is also indicated as being sound-rated must comply with the requirements specified for exterior doors and for sound-rated doors; where two requirements conflict, comply with the most stringent.

### **2.03 HOLLOW METAL DOORS**

- A. Door Finish: Factory primed and field finished.
- B. Exterior Doors: Thermally insulated.
  - 1. Based on NAAMM HMMA Custom Guidelines:
    - a. Comply with guidelines of {rs#1} for Hollow Metal Doors and Frames.
    - b. Performance Level 3 - Heavy Duty, in accordance with NAAMM HMMA 805.
    - c. Physical Performance Level A, 1,000,000 cycles; in accordance with ANSI/SDI A250.4.
    - d. Door Face Metal Thickness: 16 gage, 0.053 inch (1.3 mm), minimum.

- e. Zinc Coating: A60/ZF180 (galvannealed) or G60/Z180 (galvanized).; ASTM A653/A653M.
- 2. Door Thermal Resistance: R-Value of 6.0 minimum, for installed thickness of polystyrene.
- 3. Door Thickness: 1-3/4 inches (44.5 mm), nominal.
- 4. Door Finish: Factory primed and field finished.
- C. Interior Doors, Non-Fire Rated:
  - 1. Based on NAAMM HMMA Custom Guidelines:
    - a. Comply with guidelines of {\rs\#1} for Commercial Hollow Metal Doors and Frames.
    - b. Performance Level 3 - Heavy Duty, in accordance with NAAMM HMMA 805.
    - c. Physical Performance Level A, 1,000,000 cycles; in accordance with ANSI/SDI A250.4.
    - d. Door Face Metal Thickness: 16 gage, 0.053 inch (1.3 mm), minimum.
  - 2. Door Core Material: Manufacturers standard core material/construction and in compliance with requirements.
  - 3. Door Thickness: 1-3/4 inches (44.5 mm), nominal.
  - 4. Door Finish: Factory primed and field finished.

## **2.04 HOLLOW METAL FRAMES**

- A. Comply with standards and/or custom guidelines as indicated for corresponding door in accordance with applicable door frame requirements.
- B. Frame Finish: Factory primed and field finished.
- C. Exterior Door Frames: Full profile/continuously welded type.
  - 1. Weatherstripping: Separate, see Section 08 7100.
- D. Interior Door Frames, Non-Fire Rated: Face welded type.

## **2.05 FINISHES**

- A. Primer: Rust-inhibiting, complying with ANSI/SDI A250.10, door manufacturer's standard.

## **2.06 ACCESSORIES**

- A. Silencers: Resilient rubber, fitted into drilled hole; provide three on strike side of single door, three on center mullion of pairs, and two on head of pairs without center mullions.
- B. Temporary Frame Spreaders: Provide for factory- or shop-assembled frames.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Verify that finished walls are in plane to ensure proper door alignment.

### **3.02 INSTALLATION**

- A. Install doors and frames in accordance with manufacturer's instructions and related requirements of specified door and frame standards or custom guidelines indicated.
- B. Coordinate frame anchor placement with wall construction.
- C. Install door hardware as specified in Section 08 7100.

### **3.03 ADJUSTING**

- A. Adjust for smooth and balanced door movement.

### **3.04 SCHEDULE**

- A. Refer to Door and Frame Schedule on the drawings.

## **END OF SECTION**

This page intentionally left blank

**SECTION 08 3100  
ACCESS DOORS AND PANELS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Wall- and ceiling-mounted access units.

**1.02 SUBMITTALS**

- A. See Section 01 3000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide sizes, types, finishes, hardware, scheduled locations, and details of adjoining work.
- C. Project Record Documents: Record actual locations of each access unit.

**1.03 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

**PART 2 PRODUCTS**

**2.01 ACCESS DOORS AND PANELS ASSEMBLIES**

- A. Typical Units, unless noted or specified otherwise:
  - 1. Location: Where indicated on drawings and required access to concealed devices.
  - 2. Panel Material: Aluminum extrusions with gypsum board inlay.
  - 3. Steel Finish: Powder Coat.
  - 4. Size: 12 inch by 12 inch (305 mm by 305 mm), unless otherwise required.
  - 5. Gypsum Board Mounting Criteria: Provide drywall bead frame with door surface flush with wall surface.
- B. Recessed Units, to receive gypsum wall board or plaster:
  - 1. Material: Steel.
  - 2. Steel Finish: Powder Coat.
  - 3. Size: 12 x 12 inches (300 x 300 mm), unless otherwise required.
  - 4. In Gypsum Board: Drywall bead frame with door surface recessed for infill with wall finish.
  - 5. In Plaster: Plaster bead frame with door surface recessed for infill with plaster.
- C. Units in public (visible) areas to receive tiles:
  - 1. Material: Stainless steel, Type 304.
  - 2. Finish: 4 satin polish finish.
  - 3. Size: 12 x 12 inches (300 x 300 mm), unless otherwise indicated.
- D. Units in Wet Areas exposed to view:
  - 1. Location: Where required..
  - 2. Material: Steel, hot-dipped zinc or zinc-aluminum-alloy coated.
  - 3. Finish: Powder Coat.
  - 4. Gypsum Board Mounting Criteria: Provide drywall bead frame with door surface flush with wall surface.

**2.02 WALL- AND CEILING-MOUNTED ACCESS UNITS**

- A. Manufacturers:
  - 1. ACUDOR Products Inc: [www.acudor.com/#sle](http://www.acudor.com/#sle).
  - 2. Babcock-Davis: [www.babcockdavis.com/sle](http://www.babcockdavis.com/sle).
  - 3. Cendrex, Inc: [www.cendrex.com/#sle](http://www.cendrex.com/#sle).
  - 4. Karp Associates, Inc: [www.karpinc.com](http://www.karpinc.com).
  - 5. Nystrom, Inc: [www.nystrom.com/sle](http://www.nystrom.com/sle).
  - 6. J. L. Industries, Inc., a division of Activar Construction Products Group: [www.activarcpg.com](http://www.activarcpg.com).

- B. Wall- and Ceiling-Mounted Units: Factory-fabricated door and frame, fully assembled units with corner joints welded, filled and ground flush; square and without rack or warp; coordinate requirements with type of installation assembly being used for each unit.
  - 1. Door Style: Single thickness with rolled or turned in edges.
  - 2. Frames: 16-gauge, 0.0598-inch (1.52 mm) minimum thickness.
  - 3. Heavy-Duty Single Steel Sheet Door Panels: 14-gauge, 0.0747-inch (1.89 mm) minimum thickness.
  - 4. Hardware:
    - a. Hinges for Non-Fire-Rated Units: Continuous piano hinge.
    - b. Lock(s) for non-public areas: Screw driver slot for quarter turn cam lock.
    - c. Latch/Lock for public areas: Tamperproof tool-operated cam latch, non-screwdriver operated.
    - d. Lock(s) for secure areas: Cylinder lock with latch, two keys for each unit.

### **PART 3 EXECUTION**

#### **3.01 EXAMINATION**

- A. Verify that rough openings are correctly sized and located.

#### **3.02 INSTALLATION**

- A. Install units in accordance with manufacturer's instructions.
- B. Install frames plumb and level in openings, and secure units rigidly in place.
- C. Position units to provide convenient access to concealed equipment when necessary.

**END OF SECTION**

**SECTION 08 3313  
COILING COUNTER DOORS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Non-fire-rated coiling counter doors and operating hardware.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 9200 - Joint Sealants: Sealing joints between frames and adjacent construction.

**1.03 REFERENCE STANDARDS**

- A. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2019.
- B. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- C. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- D. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric); 2021.

**1.04 SUBMITTALS**

- A. See Section 01 3000 - Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturer's standard literature showing materials and details of construction and finish.
- C. Shop Drawings: Indicate rough and actual opening dimensions, anchorage methods, hardware locations, and installation details.
- D. Operation and Maintenance Data: Indicate modes of operation, lubrication requirements and frequency, and periodic adjustments required.

**1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.

**1.06 WARRANTY**

- A. See Section 01 7800 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 2-year manufacturer warranty for counterbalance shaft assembly. Complete forms in Owner's name and register with manufacturer.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. Coiling Counter Doors:
  - 1. Cornell Iron Works, Inc: [www.cornelliron.com](http://www.cornelliron.com).
  - 2. The Cookson Company: [www.cooksondoor.com](http://www.cooksondoor.com).
  - 3. Overhead Door Corp.: [www.overheaddoor.com](http://www.overheaddoor.com).
  - 4. McKeon Rolling Steel Door Company, Inc.: [www.mckeondoor.com](http://www.mckeondoor.com).
  - 5. Raynor; Product DuraCoil Standard: [www.raynor.com](http://www.raynor.com).
  - 6. Substitutions: See Section 01 6000 - Product Requirements.

**2.02 COILING COUNTER DOORS**

- A. Coiling Counter Metal Doors, Non-Fire-Rated: factory primed, painted steel slat curtain.
  - 1. Basis of Design: Overhead Door Corporation; Model 652.
  - 2. Mounting: Interior face mounted.
  - 3. Nominal Slat Size: 1-1/4 inches (32 mm) wide.
  - 4. Slat Profile: Flat.

5. Finish, Steel: Factory primed.
6. Color: As selected by Architect from manufacturer's full range.
7. Guides: Formed track; same material and finish unless otherwise indicated.
8. Hood Enclosure: Manufacturer's standard; aluminum.
9. Manual hand chain lift operation.
10. Locking Devices: Slide bolt on inside.

### **2.03 COMPONENTS**

- A. Metal Curtain Construction: Interlocking, single-thickness slats.
  1. Slat Ends: Each slat fitted with end locks to act as wearing surface in guides and to prevent lateral movement.
  2. Curtain Bottom: Fitted with angles to provide reinforcement and positive contact in closed position.
  3. Steel Slats: ASTM A653/A653M galvanized steel sheet, with minimum G90/Z275 coating; minimum thickness 16 gauge, 0.06 inch (1.5 mm).
- B. Guide Construction: Continuous, of profile to retain door in place, with mounting brackets of same metal.
  1. Guides for Galvanized Curtains: ASTM A36/A36M steel angles, size as indicated, hot-dip galvanized per ASTM A123/A123M.
- C. Hood Enclosure: Internally reinforced to maintain rigidity and shape.
- D. Lock Hardware:
- E. Slide Bolt: Provide on single-jamb side, extending into slot in guides, with padlock on one side.
- F. Roller Shaft Counterbalance: Steel pipe and torsion steel spring system, capable of producing torque sufficient to ensure smooth operation of curtain from any position and capable of holding position at mid-travel; with adjustable spring tension; requiring 25 lb (10 kg) nominal force to operate.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that adjacent construction is suitable for door installation.
- B. Verify that electrical services have been installed and are accessible.
- C. Verify that door opening is plumb, header is level, and dimensions are correct.
- D. Notify Architect of any unacceptable conditions or varying dimensions.
- E. Commencement of installation indicates acceptance of substrate and door opening conditions.

### **3.02 INSTALLATION**

- A. Install units in accordance with manufacturer's instructions.
- B. Use anchorage devices to securely fasten assembly to wall construction and building framing without distortion or stress.
- C. Securely and rigidly brace components suspended from structure.
- D. Fit and align assembly including hardware; level and plumb, to provide smooth operation.

### **3.03 TOLERANCES**

- A. Maintain dimensional tolerances and alignment with adjacent work.
- B. Maximum Variation From Plumb: 1/16 inch (1.5 mm).
- C. Maximum Variation From Level: 1/16 inch (1.5 mm).
- D. Longitudinal or Diagonal Warp: Plus or minus 1/8 inch per 10 ft (3 mm per 3 m) straight edge.

### **3.04 ADJUSTING**

- A. Adjust operating assemblies for smooth and noiseless operation.

### **3.05 CLEANING**

- A. Clean installed components.
- B. Remove labels and visible markings.

**END OF SECTION**

This page intentionally left blank

**SECTION 08 3323  
OVERHEAD COILING DOORS**

**PART 1 GENERAL**

**1.01 SECTION INCLUDES**

- A. Exterior coiling doors.

**1.02 RELATED REQUIREMENTS**

- A. Section 07 9200 - Joint Sealants: Sealing joints between frames and adjacent construction.
- B. Section 08 7100 - Door Hardware: Cylinder cores and keys.
- C. Section 09 9113 - EXTERIOR PAINTING: Field paint finish.
- D. Section 09 9123 - INTERIOR PAINTING: Field paint finish.

**1.03 REFERENCE STANDARDS**

- A. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2019.
- B. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- C. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.

**1.04 SUBMITTALS**

- A. See Section 01 3000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide for each type and size of overhead coiling door and accessory.
- C. Shop Drawings: Indicate pertinent dimensioning, anchorage methods, hardware locations, and installation details.
- D. Maintenance Data: Indicate lubrication requirements and frequency and periodic adjustments required.
- E. Warranty: Submit manufacturer warranty and ensure forms have been completed in Owner's name and registered with manufacturer.

**1.05 WARRANTY**

- A. See Section 01 7800 - Closeout Submittals for warranty requirements.
- B. Correct defective Work within a five year period after Date of Substantial Completion.
- C. Provide five year manufacturer warranty for electric operating equipment.

**PART 2 PRODUCTS**

**2.01 MANUFACTURERS**

- A. Overhead Coiling Doors:
  - 1. Alpine Overhead Doors, Inc: [www.alpinedoors.com](http://www.alpinedoors.com).
  - 2. Clopay Building Products; Model CERD20: [www.clopaydoor.com/#sle](http://www.clopaydoor.com/#sle).
  - 3. Cornell Iron Works, Inc: [www.cornelliron.com](http://www.cornelliron.com).
  - 4. The Cookson Company; \_\_\_\_: [www.cooksondoor.com/#sle](http://www.cooksondoor.com/#sle).
  - 5. Wayne-Dalton, a Division of Overhead Door Corporation: [www.wayne-dalton.com/#sle](http://www.wayne-dalton.com/#sle).
  - 6. Overhead Door Corp.: [www.overheaddoor.com](http://www.overheaddoor.com).
  - 7. McKeon Rolling Steel Door Company, Inc.: [www.mckeondoor.com](http://www.mckeondoor.com).
  - 8. \_\_\_\_\_.

**2.02 COILING DOORS**

- A. Exterior Coiling Doors Type flat: Steel slat curtain.
  - 1. Basis of Design: Overhead Door Corporation; Model 653.

2. Capable of withstanding positive and negative wind loads of 20 psf (940 Pa) without undue deflection or damage to components.
3. Sandwich slat construction with insulated core of foamed-in-place polyurethane insulation; minimum R-value of R-29.
4. Nominal Slat Size: 2 inches (50 mm) wide by required length.
5. Finish: Factory finish..
6. Guide, Angles: Galvanized steel.
7. Hood Enclosure: Manufacturer's standard; primed steel.
8. Manual hand chain lift operation.
9. Mounting: Within framed opening.
10. Padlockable slide bolt on coil side of bottom bar at each jamb extending into slots in guides.

### **2.03 MATERIALS AND COMPONENTS**

- A. Metal Curtain Construction: Interlocking slats.
  1. Slat Ends: Each slat fitted with end locks to act as wearing surface in guides and to prevent lateral movement.
  2. Curtain Bottom for Slat Curtains: Fitted with angles to provide reinforcement and positive contact in closed position.
  3. Weatherstripping for Exterior Doors: Moisture and rot proof, resilient type, located at jamb edges, bottom of curtain, and where curtain enters hood enclosure of exterior doors.
  4. Steel Slats: Minimum thickness, 20 gauge, 1-7/8 inch (\_\_\_\_ mm); ASTM A653/A653M galvanized steel sheet.
- B. Guide Construction: Continuous, of profile to retain door in place, mounting brackets of same metal.
- C. Guides - Angle: ASTM A36/A36M metal angles, size as indicated.
  1. Hot-dip galvanized in compliance with ASTM A123/A123M.
- D. Hood Enclosure and Trim: Internally reinforced to maintain rigidity and shape.

## **PART 3 EXECUTION**

### **3.01 EXAMINATION**

- A. Verify that adjacent construction is suitable for door installation.
- B. Verify that electrical services have been installed and are accessible.
- C. Verify that door opening is plumb, header is level, and dimensions are correct.
- D. Notify Architect of any unacceptable conditions or varying dimensions.
- E. Commencement of installation indicates acceptance of substrate and door opening conditions.

### **3.02 INSTALLATION**

- A. Install units in accordance with manufacturer's instructions.
- B. Use anchorage devices to securely fasten assembly to wall construction and building framing without distortion or stress.
- C. Securely and rigidly brace components suspended from structure. Secure guides to structural members only.
- D. Fit and align assembly including hardware; level and plumb, to provide smooth operation.
- E. Install enclosure and perimeter trim.

### **3.03 TOLERANCES**

- A. Maintain dimensional tolerances and alignment with adjacent work.
- B. Maximum Variation From Plumb: 1/16 inch (1.6 mm).
- C. Maximum Variation From Level: 1/16 inch (1.6 mm).

- D. Longitudinal or Diagonal Warp: Plus or minus 1/8 inch per 10 feet (3.2 mm per 3 m) straight edge.

#### **3.04 ADJUSTING**

- A. Adjust operating assemblies for smooth and noiseless operation.

#### **3.05 CLEANING**

- A. Clean installed components.
- B. Remove labels and visible markings.

**END OF SECTION**

This page intentionally left blank