

**SECTION 10 1100
VISUAL DISPLAY UNITS**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Porcelain enamel steel markerboards.

1.02 REFERENCE STANDARDS

- A. ANSI A208.1 - American National Standard for Particleboard; 2022.
- B. ASTM A424/A424M - Standard Specification for Steel, Sheet, for Porcelain Enameling; 2018.

1.03 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's data on markerboard, trim, and accessories.
- C. Maintenance Data: Include data on regular cleaning, stain removal .

1.04 WARRANTY

- A. See Section 01 7800 - Closeout Submittals, for additional warranty requirements.
- B. Provide five year warranty for markerboard to include warranty against discoloration due to cleaning, crazing or cracking, and staining.

PART 2 PRODUCTS

2.01 VISUAL DISPLAY UNITS

- A. Porcelain Enamel Steel Markerboards:
 - 1. Color: White.
 - 2. Steel Face Sheet Thickness: 24 gauge, 0.0239 inch (0.61 mm).
 - 3. Core: Particleboard, manufacturer's standard thickness, laminated to face sheet.
 - 4. Backing: Aluminum foil, laminated to core.
 - 5. Size: As indicated on drawings.
 - 6. Frame: Extruded aluminum , with concealed fasteners.
 - 7. Frame Finish: Anodized, natural.
 - 8. Accessories: Provide marker tray and map rail.
- B. Units Made of More Than One Panel: Factory-assembled outdoor enclosed aluminum directory board in a single frame, of materials specified above.
 - 1. Manufacturers:
 - a. Basis of design: Aarco Products, Inc.; OADC3672-3H: WWW.aarcoproducts.com.
 - b. Length: 6 feet (1830 mm) , in one piece.
 - c. Frame: Extruded aluminum, with concealed fasteners.
 - d. Frame Finish: Anodized, natural.

2.02 MATERIALS

- A. Porcelain Enameled Steel Sheet: ASTM A424/A424M, Type I, Commercial Steel, with fired-on vitreous finish.
- B. Particleboard: ANSI A208.1; wood chips, set with waterproof resin binder, sanded faces.
- C. Foil Backing: Aluminum foil sheet, 0.005 inch thick (0.13 mm thick).

2.03 ACCESSORIES

- A. Map Rail: Extruded aluminum, manufacturer's standard profile, with cork insert and runners for accessories; 1 inch wide overall (; 25 mm wide overall) , full width of frame.
- B. Marker Tray: Aluminum, manufacturer's standard profile, one piece full length of markerboard, molded ends, concealed fasteners, same finish as frame.
- C. Mounting Brackets: Concealed.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that internal wall blocking is ready to receive work and positioning dimensions are as instructed by the manufacturer.

3.02 INSTALLATION

- A. Install boards in accordance with manufacturer's instructions.
- B. Install with top of chalk tray at 30 inches (760 mm) above finished floor unless noted otherwise.
- C. Secure units level and plumb.

3.03 CLEANING

- A. Clean board surfaces in accordance with manufacturer's instructions.

END OF SECTION

SECTION 10 1423 PANEL SIGNAGE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Panel signage.

1.02 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design; 2010.
- B. ICC A117.1 - Accessible and Usable Buildings and Facilities; 2017.

1.03 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's product literature for each type of panel sign, indicating styles, font, foreground and background colors, locations, and overall dimensions of each sign.
- C. Shop Drawings:
 - 1. Include dimensions, locations, elevations, materials, text and graphic layout, attachment details, and schedules.
 - 2. Schedule: Provide information sufficient to completely define each panel sign for fabrication, including room number, room name, other text to be applied, sign and letter sizes, fonts, and colors.
 - a. When room numbers to appear on signs differ from those on drawings, include the drawing room number on schedule.
 - b. When content of signs is indicated to be determined later, request such information from Owner through Architect at least 2 months prior to start of fabrication; upon request, submit preliminary schedule.
 - c. Submit for approval by Owner through Architect prior to fabrication.
- D. Manufacturer's qualification statement.

1.04 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.

PART 2 PRODUCTS

2.01 MANUFACTURERS

2.02 REGULATORY REQUIREMENTS

- A. Accessibility Requirements: Comply with ADA Standards and ICC A117.1 and applicable building codes, unless otherwise indicated; in the event of conflicting requirements, comply with the most restrictive requirements.

2.03 PANEL SIGNAGE

- A. Panel Signage Type A:
 - 1. Application: Room and door signs.
 - 2. Description: Flat signs with engraved panel media, tactile characters.
 - 3. Sign Size: 4 inches by 6 inches (100 mm by 152 mm).
 - 4. Total Thickness: 1/8 inch (3 mm).
 - 5. Color and Font, unless otherwise indicated:
 - a. Character Font: Helvetica, Arial, or other sans serif font.
 - b. Character Case: Upper and lower case (title case).
 - c. Background Color: As scheduled.
 - d. Character Color: Contrasting color.
 - 6. Material: Laminated colored plastic engraved through face to expose core as background color.

7. Profile: Flat panel in aluminum frame.
 - a. Frame Finish: Black anodized.
8. Tactile Letters: Raised 1/32 inch minimum.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that substrate surfaces are ready to receive work.
- B. Notify Architect if conditions are not suitable for installation of signs; do not proceed until conditions are satisfactory.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install with horizontal edges level.
- C. Locate panel signs and mount at heights indicated on drawings and in accordance with ADA Standards and ICC A117.1.
- D. Protect from damage until 11-05-2025; repair or replace damaged items.

END OF SECTION

**SECTION 10 2113.13
METAL TOILET COMPARTMENTS**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal toilet compartments.
- B. Urinal screens.

1.02 REFERENCE STANDARDS

- A. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- B. ASTM A666/A666M - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2024.

1.03 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements, for submittal procedures.
- B. Shop Drawings: Indicate partition plan, elevation views, dimensions, details of wall supports, door swings.
- C. Product Data: Provide data on panel construction, hardware, and accessories.
- D. Samples: Submit two samples of partition panels, ____x____ inch (____x____ mm) in size illustrating panel finish, color, and sheen.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Metal Toilet Compartments:
 - 1. Ampco Products, Inc: www.ampco.com.
 - 2. ASI Global Partitions; Stainless Steel: www.asi-globalpartitions.com/#sle.
 - 3. Metpar Corp: www.metpar.com/#sle.
 - 4. Sanymetal, A Crane Plumbing Company: www.sanymetal.com.

2.02 MATERIALS

- A. Steel Sheet: Hot-dipped galvanized steel sheet, ASTM A653/A653M, with G90/Z275 coating.

2.03 COMPONENTS

- A. Toilet Compartments: Powder coated steel, floor-mounted headrail-braced.
- B. Doors, Panels, and Pilasters: Sheet steel faces, pressure bonded to sound deadening core, formed and closed edges; corners made with corner clips or mitered, welded, and ground smooth.
 - 1. Panel Faces: 20 gauge, 0.0359 inch (0.91 mm).
 - 2. Door Faces: 22 gauge, 0.0299 inch (0.76 mm).
 - 3. Pilaster Faces: 20 gauge, 0.0359 inch (0.91 mm).
 - 4. Reinforcement: 12 gauge, 0.1046 inch (2.66 mm).
 - 5. Internal Reinforcement: Provide in areas of attached hardware and fittings. Mark locations of reinforcement for partition mounted washroom accessories.
- C. Door and Panel Dimensions:
 - 1. Thickness: 1 inch (25 mm).
 - 2. Door Width: 24 inch (610 mm).
 - 3. Door Width for Handicapped Use: 36 inch (915 mm) , out-swinging.
 - 4. Height: 58 inch (1473 mm).
- D. Pilasters: 1-1/4 inch (32 mm) thick, of sizes required to suit compartment width and spacing.
- E. Urinal Screens: Wall mounted with continuous panel brackets.

2.04 ACCESSORIES

- A. Pilaster Shoes: Formed ASTM A666 Type 304 stainless steel with No. 4 finish, 3 inch (175 mm) high, concealing floor fastenings.
 - 1. Provide adjustment for floor variations with screw jack through steel saddles integral with pilaster.
- B. Head Rails: Hollow chrome-plated steel tube, 1 by 1-5/8 inch (25 by 41 mm) size, with anti-grip strips and cast socket wall brackets.
- C. Brackets: Polished chrome-plated non-ferrous cast metal.
- D. Attachments, Screws, and Bolts: Stainless steel , tamper proof type.
 - 1. For attaching panels and pilasters to brackets: Through-bolts and nuts ; tamper proof.
- E. Hardware: Polished chrome plated non-ferrous cast metal:
 - 1. Pivot hinges, gravity type, adjustable for door close positioning; two per door.
 - 2.
 - 3. Thumb turn or sliding door latch with exterior emergency access feature.
 - 4. Door strike and keeper with rubber bumper; mounted on pilaster in alignment with door latch.
 - 5. Coat hook with rubber bumper; one per compartment, mounted on door.
 - 6. Provide door pull for outswinging doors.

2.05 FINISHING

- A. Powder Coated Steel Compartments: Clean, degrease, and neutralize. Follow immediately with a phosphatizing treatment, prime coat and two finish coats powder coat enamel.
- B. Color: Single color as selected.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that field measurements are as indicated.
- C. Verify correct spacing of and between plumbing fixtures.
- D. Verify correct location of built-in framing, anchorage, and bracing.

3.02 INSTALLATION

- A. Install partitions secure, rigid, plumb, and level in accordance with manufacturer's instructions.
- B. Maintain 3/8 to 1/2 inch (9 to 13 mm) space between wall and panels and between wall and end pilasters.
- C. Attach panel brackets securely to walls using anchor devices.
- D. Attach panels and pilasters to brackets. Locate head rail joints at pilaster center lines.

3.03 TOLERANCES

- A. Maximum Variation From True Position: 1/4 inch (6 mm).
- B. Maximum Variation From Plumb: 1/8 inch (3 mm).

3.04 ADJUSTING

- A. Adjust and align hardware to uniform clearance at vertical edge of doors, not exceeding 3/16 inch (5 mm).
- B. Adjust hinges to position doors in partial opening position when unlatched. Return out swinging doors to closed position.

END OF SECTION

**SECTION 10 2600
WALL AND DOOR PROTECTION**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Corner guards.

1.02 REFERENCE STANDARDS

- A. ASTM D256 - Standard Test Methods for Determining the Izod Pendulum Impact Resistance of Plastics; 2023, with Editorial Revision.
- B. ASTM F476 - Standard Test Methods for Security of Swinging Door Assemblies; 2023.

1.03 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements for submittal procedures.
- B. Product Data: Indicate physical dimensions, features, wall mounting brackets with mounted measurements, anchorage details, and rough-in measurements.
- C. Samples: Submit samples illustrating component design, configurations, joinery, color and finish.
 - 1. Submit two sections of corner guards, bumper rails, and protective corridor handrails, 24 inches (610 mm) long.
- D. Maintenance Materials: Furnish the following for Owner's use in maintenance of project:
 - 1. See Section 01 6000 - Product Requirements, for additional provisions.
 - 2. Extra Stock Materials: One package(s) of minimum 96 inches (2438 mm) long unit of each kind of covers for corner guards and bumper rails.
- E. Maintenance Data: Manufacturer's instructions for care and cleaning of each type of product. Include information about both recommended and potentially detrimental cleaning materials and methods.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Deliver wall and door protection items in original, undamaged protective packaging. Label items to designate installation locations.
- B. Protect work from moisture damage.
- C. Protect work from UV light damage.
- D. Do not deliver products to project site until areas for storage and installation are fully enclosed, and interior temperature and humidity are in compliance with manufacturer's recommendations for each type of item.
- E. Store products in either horizontal or vertical position, in compliance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 PERFORMANCE CRITERIA

- A. Impact Strength: Unless otherwise noted, provide protection products and assemblies that have been successfully tested for compliance with applicable provisions of ASTM D256 and/or ASTM F476.

2.02 PRODUCT TYPES

- A. Corner Guards - Surface Mounted:
 - 1. Material: High impact vinyl with full height extruded aluminum retainer.
 - 2. Width of Wings: 2 inches (51 mm).
 - 3. Corner: Radiused.
 - 4. Color: As selected from manufacturer's standard colors.
 - 5. Length: One piece.

2.03 FABRICATION

- A. Fabricate components with tight joints, corners and seams.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that rough openings, concealed blocking, and anchors are correctly sized and located.
- B. Verify that substrate surfaces for adhered items are clean and smooth.

3.02 INSTALLATION

- A. Install components in accordance with manufacturer's instructions, level and plumb, secured rigidly in position to supporting construction.
- B. Position corner guard 4 inches (102 mm) above finished floor to 74 inches high (____ mm high).

3.03 TOLERANCES

- A. Maximum Variation From Required Height: 1/4 inch (6 mm).
- B. Maximum Variation From Level or Plane For Visible Length: 1/4 inch (6 mm).

3.04 CLEANING

- A. Clean wall and door protection items of excess adhesive, dust, dirt, and other contaminants.

END OF SECTION

**SECTION 10 2800
TOILET, BATH, AND LAUNDRY ACCESSORIES**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Commercial shower and bath accessories.
- B. Under-lavatory pipe supply covers.
- C. Diaper changing stations.
- D. Utility room accessories.

1.02 RELATED REQUIREMENTS

- A. Section 09 2116 - Gypsum Board Assemblies: Concealed supports for accessories, including in wall framing and plates.

1.03 REFERENCE STANDARDS

- A. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- B. ASTM A269/A269M - Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service; 2022.
- C. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- D. ASTM A666/A666M - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2024.
- E. ASTM B456 - Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium; 2017 (Reapproved 2022).
- F. ASTM C1036 - Standard Specification for Flat Glass; 2021.
- G. ASTM C1048 - Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass; 2018.
- H. ASTM F2285 - Standard Consumer Safety Performance Specification for Diaper Changing Tables for Commercial Use; 2022.

1.04 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Submit data on accessories describing size, finish, details of function, and attachment methods.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Commercial Toilet, Shower, and Bath Accessories:
 - 1. ASI - American Specialties, Inc: www.americanspecialties.com.
 - 2. Bradley Corporation: www.bradleycorp.com.
 - 3. Georgia-Pacific Professional; _____: www.gppro.com/#sle.
 - 4. Substitutions: Section 01 6000 - Product Requirements.

2.02 MATERIALS

- A. Accessories - General: Shop assembled, free of dents and scratches and packaged complete with anchors and fittings, steel anchor plates, adapters, and anchor components for installation.
- B. Keys: Provide 4 keys for each accessory to Architect; master key lockable accessories.
- C. Stainless Steel Sheet: ASTM A666/A666M.

- D. Stainless Steel Tubing: ASTM A269/A269M, Grade TP304 or TP316.
- E. Galvanized Sheet Steel: Hot-dipped galvanized steel sheet, ASTM A653/A653M, with G90/Z275 coating.
- F. Mirror Glass: Tempered safety glass, ASTM C1048; and ASTM C1036 Type I, Class 1, Quality Q2, with silvering as required.
- G. Fasteners, Screws, and Bolts: Hot dip galvanized; tamper-proof; security type.
- H. Expansion Shields: Fiber, lead, or rubber as recommended by accessory manufacturer for component and substrate.

2.03 FINISHES

- A. Stainless Steel: No. 4 Brushed finish.
- B. Chrome/Nickel Plating: ASTM B456, SC 2, satin finish.
- C. Galvanizing for Items Other than Sheet: Comply with ASTM A123/A123M; galvanize ferrous metal and fastening devices.
- D. Shop Primed Ferrous Metals: Pretreat and clean, spray apply one coat primer and bake.
- E. Back paint components where contact is made with building finishes to prevent electrolysis.

2.04 COMMERCIAL TOILET ACCESSORIES

- A. See accessories schedule on drawings.
- B. Waste Receptacle: Recessed, stainless steel, seamless lower door for access to container, with tumbler lock, reinforced panel full height of door, push-in self-closing top door, continuously welded bottom pan and seamless exposed flanges.
 - 1. Liner: Removable seamless stainless steel receptacle.
 - 2. Minimum capacity: 4 gallons (15 liters).
- C. Mirrors: Stainless steel framed, 1/4 inch (6 mm) thick tempered safety glass; ASTM C1048.
 - 1. Size: 24" x 36".
 - 2. Frame: 0.05 inch (1.3 mm) angle shapes, with mitered and welded and ground corners, and tamperproof hanging system; satin finish.
- D. Grab Bars: Stainless steel, nonslip grasping surface finish.
 - 1. Standard Duty Grab Bars:
 - a. Push/Pull Point Load: 250 pound-force (1112 N), minimum.
 - b. Dimensions: 1-1/4 inch (32 mm) outside diameter, minimum 0.05 inch (1.3 mm) wall thickness, exposed flange mounting, 1-1/2 inch (38 mm) clearance between wall and inside of grab bar.
 - c. Finish: Satin.
 - 2. Heavy Duty Grab Bars: Floor supports are acceptable if necessary to achieve load rating.
 - a. Push/Pull Point Load: Minimum 1000 pound-force (4448.2 N), minimum.
 - b. Dimensions: 1-1/2 inch (38 mm) outside diameter, minimum 0.125 inch (3.17 mm) wall thickness, exposed flange mounting, 1-1/2 inch (38 mm) clearance between wall and inside of grab bar.
- E. Sanitary Napkin Disposal Unit: Stainless steel, surface-mounted, self-closing door, locking bottom panel with full-length stainless steel piano-type hinge, removable receptacle.

2.05 UNDER-LAVATORY PIPE AND SUPPLY COVERS

- A. Under-Lavatory Pipe and Supply Covers:

2.06 DIAPER CHANGING STATIONS

- A. Diaper Changing Station: Wall-mounted folding diaper changing station for use in commercial toilet facilities, meeting or exceeding ASTM F2285.
 - 1. Material: Polyethylene.

2. Mounting: Surface.
3. Color: Gray.
4. Minimum Rated Load: 250 pounds (113.4 kg).

2.07 UTILITY ROOM ACCESSORIES

- A. Combination Utility Shelf/Mop and Broom Holder: 0.05 inch (1.3 mm) thick stainless steel, Type 304, with 1/2 inch (12 mm) returned edges, 0.06 inch (1.6 mm) steel wall brackets.
 1. Hooks: Four, 0.06 inch (1.6 mm) stainless steel rag hooks at shelf front.
 2. Mop/broom holders: Three spring-loaded rubber cam holders at shelf front.
 3. Length: 36 inches (900 mm).
 4. Products:
 - a. American Specialties, Inc; #1308-3: www.americanspecialties.com/#sle.
 - b. Substitutions: 01 6000 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify exact location of accessories for installation.
- C. Verify blocking and backing in walls is installed in accordance with manufactures instructions.

3.02 PREPARATION

- A. Deliver inserts and rough-in frames to site for timely installation.
- B. Provide templates and rough-in measurements as required.

3.03 INSTALLATION

- A. Install accessories in accordance with manufacturers' instructions in locations indicated on drawings.
- B. Install plumb and level, securely and rigidly anchored to substrate.
- C. Mounting Heights: As required by accessibility regulations, unless otherwise indicated.

END OF SECTION

This page intentionally left blank

SECTION 10 7500 FLAGPOLES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Aluminum Flagpoles.

1.02 REFERENCE STANDARDS

- A. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes; 2021.
- B. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric); 2021.
- C. NAAMM FP 1001 - Guide Specifications for Design Loads of Metal Flagpoles; 2007.

1.03 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on pole, accessories, and configurations.
- C. Shop Drawings: Indicate detailed dimensions, base details, anchor requirements, and imposed loads.
- D. Maintenance Data: Provide lubrication and periodic maintenance requirement schedules and instructions.

1.04 QUALITY ASSURANCE

- A. Designer Qualifications: Design flagpole foundation under direct supervision of a Professional Structural Engineer experienced in design of this Work and licensed Nevada.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Spiral wrap flagpole with protective covering and pack in protective shipping tubes or containers.
- B. Protect flagpole and accessories from damage or moisture.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Flagpoles:
 - 1. Acme Flagpoles Company, Division of Lingo, Inc.: www.lingoinc.com
 - 2. Concord Industries, Inc: www.concordindustries.com.
 - 3. Ewing Flagpoles: www.ewingflagpole.com.
 - 4. Morgan-Francis: www.morgan-francis.com.
 - 5. National Flag and Flagpoles: nationalflagandflagpole.com
 - 6. Pole-Tech Co, Inc: www.poletech.com.

2.02 FLAGPOLES

- A. Flagpoles: Designed in accordance with NAAMM FP 1001
 - 1. Material: Aluminum.
 - 2. Design: Cone tapered.
 - 3. Mounting: Ground mounted type.
 - 4. Nominal Height: 30 ft (____ m); measured from nominal ground elevation.
 - 5. Halyard: Internal type, manual winch operation.

2.03 POLE MATERIALS

- A. Aluminum: ASTM B221 (ASTM B221M) , 6063 alloy , T6 temper.

2.04 ACCESSORIES

- A. Finial Ball: Gold, 6 inch (150 mm) diameter.

- B. Truck Assembly: Cast aluminum; revolving, stainless steel ball bearings, non-fouling.
- C. Flag: _____ design, 4 ft by 6 ft (1.21 m by 1.83 m) size, nylon fabric, brass grommets, hemmed edges.
- D. Cleats: 9 inch (230 mm) size, aluminum with galvanized steel fastenings, one per halyard.
- E. Cleat Box: Aluminum, with built-in hinge and hasp assembly, attached to pole with tamper proof screws inside box, key access.
- F. Halyard: 5/16 inch (8 mm) diameter nylon, braided, white.
- G. Connecting Sleeve For Multiple Section Poles: Same material as pole, precision fit for field assembly of pole, concealed fasteners.

2.05 OPERATORS

- A. Hand Crank: Removable _____ type.

2.06 MOUNTING COMPONENTS

- A. Pole Base Attachment: Flush; aluminum base with base cover.
- B. Lightning Ground Cable: Copper No. 6 AWG, soft drawn.

2.07 FINISHING

- A. Metal Surfaces in Contact With Concrete: Asphaltic paint.
- B. Aluminum: Mill finish.
- C. Finial: Gold anodized finish.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that concrete foundation is ready to receive work and dimensions are as indicated on shop drawings.

3.02 PREPARATION

- A. Coat metal sleeve surfaces below grade and surfaces in contact with dissimilar materials with asphaltic paint.

3.03 INSTALLATION

- A. Install flagpole, base assembly, and fittings in accordance with manufacturer's instructions.
- B. Coordinate installation of conduit for security through base of flag pole.

3.04 TOLERANCES

- A. Maximum Variation From Plumb: 1 inch (25 mm).

3.05 ADJUSTING

- A. Adjust operating devices so that halyard and flag function smoothly.

3.06 SCHEDULES

- A. Pavillion Poles: One 30 feet (9.1 m) with U.S. flag, one 30 feet (9.1 m) with Nevada state flag, one 30 feet (9.1 m) with Nye County School District flag

END OF SECTION