

SECTION 08 71 00

DOOR HARDWARE

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Door Hardware, including electric hardware.
- B. Storefront and entrance door hardware.

1.2 RELATED SECTIONS

- A. Section 07 90 00 - Joint Protection: exterior thresholds.
- B. Section 08 11 13 - Hollow Metal Doors and Frames.
- C. Section 08 41 13 - Aluminum Entrances and Storefronts.

1.3 REFERENCES

- A. Use date of standard in effect as of Bid date.
- B. American National Standards Institute - ANSI 156.18 - Materials and Finishes.
- C. ICC/ANSI A117.1 - Specifications for making buildings and facilities usable by physically handicapped people.
- D. ADA - Americans with Disabilities Act, 2010 ADA Standards for Accessible Design.
- E. BHMA - Builders Hardware Manufacturers Association.
- F. DHI - Door and Hardware Institute.
- G. NFPA - National Fire Protection Association:
 - 1. NFPA 80 - Fire Doors and Windows
 - 2. NFPA 105 - Smoke and Draft Control Door Assemblies
 - 3. NFPA 252 - Fire Tests of Door Assemblies
- H. UL - Underwriters Laboratories:
 - 1. UL10C - Positive Pressure Fire Tests of Door Assemblies.
 - 2. UL 305 - Panic Hardware
- I. WHI - Warnock Hersey Incorporated.
- J. Local applicable codes.
- K. SDI - Steel Door Institute.
- M. International Building Code (IBC) with Southern Nevada Amendments.

SUBMITTALS AND SUBSTITUTIONS

- A. See Section 01 33 00 - Submittal Requirements, for submittal procedures.
- B. Product Data: Manufacturer's catalog literature for each type of hardware, marked to clearly show products to be furnished for this project.
 - 1. Only submittals printed one sided will be accepted and reviewed. Organize vertically formatted schedule into "Hardware Sets" with index of doors and headings, indicating complete designations of every item required for each door or opening. Minimum 10pt font size. Include following information:
 - a. Type, style, function, size, quantity and finish of hardware items.
 - b. Use BHMA Finish codes per ANSI A156.18.
 - c. Name, part number and manufacturer of each item.
 - d. Fastenings and other pertinent information.
 - e. Location of hardware set coordinated with floor plans and door schedule.
 - f. Explanation of abbreviations, symbols, and codes contained in schedule.
 - g. Mounting locations for hardware.
 - h. Door and frame sizes, materials and degrees of swing.
 - i. List of manufacturers used and their nearest representative with address and phone number.
 - j. Catalog cuts.
 - k. Bid and submit manufacturer's updated/improved item if scheduled item is discontinued.
 - l. Deviations: Highlight, encircle or otherwise identify deviations from "Schedule of Finish Hardware" on submittal with notations clearly designating those portions as deviating from this section.
 - m. Furnish as-built/as-installed schedule with closeout documents, including keying schedule, riser and point-to-point wiring diagrams, manufacturers' installation, adjustment and maintenance information, and supplier's final inspection report.
- C. Hardware Schedule: Detailed listing of each item of hardware to be installed on each door. Use door numbering scheme as included in the Contract Documents. Identify electrically operated items and include power requirements.
 - 1. Point-to-point wiring diagrams.
- D. Keying Schedule: Coordinate Best Cores with Owner
- E. Manufacturer's Installation Instructions: Indicate special procedures, perimeter conditions requiring special attention.
- F. Maintenance Data: Include data on operating hardware, lubrication requirements, and inspection procedures related to preventative maintenance.
 - 1. Submit manufacturer's parts lists and templates.
 - 2. Bitting List: List of combinations as furnished.
- F. Warranty: Submit manufacturer's warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.

- H. Project Record Documents: Record actual locations of concealed equipment, services, and conduit.
- I. Maintenance Materials and Tools: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Lock Cylinders: Ten for each master keyed group.
 - 3. Tools: One set of all special wrenches or tools applicable to each different or special hardware component, whether supplied by the hardware component manufacturer or not.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum 10 years of documented experience.
 - 1. Hardware supplier: direct factory contract supplier who employs an architectural hardware consultant available at reasonable times during course of work for project hardware consultation to Owner, Architect and Contractor.
 - a. Responsible for detailing, scheduling and ordering of finish hardware. Detailing implies that the submitted schedule of hardware is correct and complete for the intended function and performance of the openings.
 - b. Responsible for creating a punch list on all items that do not comply with these specifications. In which all items will be completed and verified by Owner before Hardware Certification is issued to the Contractor.
- B. Hardware Supplier Qualifications: Company specializing in supplying the type of products specified in this section with at least 5 years documented experience.
- C. Exit Doors: Operable from inside with single motion without the use of a key or special knowledge or effort.
- D. Fire-Rated Openings: NFPA 80 compliant. Hardware UL10C (positive pressure) compliant for given type/size opening and degree of label. Provide proper latching hardware, non-flaming door closers, approved-bearing hinges, and resilient seals. Coordinate with wood door section for required intumescent seals. Furnish openings complete.
- E. Furnish hardware items required to complete the work in accordance with specified performance level and design intent, complying with manufacturers' instructions and code requirements.
- F. Pre-Installation Meetings: Initiate and conduct with supplier, installer and related trades, coordinate materials and techniques, and sequence complex hardware items and systems installation. Include manufacturers' representatives of locks, panic hardware and door closers in the meetings. Convene prior to commencement of related work.
- G. All hardware on aluminum storefront doors, gates and all other swinging doors, gates, keyed switches must match the brands, style and key system used in the balance of the building.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Delivery: Coordinate delivery to appropriate locations.
- B. Acceptance at Site: Items individually packaged in manufacturers' original containers, complete with proper fasteners and related pieces. Clearly mark packages to indicate contents, locations in hardware schedule and door numbers.
- C. Storage: Provide securely locked storage area for hardware, protect from moisture, sunlight, paint, chemicals, dust, excessive heat and cold, etc.

1.7 PROJECT CONDITIONS AND COORDINATION

- A. Where exact types of hardware specified are not adaptable to finished shape or size of members requiring hardware, provide suitable types having as nearly as practical the same operation and quality as type specified.
- B. Coordination: Coordinate hardware with other work, see section 1.1 item B. Furnish hardware items of proper design for use on doors and frames of the thickness, profile, swing, security and similar requirements indicated, as necessary for proper installation and function, regardless of omissions or conflicts in the information on the Contract Documents. Furnish related trades with the following information:
 - 1. Location of embedded and attached items to concrete.
 - 2. Location of wall-mounted hardware, including wall stops.
 - 3. Location of finish floor materials and floor-mounted hardware.
 - 4. Locations for conduit and raceways as needed for electrical, electronic and electro-pneumatic hardware items.
 - 5. Fire/life-safety system interfacing. Point-to-point wiring diagrams plus riser diagrams to related trades.
 - 6. Manufacturer templates to door and frame fabricators.
- C. Check Shop Drawings for doors and entrances to confirm that adequate provisions will be made for proper hardware installation.

1.8 WARRANTY

- A. Part of respective manufacturers' regular terms of sale. Provide manufacturers' written warranties:
 - 1. Heavy Duty Mortise Lock: 3 Years
 - 2. Exit Devices: 3 years mechanical - 1 year electrical
 - 3. Closers: 30 years mechanical - 2 years electrical
 - 4. Hinges: 1 year
 - 5. Other Hardware 2 years

1.9 COMMISSIONING

- A. Conduct these tests prior to request for Hardware Certification and substantial completion:

1. With installer, AHC present, test door hardware operation with climate control system and stairwell pressurization system both at rest and while in full operation.
2. With installer, AHC and access control contractor and electrical contractor present, test electrical, electronic and electro-pneumatic hardware systems for satisfactory operation.
3. With installer AHC and electrical contractor present, test hardware interfaced with fire/life-safety system for proper operation and release.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Listed acceptable alternate manufacturers: These will be considered; submit for review products with equivalent function and features of scheduled products.

ITEM:	Acceptable Manufacturers
1. Hinges	Ives, Stanley, McKinney
2. Key System	Schlage Conventional 6-pin
3. Locks	Schlage
4. Exit Devices	Sargent
6. Closers	LCN
7. Surface Bolts	Ives, Rockwood, Trimco
8. Automatic Flush Bolts	Ives, Rockwood, Trimco
9. Silencers	Ives, Rockwood, Trimco
10. Push & Pull Plates	Ives, Rockwood, Trimco
11. Lock Protectors	Ives, Rockwood, Trimco
12. Kickplates	Ives, Rockwood, Trimco
14. Overhead Stops and Holders	Glynn Johnson, Rixson, Sargent
15. Thresholds	NGP, Pemko, Zero
16. Seals & Bottoms	NGP, Pemko, Zero
17. Key Cabinets	Lund, Telkee
18. Electromagnetic Door Holders	LCN, Rixson, RSG

2.2 HINGING METHODS

- A. Drawings typically depict doors at 90 degrees, doors will actually swing to maximum allowable degree of opening potential and if it's a pair, maximum of the two. Use wide-throw conventional or continuous hinges as needed up to 8 inches in width to allow door to stand parallel to wall for true 180-degree opening. Advise architect if 8-inch width is insufficient.
- B. Conform to manufacturer's published hinge selection standard for door dimensions, weight and frequency, and to hinge selection as scheduled. Where manufacturer's standard exceeds the scheduled product, furnish the heavier of the two choices, and notify Architect of deviation from scheduled hardware.
- C. Conventional Hinges: Steel or stainless steel pins and concealed bearings. Hinge open widths minimum, but of sufficient throw to permit maximum door swing. In general,

conventional hinges are not to be used on out-swinging exterior doors (See continuous hinges below).

1. Out-swinging exterior doors: non-ferrous with non-removable (NRP) pins.
2. Non-ferrous material exteriors and at doors subject to corrosive atmospheric conditions.

2.3 LOCKSETS, LATCHSETS, DEADBOLTS

- A. Heavy- Cylindrical Locks: as scheduled.
1. Provide cylindrical locks conforming to ANSI/BHMA A156.2 Series 4000, Grade 1, and UL Listed for 3-hour fire doors.
 2. Provide locks with standard 2-3/4 inches (70 mm) backset
 4. Provide standard ASA strikes unless extended lip strikes are necessary to protect trim.
 5. Lever trim: independently operating levers with two external return spring cassettes mounted under roses to prevent lever sag.
 6. Lock Series and Design: Schlage ND" Series, "06 -Rhodes" design.
 7. Accepted substitutions: Best 93K Series, Sargent 10-Line Series

2.4 EXIT DEVICES / PANIC HARDWARE

- A. General features:
1. End caps: impact-resistant, flush-mounted. No raised edges or lips to catch carts or other equipment.
 2. Releasable in normal operation with 15-lb. maximum operating force and with 32 lb. maximum pressure under 250-lb. load to the door.
 3. Flush end cap design as opposed to typical "bottle-cap" design end cap.
 4. Exit Device Series and Design: Von Duprin 98 Series (smooth mechanism case) with 996 lever trim
- B. Specific Features:
1. Non-Fire Rated Devices: Hex Key Dogging
 2. Lever Trim: 996 breakaway type, forged brass or bronze escutcheon minimum .130" thickness, compression spring drive, match lockset lever design.
 - a. Use standard Von Duprin 996 trim only at fire rated openings. All other openings to be provided with Vandal Resistant Pull Trim, Ives VR900 series or reviewed equal.
 3. Fire-Labeled Devices: UL label indicating "Fire Exit Hardware". Vertical rod devices less bottom rod unless otherwise scheduled.
 4. Electrically Operated Devices: Single manufacturer source for electric latch retraction devices, electrically controlled trim, power transfers, power supplies, monitoring switches and controls.
 5. Mullions: Anchors must be free and clear of expansion joints, consult Architect. Anchors into expansion joints will not be accepted.
 6. Accepted substitutions: Precision Apex 2000 Series, Sargent 80 Series

2.5 CLOSERS

- A. Surface Closers: LCN 4040XP as scheduled

1. Provide door closers conforming to ANSI/BHMA A156.4 Grade 1 requirements by BHMA certified independent testing laboratory. ISO 9000 certify closers. Stamp units with date of manufacture code
2. Provide door closers with fully hydraulic, full rack and pinion action with cast aluminum cylinder or cast iron.
3. Non-sized, non-handed, and adjustable.
4. Installed for maximum allowable opening potential.
5. Plates, brackets and special templating when needed for interface with particular header, door and wall conditions and neighboring hardware
6. Adjustable to open with not more than 8.5 lbs. pressure to open at exterior doors and 5 lbs. at interior doors. As allowed per IBC. The local authority may increase the allowable pressure for fire doors to achieve positive latching, but not to exceed 15lbs.
7. Separate adjusting valves for closing speed, latching speed and backcheck.
8. Exterior doors: seasonal adjustments not required for temperatures from 120 degrees F to -30 degrees F, furnish checking fluid data on request.
9. Accepted substitutions: Norton 8500

2.6 OTHER HARDWARE

- A. Automatic Flush Bolts: Low operating force design.
- B. Surface Bolts: 8-inch x SNB (Sex nuts and bolts).
- C. Overhead Stops: Non-plastic mechanisms and finished metal end caps. Field-changeable hold-open, friction and stop-only functions.
- D. Lock Guards: As specified with SNB (Sex nuts and bolts). Welded studs are not acceptable.
- E. Kick Plates: Beveled four edges (B4E), .050 inches minimum thickness, height and width as scheduled. Sheet-metal screws of bronze or stainless steel to match other hardware.
- F. Door Stops: Provide stops to protect walls, casework or other hardware.
 1. Unless otherwise noted in Hardware Sets, provide wall type with appropriate fasteners. Where wall type cannot be used, provide floor type. If neither can be used, provide separate overhead type.
 2. Locate overhead stops for maximum possible opening. Consult with Owner for furniture locations. Minimum: 90deg stop / 95deg dead stop. Note degree of opening in submittal.
- G. Seals: Finished to match adjacent frame color. Resilient seal material: Silicone rubber as scheduled.
- H. Thresholds: As scheduled and per details. Substitute products: certify that the products equal or exceed specified material's thickness. Proposed substitutions: submit for approval.
 1. Exteriors: Seal perimeter to exclude water and vermin. Use sealant complying with requirements in Division 7 "Thermal and Moisture Protection". Non-ferrous 1/4inch fasteners and lead expansion shield anchors, or Red-Head #SFS-1420

(or reviewed equivalent) Flat Head Sleeve Anchors (SS/FHSL). Plastic anchors are not allowed.

2. Fire-rated openings, 90min or less duration: use thresholds to interrupt floor covering material under the door where that material has a critical radiant flux value less than 0.22 watts per square centimeter, per NFPA 253. Use threshold unit as scheduled. If none scheduled, request direction from Architect.
 3. Fire-rated openings, 3hour duration: Thresholds, where scheduled, to extend full jamb depth.
 4. Fasteners: Generally, Non-ferrous 1/4-inch fasteners and lead expansion shield anchors, or Red-Head #SFS-1420 (or approved equivalent) Flat Head Sleeve Anchors (SS/FHSL). Plastic plugs with wood or sheet metal screws are not an acceptable substitute for specified fastening methods.
 5. Install thresholds so that threshold contacts frame at rabbets, stops and soffit (H Pattern Cut).
 6. Anchors must be free and clear of expansion joint, consult Architect. Anchors into expansion joints will not be accepted.
- I. Silencers: Interior hollow metal frames, 3 for single doors, 2 for pairs of doors. Omit where adhesive mounted seal occurs. Leave no unfilled/uncovered pre-punched silencer holes.
 - J. Wall & Floor-mounted electromagnetic door holders. Incorporate into U.L. listed fire & life-safety system, doors released to allow closure and latching when door's zone is in an alarm state. Use minimum projection required to allow door to open as widely as allowed by wall conditions and projection of door hardware.

2.7 FINISH

- A. Generally, BHMA 626 Satin Chromium
 1. Areas using BHMA 626 to have push-plates, pulls and protection plates of BHMA 630, Satin Stainless Steel, unless otherwise noted.
- B. Door closers: factory powder coated to match other hardware, unless otherwise noted.
- C. Aluminum items: match predominant adjacent material. Seals to coordinate with frame color.

2.8 KEYING REQUIREMENTS

- A. Key System: Match Owner Standard. Coordinate keying with Owner
- B. Schlage Conventional Cylinders

PART 3 EXECUTION

3.1 ACCEPTABLE INSTALLERS

- A. Can read and understand manufacturers' templates, supplier's hardware schedule and printed installation instructions and has a minimum of 3 years installing door hardware.

Can readily distinguish drywall screws from manufacturers furnished fasteners. Available to meet with manufacturers' representatives and related trades to discuss installation of hardware.

3.2 PREPARATION

- A. Ensure that walls and frames are square and plumb before hardware installation. Make corrections before commencing hardware installation.
- B. Locate hardware per SDI-100 and applicable building, fire, life-safety, accessibility, and security codes.
 - 1. Notify Architect of code conflicts before ordering material.
 - 2. Locate levers, key cylinders, thumb-turn pieces, touch bars and other operable portions of latching hardware between 30 inches to 40 inches above the finished floor.
 - 3. Where new hardware is to be installed near existing doors/hardware scheduled to remain, match locations of existing hardware.
- C. Overhead stops: before installing, determine proposed locations of furniture items, fixtures, and other items to be protected by the overhead stop's action. Install overhead stops prior to closers when both are used.

3.3 INSTALLATION

- A. Install hardware per manufacturer's instructions and recommendations. Do not install surface-mounted items until finishes have been completed on substrate or surface. Set units level, plumb and true to line and location. Adjust and reinforce attachment substrate or surface for proper installation and operation. Remove and reinstall or replace work deemed defective by NVARNG Lock Shop or Architect.
 - 1. Gaskets: install jamb-applied gaskets before closers, overhead stops, rim strikes, etc.; fasten hardware over and through these seals. Install sweeps across bottoms of doors before astragals, cope sweeps around bottom pivots, trim astragals to tops of sweeps.
 - 2. When hardware is to be attached to existing metal surface and insufficient reinforcement exists, use RivNuts, NutSerts or similar anchoring device for screws as approved
 - 3. Use manufacturers' fasteners furnished with hardware items or submit Request for Substitution.
 - 4. Replace fasteners damaged by power-driven tools.
 - 5. Form fit/cut one-piece thresholds to match existing & new frame conditions. "H" shape on standard frames.
- B. Locate floor stops no more than 4 inches from walls and not within paths of travel. See paragraph 2.2 regarding hinge widths, door should be well clear of point of wall reveal. Point of contact of floor stop to hinge edge of door to be not less than half the width of the door but not installed to offer a tripping hazard. Where situation is questionable or difficult, contact Architect or Architectural Hardware Consultant for direction.
- C. Exterior Floor Stops: Core concrete for exterior door floor stops. Set anchors or stops in epoxy.

- D. Locate overhead stops for minimum 90 degrees and maximum allowable degree of swing.
- E. Drill pilot holes for fasteners in wood doors and/or frames.
- F. Lubricate and adjust existing hardware scheduled to remain for proper working condition, safety and security. Carefully remove and give to Owner items not scheduled for reuse.

3.4 ADJUSTING

- A. Adjust and check for proper operation, function, safety and security. Replace units, which cannot be adjusted to operate freely and smoothly.
 - 1. Hardware damaged by improper installation or adjustment methods: repair or replace to Owner's satisfaction.
 - 2. Adjust doors to fully latch with no more than 1 pound of pressure.
 - 3. Adjust delayed-action closers on fire-rated doors to fully close from fully opened position in no more than 10 seconds.
 - 4. Adjust door closers per 2.5 this section.
- B. Inspection: Initiate meeting with Architect, General Contractor, AHC, hardware installer and hardware supplier to create a punch list to be completed for final inspection.
- C. Final inspection: Installer to provide letter to Owner that upon completion installer has visited the Project and has accomplished the following:
 - 1. Re-adjust hardware.
 - 2. Evaluate maintenance procedures and recommend changes or additions and instruct Owner's personnel.
 - 3. Identify items that have deteriorated or failed.
 - 4. Submit written report identifying problems
 - 5. After all above items are complete initiate final walk with Owner to obtain Hardware Certificate.

3.5 DEMONSTRATION

- A. Demonstrate mechanical hardware and electrical, electronic and pneumatic hardware systems, including adjustment and maintenance procedures.

3.6 PROTECTION/CLEANING

- A. Cover installed hardware, protect from paint, cleaning agents, weathering, carts/barrows, etc. Remove covering materials and clean hardware just prior to substantial completion.
- B. Clean adjacent wall, frame and door surfaces soiled from installation/reinstallation process.

3.7 SCHEDULE OF FINISH HARDWARE

- A. See door schedule in drawings for hardware set assignments.

3.8 COMMISSIONING

- A. The punch list of installation deficiencies must be completed and all items needing correction must be completed prior to issuance of Certificate of Occupancy.
- B. Conduct these tests prior to request for certificate of substantial completion:
1. With installer present, test door hardware operation with climate control system at rest and while in full operation.
 2. With installer and electrical contractor present, test hardware interfaced with fire/life-safety system for proper operation and release.

3.9 SCHEDULE OF FINISH HARDWARE

- A. The hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware, and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.
- B. Hardware Schedule:

HW SET: 01 - EXTERIOR HMD - STOREROOM LOCK

100	101	104	104A	106	108
111					

Provide each SGL door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER		FINISH	MFR
3	EA	HINGE	5BB1 4.5 X 4.5 NRP		630	IVE
1	EA	STOREROOM LOCK	ND80P6D RHO		626	SCH
1	EA	LOCK GUARD	LG10		630	IVE
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS		630	IVE
1	EA	RAIN DRIP	142A-OMIT IF SHELTERED		AA	ZER
1	SET	GASKETING	50AA-S		AA	ZER
1	EA	DOOR SWEEP	39A		A	ZER
1	EA	THRESHOLD	546A -OR PER SILL DETAIL		A	ZER

HW SET: 02 - EXTERIOR HMD IN-SWINGING - STOREROOM LOCK

102 103

Provide each SGL door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER		FINISH	MFR
3	EA	HINGE	5BB1 4.5 X 4.5		630	IVE
1	EA	STOREROOM LOCK	ND80P6D RHO		626	SCH
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS		630	IVE
1	EA	FLOOR STOP	FS436/438 -AS REQ		626	IVE
1	EA	RAIN DRIP	142A-OMIT IF SHELTERED		AA	ZER
1	SET	GASKETING	50AA-S		AA	ZER
1	EA	DOOR SWEEP	39A		A	ZER
1	EA	THRESHOLD	546A -OR PER SILL DETAIL		A	ZER

HW SET: 03 - INTERIOR STOREROOM LOCK

105 107

Provide each SGL door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER		FINISH	MFR
3	EA	HINGE	5BB1 4.5 X 4.5		652	IVE
1	EA	STOREROOM LOCK	ND80P6D RHO		626	SCH
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS		630	IVE
1	EA	FLOOR STOP	FS436/438 -AS REQ		626	IVE
3	EA	SILENCER	SR64/SR65 AQ REQ		GRY	IVE

HW SET: 04 - EXTERIOR HMD- FACULTY RESTROOM LOCK

109

Provide each SGL door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER		FINISH	MFR
3	EA	HINGE	5BB1 4.5 X 4.5 NRP		630	IVE
1	EA	FAC RESTRM W/IND CYL	ND85P6D RHO		626	SCH
1	EA	LOCK GUARD	LG10		630	IVE
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS		630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B-CS (@ INSWINGING)		630	IVE
1	EA	RAIN DRIP	142A-OMIT IF SHELTERED		AA	ZER
1	SET	GASKETING	50AA-S		AA	ZER
1	EA	DOOR SWEEP	39A		A	ZER
1	EA	THRESHOLD	546A -OR PER SILL DETAIL		A	ZER
1	EA	COAT AND HAT HOOK	543		630	IVE

HW SET: 05 - INTERIOR - PRIVACY LOCK

100A

101A

Provide each SGL door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER		FINISH	MFR
3	EA	HINGE	5BB1 4.5 X 4.5		652	IVE
1	EA	PRIVACY LOCK W/ OUTSIDE INDICATOR	ND40S RHO OS-OCC		626	SCH
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS		630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B-CS (@ INSWINGING)		630	IVE
1	EA	WALL STOP	WS406/407CCV		630	IVE
1	EA	COAT AND HAT HOOK	543		630	IVE
3	EA	SILENCER	SR64/SR65 AQ REQ		GRY	IVE

HW SET: 06 - INTERIOR WITH PUSH/PULL AT MULTI STALL RESTROOM. WITH CLASSROOM DEADBOLT TO LOCK DOORS AFTER HOURS OR FOR MAINTENANCE.

110

Provide each SGL door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER		FINISH	MFR
3	EA	HINGE	5BB1HW 4.5 X 4.5		652	IVE
1	EA	CLASSROOM DEADBOLT	B663P		626	SCH
1	EA	PUSH PLATE	8200 4" X 16" CFC		630	IVE
1	EA	PULL PLATE	8303 10" 4" X 16" CFT		630	IVE
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS		630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B-CS (@ INSWINGING)		630	IVE
1	EA	WALL STOP	WS406/407CCV		630	IVE
3	EA	SILENCER	SR64/SR65 AQ REQ		GRY	IVE

HW SET: 07 - ROLL-UP DOOR

102B 106A 112

Provide each RU door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
1	EA	ROLL-UP	HARDWARE BY ROLL UP DOOR MANUFACTURER		B/O

END OF SECTION