

Jairo GomezFacio

From: Jon Wayne Nielsen <jwn@buildmonuments.com>
Sent: Friday, May 15, 2026 3:50 PM
To: Jon Cox; Derek Rosse; Avery Hacker; Jairo GomezFacio
Subject: RE: NCSD THS Field & Demo: Monument Homework

Follow Up Flag: Follow up
Flag Status: Flagged

Jon,

We requested an mix design from the available sources but it hasn't come back to us yet. I can provide that as it comes in, but will answer the others for you now.

1. Haul off quantity: First let me clarify, our bid includes all of the haul off and import necessary to deliver the project at the design grades. Monument's offer takes the whole grading scope without change orders or volume claims. I even hesitate to answer and tie our offer to a limited volume. Our responsibility ends at acceptance not a load count.

I estimated grading 8" across all of the areas designated, generating 5,555.81 CY of haul off. I started to diminish that volume for the roads and dirt parking lot which should not require hauloff if managed well, then I left it to supplement the difficult trash situation in Tonopah. I left the extra trucking in to carry out the concrete and building spoils. Monument secured a location to haul off all of the earthen spoils, but did not have a commitment on the rest. However, since I considered the entire area, I have sufficient estimated to truck out the other debris associated with the broad grading scope.

2. Paving the road. Our original bid includes Type II for the road. Since we already mobilized we can add 2" on top of the road from saw cut to the valley gutter and the area in front of the building (approximately 26K SF) for \$122,788.00.

3. We requested 4" and 2" pavement mix designs from the nearest supplier. We also wanted to vet that with our track surfacing partner. Please allow more time.

4. Foundation excavations: I did not include foundation digging. We will rough grade the area. We included all excavation for foundations in our concrete estimate per 1.c.iv of that scope of work. We intended to have a mini-x up there for demolition. We can negotiate excavation and likely discount concrete if combined with adjacent scopes.

5. Monument confirms we used the provided wage rates. Since our meeting, we compared those and the Clark County rates and found no differences for our classifications.

Yesterday we focused much of our discussion sorting our estimates into CORE's packages. It was hard to set expectations while coordinating these packages in a new way. Monument included everything CORE wrote into the scopes but also included the obvious connections between those scopes. For example, we knew our utility connections include components by others which we had to work out. However, many sports contractors may not want to work together with every partner available to CORE. These same companies compete too regularly. My first goal is great partnerships. I can't resolve every grudge, but we offer to negotiate any adjacent package until we are competitive for CORE and its Client.

Thank you for your time.

MONUMENT CONSTRUCTION

Jon Wayne Nielsen

Cell: 702.576.5210 Office: 702.530.2303
7787 Eastgate Road #110 Henderson, NV 89011

WWW.BUILDMONUMENTS.COM



[AZ 328669 CA B 948735 NV B 0075502 UNLIMITED NV A 0080649 UNLIMITED UT B100# 113632903-5501](#)