

Dawn Duranleau

From: Travis Starley <tstarley@usmechanicalllc.com>
Sent: Monday, June 1, 2026 5:54 PM
To: Jairo GomezFacio
Cc: Jon Cox; Derek Rosse; Avery Hacker; Dawn Duranleau
Subject: RE: Tonopah HS Field - US Mech. Additional Information

Jairo,

See below.

Thanks,

Travis Starley
472 S 640 W
Pleasant Grove UT 84062
801-796-2075 office
702-544-2303 cell
801-785-6023 fax
tstarley@usmechanicalllc.com
www.usmechanicalllc.com



From: Jairo GomezFacio <jairogomezfacio@coreconstruction.com>
Sent: Friday, May 29, 2026 2:35 PM
To: Travis Starley <tstarley@usmechanicalllc.com>
Cc: Jon Cox <joncox@coreconstruction.com>; Derek Rosse <derekrosse@coreconstruction.com>; Avery Hacker <averyhacker@coreconstruction.com>; Dawn Duranleau <dawnduranleau@coreconstruction.com>
Subject: Tonopah HS Field - US Mech. Additional Information

Travis,

Please provide the following information by **no later than Monday, 6/1/26, afternoon.**

- Propane piping includes underground digging to the existing building and to the new location-Yes
- Verify hard dig for elementary school demo-\$8,300
- Assume 18" for trench-correct
- Provide cost for concrete trench patching for the underground gas line.-\$36,800
- Provide cost for elevated gas line on top of existing shade structure to remain-\$13,500
- Included price for propane tank (Provide spec)-waiting on vendor
- Provide cost for a gas meter at the propane tank.-\$8,562
- Provide cost breakdown for propane tank. \$15,000
- Included cost for concrete pad for propane tank \$5,111

- Assume residential-style exhaust fans-correct
- Provide the cost for shifting FCU 5 to Team 1-\$3,945
- Provide cost to switch over to an RTU instead of FCU.-no savings
- Provide the cost of eliminating the ceiling of the marked-up rooms.-\$758

If you have any questions, please let us know.

Thank you,

Jairo Gomez

Project Engineer

CORE Construction | West

C: 725-324-2528 | W: coreconstruction.com

E: jairogomezfacio@coreconstruction.com