RIVERBEND PROCESS INDUSTRIES

Environmental Compliance Department

Monthly Effluent Compliance Audit

Audit No: ECA-2026-1052

Site: Riverbend Industrial Park

Date: 21/10/2026

Auditor: Meera Pillai

Outlet pH: 7.3

Outlet TSS: 38 mg/L

Outlet COD: 212 mg/L

Flow Meter Reading: 18,642 m3

Laboratory Results

Parameter	Limit	Result	Status
pH	6.5-8.5	7.3	PASS
TSS	100	38	PASS
COD	250	212	PASS
BOD	30	21	PASS
Oil and Grease	10	4.2	PASS

Site Checklist

- [x] Sampling point labelled
- [x] Composite sampler operating
- [x] Discharge log up to date

Fig 1. Outfall channel

Auditor Signature:

Remarks: All parameters within consent limits.

Hydris demo document - print, then scan with Audit scan on the glasses or in the console.