

COASTAL STRUCTURAL ENGINEERING CONSULTANTS

Specialists in Windstorm, Hail, & Structural Envelope Analysis

Claimant: Coastal Heritage Realty Group Policy Number: POL-771820

Property: 120 Ocean View Blvd, Tampa, FL Date of Loss: August 26, 2026

Peril Type: Windstorm & Gale Wind Uplift Weather Correlation: NOAA Confirmed 78mph

ENGINEERING DAMAGE ASSESSMENT & ESTIMATE:

1. Tear-Off & Disposal of Blown Architectural Shingles [38 SQ @ \$330.00/SQ] \$12,540.00
2. 5/8in CDX Plywood Roof Decking Replacement [18 Sheets @ \$110.00/sheet] \$1,980.00
3. Owens Corning Duration Lifetime Shingle System & Underlayment \$15,200.00
4. Interior Second-Floor Ceiling Water Stain Drywall & Paint Remediation \$6,530.00
5. Florida Building Code Section 1507 Hurricane Tie-Down Strapping Retrofit \$2,500.00

CODE COMPLIANCE & WARRANTY:

- High-wind 130 mph warranty rated shingles required per regional wind zone ordinance.

TOTAL REPAIR & CODE UPGRADE ESTIMATE (RCV): \$38,750.00

Senior Property Consultant: Robert Henderson, PE #58821