RCS01 Afternoon Lab - Rolling Sink Module

CTS Cohort 6 | D09 / RCS01 | Monday, July 20, 2026

Core rule: A professional does not guess. A professional checks, protects, and verifies.

Lab Mission

Build a simple sink drain and P-trap assembly in the rolling lab module, inspect it, leak-test it, troubleshoot problems, and document verified work.

Safety Boundary

- Water stays off until the assembly has been inspected.
- No electrical tools or cords near wet areas.
- Wipe spills immediately.
- Stop if a fitting does not align or a part is missing.
- Do not overtighten plastic fittings. Hand-tight plus instructor guidance only.

Roles

Role	Job
Builder	Assembles parts and calls out each step.
Inspector	Checks alignment, washers, tightness, and leaks.
Documenter	Records parts, issues, fixes, and evidence photos.

Parts Inventory

Part	Have it?	What it does	Notes
Sink basin/module		Holds water and routes it to drain	
Faucet		Controls water into sink	
Supply line/shutoff		Brings water to faucet and allows shutoff	
Tailpiece		Connects sink drain to trap	
P-trap		Holds water seal and service point	
Slip nuts/washers		Seal adjustable drain joints	
Drain outlet		Carries water away	

Build Sequence

1. Inventory all parts.

2. Lay parts out in system order.
3. Dry-fit the tailpiece, trap, and outlet path.
4. Check washer direction and slip nut alignment.
5. Hand-tighten fittings.
6. Stop for inspection before water testing.
7. Place bucket/towel before testing.
8. Run a small amount of water and observe.
9. Mark or record any leak before fixing it.
10. Correct one issue at a time.
11. Retest and verify dry joints.
12. Reset the module after instructor approval.

Leak Troubleshooting Table

Problem observed	Likely cause	Fix attempted	Retest result	Instructor initials

Success Criteria

- Parts identified and assembled in correct order.
- No leaks after correction and retest.
- Group can explain the water path.
- Station is clean, dry, and reset.
- Verification log is complete.