PV102 Day 5 Afternoon Lab

Critical Load Storage Plan

PV102 | CTS Day 21 | Afternoon Lab
Storage has a defined job: carry named loads through named time. | Monday, August 10, 2026

Mission

Teams reduce an oversized wish list into a critical-load storage plan that a real system could support.

Safety boundary

This lab is training work. Do not energize or connect equipment outside the instructor-approved procedure. When in doubt, stop, isolate, verify, and ask.

Scenario options

- Bus conversion overnight loads: fridge, fan, lights, phone, laptop, water pump, optional induction cooktop.
- Remote sensor must survive two stormy days with no site visit.
- Small shop wants outage backup for lights, router, one outlet, and refrigerator only.

Procedure

- Start with the Day 3 load table or provided scenario.
- Mark each load as critical, useful, or optional.
- Calculate critical daily Wh.
- Choose an autonomy target and estimate required Wh before adjustment.
- List the battery information required before final sizing.
- Handoff the critical-load list, autonomy target, and rejected optional loads.

Acceptance criteria

- Match the real job.
- Show the energy or work path.
- Name the dominant constraint.
- State the safety boundary.
- Record unknowns instead of guessing.
- Give a handoff another crew can use.

Team handoff form

Item	Response
Team members	
Scenario	
Primary decision	

Evidence	
Safety boundary	
Unknowns	
Next safest action	