PV102 Day 2 Afternoon Lab

Site Walk and Solar Access Handoff

PV102 | CTS Day 18 | Afternoon Lab
Measure the site before you size the system. | Tuesday, August 4, 2026

Mission

Teams inspect three candidate locations and decide which one deserves further design work.

Safety boundary

This lab is training work. Do not energize or connect equipment outside the instructor-approved procedure. When in doubt, stop, isolate, verify, and ask.

Scenario options

- South-facing roof plane with one morning tree shadow and limited attic access.
- Open ground rack area with excellent sun but long wire run and mower traffic.
- West-facing shed roof near the load with easy service access and afternoon sun.

Procedure

- Assign one candidate location per team.
- Sketch the site from above and mark north, shade sources, access path, approximate array area, and likely wire route.
- Record observations in three columns: measured, observed, unknown.
- Name the best reason to keep or reject the site for first-pass design.
- Prepare a two-minute handoff for Day 3.

Acceptance criteria

- Match the real job.
- Show the energy or work path.
- Name the dominant constraint.
- State the safety boundary.
- Record unknowns instead of guessing.
- Give a handoff another crew can use.

Team handoff form

Item	Response
Team members	
Scenario	
Primary decision	

Evidence	
Safety boundary	
Unknowns	
Next safest action	