



Home

Plant

O&M

Org & User

Edit Grid Profile

File Name: EU_EN50438

S N	Name	Value	Unit	Range
1	EU_EN50438 ?			
2	H/LVRT ?			
3	Nominal Voltage (NV)	230	V	~
4	Low Voltage 1 (LV1)	<input type="text" value="184"/>	V	170~195.5
5	LV1 Maximum Trip Time (MTT)	1.6	s	~
6	High Voltage 1 (HV1)	<input type="text" value="260"/>	V	253~270
7	HV1 Maximum Trip Time (MTT)	1.6	s	~
8	H/LFRT ?			
9	Nominal Frequency	50	Hz	~
1 0	Low Frequency 1 (IF1)	<input type="text" value="48"/>	Hz	48~49.9
1 1	IF1 Maximum Trip Time (MTT)	1.6	s	~
1 2	High Frequency 1 (HF1)	<input type="text" value="51"/>	Hz	50.1~51



	Home	Plant	O&M	Org & User	~
1 4	Islanding Detection (ID)				
1 5	ID Function Activated	<input type="text" value="1"/>			0~1
1 6	Reconnection (RT)				
1 7	Reconnect Time (RT)	<input type="text" value="10"/>	s		10~300
1 8	Reconnect High Voltage (RHV)	<input type="text" value="253"/>	V		240~253
1 9	Reconnect Low Voltage (RLV)	<input type="text" value="184"/>	V		184~210
2 0	Reconnect High Frequency (RHF)	<input type="text" value="51"/>	s		50.1~51
2 1	Reconnect Low Frequency (RLF)	<input type="text" value="48"/>	s		48~49.9
2 2	Ramp Rates(RR)				
2 3	Normal Ramp up Rate (RUR_NM)	<input type="text" value="40"/>	Rated%/s		10~100
2 4	Soft Start Ramp up Rate (RUR_SS)	<input type="text" value="10"/>	Rated%/s		0.1~10
2 5	Active Power Control (APC)				
2 6	APC Function Activated	<input type="text" value="1"/>			0~1