

Fleet Performance Summary – January 2026

Asset Operations · operating portfolio 1,100 MW

David Chen · 12 February 2026 · OPS-RPT-2026-01

1. Headlines


The fleet produced **264.5 GWh** from wind and solar in January 2026, 1.2 % below budget (267.6 GWh). Best performer against budget was Ostholstein (+6.4 %); weakest was Lüneburger Heide Solar (-15.4 %).

Kestrel Ridge T-07 gearbox failure on 14 January (KR-INC-2026-003); the turbine was offline for the rest of the month. Fleet-wide CMS data review found no similar trend.

2. Asset table

Asset	Technology	Actual (GWh)	Budget (GWh)	Variance	Availability
Kestrel Ridge	Onshore wind	24.7	25.2	-2.0 %	94.1 %
Skerrow Moor	Onshore wind	30.8	29.2	+5.5 %	97.7 %
Dunmore Hill	Onshore wind	18.1	18.1	+0.0 %	96.7 %
Glenquey	Onshore wind	17.3	16.8	+3.0 %	98.0 %
Nordheide	Onshore wind	27.7	28.8	-3.8 %	98.1 %
Wesermarsch	Onshore wind	20.8	22.0	-5.5 %	95.8 %
Ostholstein	Onshore wind	21.6	20.3	+6.4 %	97.0 %
Emsland	Onshore wind	27.5	26.3	+4.6 %	98.3 %
Altmark	Onshore wind	32.2	32.0	+0.6 %	97.8 %
Thy Vest	Onshore wind	31.6	35.1	-10.0 %	97.3 %
Ringkøbing	Onshore wind	9.0	10.4	-13.5 %	95.5 %
Uckermark Solar	Solar PV	2.1	2.1	+0.0 %	99.5 %
Lüneburger Heide Solar	Solar PV	1.1	1.3	-15.4 %	99.3 %

Net generation at the point of connection. Budget = P50 per asset, monthly profile.



3. Safety

No recordable injuries in operations this month. 15 near misses and 49 safety observations were reported across the operating sites.

4. Actions for next month

- Prepare O&M readiness steering committee for Harrow Bay.
- Update spare parts minimum stock for converter modules after two failures.
- Close out open corrective work orders older than 30 days at Wesermarsch.