

Fleet Performance Summary – March 2026

Asset Operations · operating portfolio 1,100 MW

David Chen · 12 April 2026 · OPS-RPT-2026-03

1. Headlines


The fleet produced **239.4 GWh** from wind and solar in March 2026, 0.1 % above budget (239.1 GWh). Best performer against budget was Emsland (+7.9 %); weakest was Nordheide (-12.0 %).

Redispatch 2.0 curtailment at Nordheide reached 6.4 % of potential production – the highest month so far. Endoscope campaign at Kestrel Ridge completed (one finding on T-12).

2. Asset table

Asset	Technology	Actual (GWh)	Budget (GWh)	Variance	Availability
Kestrel Ridge	Onshore wind	21.7	21.7	+0.0 %	97.7 %
Skerrow Moor	Onshore wind	25.9	25.2	+2.8 %	98.3 %
Dunmore Hill	Onshore wind	16.1	15.6	+3.2 %	96.8 %
Glenquey	Onshore wind	15.1	14.5	+4.1 %	97.0 %
Nordheide	Onshore wind	21.9	24.9	-12.0 %	97.3 %
Wesermarsch	Onshore wind	20.2	19.0	+6.3 %	94.3 %
Ostholstein	Onshore wind	16.0	17.5	-8.6 %	97.4 %
Emsland	Onshore wind	24.5	22.7	+7.9 %	98.2 %
Altmark	Onshore wind	25.5	27.6	-7.6 %	96.0 %
Thy Vest	Onshore wind	32.7	30.3	+7.9 %	98.2 %
Ringkøbing	Onshore wind	8.4	9.0	-6.7 %	94.8 %
Uckermark Solar	Solar PV	7.1	6.8	+4.4 %	99.4 %
Lüneburger Heide Solar	Solar PV	4.3	4.3	+0.0 %	99.8 %

Net generation at the point of connection. Budget = P50 per asset, monthly profile.



3. Safety

One lost time injury: a contractor technician fractured his ankle at Altmark on 19 March (HSE-INC-2026-007). 13 near misses and 61 safety observations were reported across the operating sites.

4. Actions for next month

- Close out open corrective work orders older than 30 days at Wesermarsch.
- Prepare O&M readiness steering committee for Harrow Bay.
- Complete CMS threshold retuning at Skerrow Moor and Glenquey.