

Fleet Performance Summary – May 2026

Asset Operations · operating portfolio 1,100 MW

David Chen · 12 June 2026 · OPS-RPT-2026-05

1. Headlines


The fleet produced **166.5 GWh** from wind and solar in May 2026, 1.5 % below budget (169.0 GWh). Best performer against budget was Nordheide (+10.4 %); weakest was Thy Vest (-12.6 %).

Preventive ISS bearing replacement on Kestrel Ridge T-12. Annual service campaigns running at Kestrel Ridge, Skerrow Moor and Thy Vest.

2. Asset table

Asset	Technology	Actual (GWh)	Budget (GWh)	Variance	Availability
Kestrel Ridge	Onshore wind	13.6	14.3	-4.9 %	96.8 %
Skerrow Moor	Onshore wind	15.8	16.6	-4.8 %	97.1 %
Dunmore Hill	Onshore wind	10.1	10.3	-1.9 %	96.8 %
Glenquey	Onshore wind	9.2	9.6	-4.2 %	96.7 %
Nordheide	Onshore wind	18.1	16.4	+10.4 %	98.2 %
Wesermarsch	Onshore wind	13.2	12.5	+5.6 %	95.8 %
Ostholstein	Onshore wind	10.3	11.5	-10.4 %	96.5 %
Emsland	Onshore wind	15.7	14.9	+5.4 %	98.3 %
Altmark	Onshore wind	17.7	18.2	-2.7 %	97.0 %
Thy Vest	Onshore wind	17.4	19.9	-12.6 %	96.0 %
Ringkøbing	Onshore wind	6.0	5.9	+1.7 %	96.6 %
Uckermark Solar	Solar PV	11.7	11.6	+0.9 %	99.6 %
Lüneburger Heide Solar	Solar PV	7.7	7.3	+5.5 %	99.7 %

Net generation at the point of connection. Budget = P50 per asset, monthly profile.



3. Safety

No lost time injuries in operations. 14 near misses and 52 safety observations were reported across the operating sites.

4. Actions for next month

- Follow up open warranty items with the OEMs (Skerrow Moor blade bearing seals).
- Close out open corrective work orders older than 30 days at Wesermarsch.
- Update spare parts minimum stock for converter modules after two failures.