

Fleet Performance Summary – July 2026

Asset Operations · operating portfolio 1,100 MW

David Chen · 12 August 2026 · OPS-RPT-2026-07


1. Headlines

The fleet produced **128.7 GWh** from wind and solar in July 2026, 3.6 % below budget (133.5 GWh). Best performer against budget was Wesermarsch (+10.5 %); weakest was Dunmore Hill (-12.8 %). Very low wind across the UK fleet (Kestrel Ridge 17 % capacity factor). Solar generation slightly above budget.

2. Asset table

Asset	Technology	Actual (GWh)	Budget (GWh)	Variance	Availability
Kestrel Ridge	Onshore wind	9.8	10.9	-10.1 %	97.6 %
Skerrow Moor	Onshore wind	11.5	12.6	-8.7 %	97.7 %
Dunmore Hill	Onshore wind	6.8	7.8	-12.8 %	95.9 %
Glenquey	Onshore wind	6.7	7.3	-8.2 %	96.8 %
Nordheide	Onshore wind	11.3	12.4	-8.9 %	97.7 %
Wesermarsch	Onshore wind	10.5	9.5	+10.5 %	94.6 %
Ostholstein	Onshore wind	8.7	8.8	-1.1 %	95.9 %
Emsland	Onshore wind	11.6	11.3	+2.7 %	97.6 %
Altmark	Onshore wind	15.2	13.8	+10.1 %	97.8 %
Thy Vest	Onshore wind	14.7	15.1	-2.6 %	96.6 %
Ringkøbing	Onshore wind	4.1	4.5	-8.9 %	96.9 %
Uckermark Solar	Solar PV	10.9	12.0	-9.2 %	99.1 %
Lüneburger Heide Solar	Solar PV	6.9	7.5	-8.0 %	99.0 %

Net generation at the point of connection. Budget = P50 per asset, monthly profile.



3. Safety

No lost time injuries in operations. 10 near misses and 32 safety observations were reported across the operating sites.

4. Actions for next month

- Close out open corrective work orders older than 30 days at Wesermarsch.
- Complete CMS threshold retuning at Skerrow Moor and Glenquey.
- Update spare parts minimum stock for converter modules after two failures.