

Fleet Performance Summary – August 2026

Asset Operations · operating portfolio 1,100 MW

David Chen · 12 September 2026 · OPS-RPT-2026-08

1. Headlines


The fleet produced **153.8 GWh** from wind and solar in August 2026, 3.4 % above budget (148.7 GWh). Best performer against budget was Thy Vest (+12.0 %); weakest was Ringkøbing (-5.8 %).

Altmark WEA 12 offline for 5 days after a transformer gas relay alarm on 21 August. Drone blade inspection campaign completed at Kestrel Ridge.

2. Asset table

Asset	Technology	Actual (GWh)	Budget (GWh)	Variance	Availability
Kestrel Ridge	Onshore wind	13.0	12.6	+3.2 %	97.8 %
Skerrow Moor	Onshore wind	15.4	14.6	+5.5 %	98.0 %
Dunmore Hill	Onshore wind	9.4	9.1	+3.3 %	96.2 %
Glenquey	Onshore wind	8.6	8.4	+2.4 %	97.5 %
Nordheide	Onshore wind	14.1	14.4	-2.1 %	98.2 %
Wesermarsch	Onshore wind	10.8	11.0	-1.8 %	94.9 %
Ostholstein	Onshore wind	9.9	10.1	-2.0 %	98.2 %
Emsland	Onshore wind	14.0	13.1	+6.9 %	96.4 %
Altmark	Onshore wind	17.2	16.0	+7.5 %	96.4 %
Thy Vest	Onshore wind	19.6	17.5	+12.0 %	97.7 %
Ringkøbing	Onshore wind	4.9	5.2	-5.8 %	94.7 %
Uckermark Solar	Solar PV	10.7	10.3	+3.9 %	98.9 %
Lüneburger Heide Solar	Solar PV	6.2	6.4	-3.1 %	99.1 %

Net generation at the point of connection. Budget = P50 per asset, monthly profile.



3. Safety

No recordable injuries in operations this month. 14 near misses and 60 safety observations were reported across the operating sites.

4. Actions for next month

- Prepare O&M readiness steering committee for Harrow Bay.
- Review negative price strategy for Uckermark and Lüneburger Heide with the trading desk.
- Complete CMS threshold retuning at Skerrow Moor and Glenquey.