

Annual Grid Code Compliance Report 2025

Kestrel Ridge Wind Farm – submitted to NordGrid Transmission

Sofie Lindqvist · 17 April 2026 · KR-ELE-RPT-2025-01

Kestrel Ridge Wind Farm (75.6 MW) operated in compliance with its connection agreement NGT-CA-2021-0213 throughout 2025. Availability was 97.4 %, generation 206.6 GWh.

Item	2025
Frequency response events	14 (all compliant)
Voltage excursions	0
Constraint instructions from NordGrid	23 (98.5 h)
Protection operations	2 (correct)
Harmonic measurements	Within planning levels
Changes to plant	None

Note for 2026: T-07 gearbox exchange in January–February 2026 (KR-INC-2026-003) – no change to electrical characteristics, NordGrid informed on 16 January 2026.