

Monthly Performance Report – November 2024

Kestrel Ridge Wind Farm (75.6 MW)

David Chen · 09 December 2024 · KR-OPS-RPT-2024-11


1. Summary

Kestrel Ridge generated **20.9 GWh** in November 2024, 3.2 % below the P50 budget of 21.6 GWh. Availability of **97.3 %** met the contract target of 97.0 %. Mean hub-height wind speed of 9.2 m/s was close to the long-term mean (9.1 m/s).

2. Production and key figures

KPI	November 2024	Budget / target	YTD 2024	YTD budget
Net generation (GWh)	20.9	21.6	118.3	120.9
Time-based availability	97.3 %	97.0 %	96.5 %	97.0 %
Capacity factor	38.4 %	39.7 %	26.7 %	–
Mean wind speed at hub height (m/s)	9.2	9.1	–	–

Source: Kestrel Ridge SCADA, revenue meter at 132 kV point of connection. Budget = P50 (2024 post-construction yield assessment).



Monthly generation vs. P50 budget, 2024 year to date

3. Availability and downtime

Total turbine downtime attributable to the contractor amounted to 40 turbine-hours for the top events listed below. No grid or force majeure exclusions were claimed this month.

Turbine	Event	Downtime (h)
---------	-------	--------------

T-15	yaw brake pad wear – pads replaced	15
T-01	generator slip ring brush wear alarm	11
T-08	high-voltage transformer gas relay alarm (inspected, no fault found)	9
T-13	high-voltage transformer gas relay alarm (inspected, no fault found)	5

Top downtime events of the month (SCADA event log, reviewed with Highline Wind Services).

4. Maintenance

- 14 corrective work orders closed, 4 still open at month end.
- Substation monthly inspection completed; no abnormalities on the 33/132 kV transformer.

5. Health, safety and environment

Indicator	Month
Hours worked on site (Highline + Weyland)	2,944
Lost time injuries	0
First aid cases	0
Near misses reported	1
Safety observations	9
Environmental incidents	0

No complaints from neighbours were received this month.

6. Outlook

We will review the downtime events above with Highline in the monthly O&M meeting and track the recurring pitch faults.

Prepared by Sara Lindgren (Performance Analyst); reviewed by Ben Okoye (Site Manager) and David Chen (Asset Operations Manager).