

Lead Local Flood Authority

To: Sarah Hollis, Senior Planning Officer, Millbrook District Council · Date: 2026-08-11

**Application MDC/2026/0412 – Land north of Millbrook (Ashcombe Farm and Hollins Farm):
solar farm of up to 85 MWp with battery storage**

Response: No objection subject to conditions

The drainage strategy is acceptable in principle. A detailed surface water drainage scheme based on the outline strategy (greenfield run-off rate of 2.1 l/s/ha, 1-in-100-year plus 40 % climate change) should be required by condition.

Yours sincerely,

Lead Local Flood Authority – Planning Liaison