

Fire and Rescue Service

To: Sarah Hollis, Senior Planning Officer, Millbrook District Council · Date: 2026-09-03

**Application MDC/2026/0412 – Land north of Millbrook (Ashcombe Farm and Hollins Farm):
solar farm of up to 85 MWp with battery storage**

Response: Advice

We have reviewed the outline Battery Safety Management Plan (BSMP) Rev 2. The separation distances between containers, the two access points, the 228 m³ fire water containment and the on-site water supply (static tank 228 m³) are in line with our guidance. We request that the final BSMP is approved before the BESS is installed and that an emergency response plan is shared with the service.

Yours sincerely,

Fire and Rescue Service – Planning Liaison