

Outline Battery Safety Management Plan

Millbrook BESS – Rev 2

Sofie Lindqvist · 28 August 2026 · MB-ENG-PLN-0007

1. Scope

Outline safety strategy for the 20 MW / 40 MWh lithium iron phosphate (LFP) battery energy storage system at Millbrook. Rev 2 incorporates comments from the fire and rescue service (meeting of 13 August 2026).

2. Key safety features

- LFP chemistry – lower thermal runaway risk than NMC
- 16 containers with 3 m separation, 25 m from the site boundary, 420 m from the nearest dwelling
- Container-level gas detection, deflagration venting and water-based suppression interface
- Two access points for emergency vehicles; 6 m wide internal road around the compound
- Static water tank 228 m³ (two hours at 1,900 l/min)
- Fire water containment in a lined, valve-controlled basin (228 m³)
- 24/7 remote monitoring from the Weyland control room with automatic shutdown

3. Emergency response

A site-specific emergency response plan will be agreed with the fire and rescue service before commissioning, including a premises information box at the gate, training for the first-response crew and an annual joint exercise.

IMAGE PLACEHOLDER

millbrook-bess-reference

Row of white containerised battery storage units on a gravel compound with a security fence and a small transformer, surrounded by grassland and young hedgerow, clear day.

Reference installation: containerised LFP storage