

Grid Connection Application

Fenwick Battery Storage – 100 MW / 200 MWh

Liam McAllister · 03 July 2026 · NGT-APP-2026-0739

1. Application summary

Item	Value
Application reference	NGT-APP-2026-0739
Submitted	15 July 2026 (competent 21 August 2026)
Applicant	Weyland Energy GmbH, for Fenwick Battery Storage Ltd (SPV in formation)
Technology	Battery energy storage system (lithium iron phosphate), 100 MW / 200 MWh (2-hour)
Point of connection requested	Fenwick 132 kV substation (existing, NordGrid), new feeder bay
Export / import capacity	100 MW / 100 MW
Requested connection date	1 October 2029
Site	Land adjacent to Fenwick substation, 4.2 ha – option with Hallam Farms Partnership signed 30 April 2026
Application fee	EUR 48,500 (paid 15 July 2026)

2. Project description

Fenwick Battery Storage will provide balancing and flexibility services to the transmission system: frequency response, balancing mechanism participation and wholesale arbitrage. The site is next to the existing Fenwick 132 kV substation, so the connection needs only a 250 m underground cable. The scheme is led by Kwame Mensah (Battery Storage Developer) with Ahmed Rahimi (Grid Connection Specialist).

3. Technical data

Parameter	Value
Number of containers	40 (2.5 MWh each) + 20 PCS/transformer skids
Round-trip efficiency (AC)	86 %
Response time	< 1 second (0–100 %)
Fault level contribution	1.2 × rated current, 3-phase
Reactive capability	0.95 lagging to 0.95 leading at full output
Point of common coupling	132 kV, Fenwick substation busbar section 2