

Glint and Glare Assessment

Millbrook Solar & Storage – Lumen Reflect Consulting, report LRC-2026-044 Rev 2

Sofie Lindqvist · 08 May 2026 · MB-DES-RPT-0021

Summary

Lumen Reflect Consulting was commissioned by Weyland Energy to assess the potential for glint and glare from the proposed Millbrook Solar & Storage scheme. We modelled 34 residential receptors, 5.5 km of road, the branch railway and the approach paths of Millbrook Airfield, using the submitted layout (Rev C) with single-axis trackers ($\pm 55^\circ$ rotation, backtracking enabled, 2.9 m maximum height).

Result: with the proposed 3 m hedgerow screen along the Mill Lane frontage, no receptor experiences more than a *low* residual effect. No mitigation is needed for road users, rail or aviation.

1. Methodology

Reflections were modelled with a geometric ray-tracing model at one-minute intervals for a full year, for each receptor at 1.5 m (ground floor) and 4.5 m (first floor) above ground. Bare-earth terrain was used first; existing hedgerows and buildings were then added from a drone survey of 14 March 2026. Effects are classified as None, Low, Moderate or High, considering duration (minutes per day, days per year), the time of day and whether the sun is in the same field of view.

2. Receptors and results