

modulyss®
Zevensterrestraat 21
9240 ZELE

Your notice of	Your reference	our reference	date
		PW/1904	2013-09-06

Certification Report Nr. 13/1904

1. Description of the flooring:

Product group:	Tufted carpet tiles - FR Bitumen backed 100% polyamide
Total mass:	4200 g/m ² - 4750 g/m ²
Effective pile thickness:	0.8 mm – 5.0 mm
Certificate of conformity:	0493-CPD-0022

2. Executed tests:

ISO 9239-1:2010
Reaction to fire tests for floorings -- Part 1: Determination of the burning behaviour using radiant heat source

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose laid on a non-combustible substrate

Critical radiant flux $\geq 4.5 \text{ kW/m}^2$*
--

*tested until flame extinguishment


This report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel. The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment

CENTEXBEL GENT
Technologiepark 7
BE-9052 Zwijnaarde (Gent)
Tel. +32 9 220 41 51
Fax +32 9 220 49 55
e-mail gent@centexbel.be

CENTEXBEL BRUSSELS
Montoyerstraat 24-B2
BE-1000 Brussels
Tel. +32 2 287 08 30
Fax +32 2 230 68 15
e-mail brussel@centexbel.be

CENTEXBEL VERVIERS
Avenue du Parc 38
BE-4650 Herve (Chaineux)
Tel. +32 87 32 24 30
Fax +32 87 34 05 18
e-mail chaineux@centexbel.be



Addressee
modulyss®

our ref.
PW/1904

date
2013-09-06

page number
2

Related commercial names to this product group are:

AFFINITY	ON-LINE 1
ALTERNATIVE 100	ON-LINE 2
BLACK &	PERPETUAL
CAMBRIDGE	REVERSE 100
CONNEXXION	ROUND-UP
COLOR &	SHINE-UP
CONVERSE 100	STEP
ECO 100 C	STREPQES C
ECO 100 L	STREPQES L
FIRST	UNI
FIRST LINES	UNIQUE
FIRST ABSOLUTE	
FIRST BLOCKS	
FIRST STRIPES	
FIRST WAVES	
GRADIENT	
IN GROOVE	
LINE-UP	
METALLIC	
MILLENNIUM	
MILLENNIUM 100	
MINIMUM 100	

The obtained classification is based on the next test reports:

Centexbel: 11.82109.01 of 2011-11-24
Centexbel: 11.82109.02 of 2011-11-24
CRET: RL 2012/216

Certificate valid until 2016-11-24

Petra Wittevrongel
product certifier