

# VOC Content Test Certificate

Thursday June 4<sup>th</sup>, 2009

Manufacturer: Winstone Wallboards Ltd (37 Felix Street, Penrose Auckland New Zealand)

Sample Description: GIB<sup>®</sup> Aquaseal multipurpose silicone sealant

Date Tested: May 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>New Zealand Green Building Council</b> <b>Green Star NZ Office 2009 IEQ-3</b> <b>Green Star NZ Office Interiors IEQ-3</b>	<b>GIB<sup>®</sup> Aquaseal</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>&lt;1 gram per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F0905-21**