

 Water Technologies & Solutions	Project No.	508782
	Project	'Wastewater Treatment Plant – ETP/STP/RO/ZLD System
	Customer	'M/s. Sandoz. Pvt. Ltd.

**REQUEST FOR QUOTATION FOR SUPPLY OF
NON-METALLIC TANKS
508782-WTS-ME-T03-0354-RE-M14**

A	12.11.2021	Request for Quotation	Amit	Uday	Uday
Rev.	Date	Description	Prepared	Checked	Approved

Table of Contents

 Water Technologies & Solutions	Project No.	508782
	Project	'Wastewater Treatment Plant – ETP/STP/RO/ZLD System
	Customer	'M/s. Sandoz. Pvt. Ltd.

1.	GENERAL.....	3
2.	SCOPE OF WORK	3
3.	NON-METALLIC TANKS :	3
4.	PAINTING:.....	4
	Painting shall be as per manufacturer standard and it should suitable for the intended application for outdoor condition.	4
5.	DIVISION OF RESPONSIBILITY:.....	4
6.	WARRANTY/GUARANTEE	5
7.	LIST OF DOCUMENTS TO BE SUBMITTED:.....	6
8.	ATTACHMENTS:.....	6

 Water Technologies & Solutions	Project No.	508782
	Project	'Wastewater Treatment Plant – ETP/STP/RO/ZLD System
	Customer	'M/s. Sandoz. Pvt. Ltd.

1. GENERAL

The document is the Requisition for Quotation (RFQ) for the requirements specified in the requirements for the Design, Engineering, Manufacture, Testing & Delivery of **NON-METALLIC TANKS** for 'Wastewater Treatment Plant – ETP/STP/RO/ZLD System, 'M/s. Sandoz. Pvt. Ltd.

This specification and all documents listed herein cover the minimum requirements for the Non-metallic Tanks along with associated accessories if any forming an integral part of the scope of supply.

All Tanks under this specification shall be of proven design and reliability for the safe and continuous operation at the specified service conditions on the jobsite.

2. SCOPE OF WORK

The scope of work shall comprise Non-metallic Tank Design, Engineering, Manufacturing, Painting/Lining, Testing, Supply with all accessories required for the system.

The above requirements are to be confirmed in the pre-order stage

3. NON-METALLIC TANKS :

The specifications of the requirements are as listed below:

REFER ATTACHED DATASHEETS (FRP & PP TANKS)

LOCATION:

- Place Navi Mumbai, Maharashtra
- Location Indoor (under Shed)
- Hazardous classification.... Safe Area
- Site Elevation (consider for Navi Mumbai, Maharashtra)
- Design Temperature 45 deg Celsius

 Water Technologies & Solutions	Project No.	508782
	Project	'Wastewater Treatment Plant – ETP/STP/RO/ZLD System
	Customer	'M/s. Sandoz. Pvt. Ltd.

4. PAINTING:

Painting shall be as per manufacturer standard and it should suitable for the intended application for outdoor coastal condition.

Color : RAL 5019 Capri Blue

5. DIVISION OF RESPONSIBILITY:

S. No.	Description	Sub-Contractor / Vendor	Buyer (SWTS)	Remarks
A	DESIGN AND ENGINEERING			
1.	Process Engineering		√	
2.	Basic Mechanical Engineering		√	
3.	Detail Mechanical Engineering	√		Supplier to provide • Mech. Data sheets • Mechanical GAD
4.	Basic Civil Engineering	√		Supplier to provide: • Eqpt. Load • Insert plate details • Anchor fastener
5	Recommended chemical dosing	-		NIL
6.	Detail Civil Engineering			By End customer
7.	Procurement of raw material and components	√		
8.	Fabrication, assembly and accessories.	√		
B	MECHANICAL			
1.	Complete System along with all internal components and accessories suitable to install.	√		Supplier to confirm compatibility of MOC for various components for the system.
2	Supports, nuts, inserts, embedded plates etc., as required.	√		Supplier to confirm compatibility of MOC for various components for the system.
3	Matching flanges (in case of flanged pipe joints) with all	√		Supplier to confirm compatibility of MOC for

 Water Technologies & Solutions	Project No.	508782
	Project	'Wastewater Treatment Plant – ETP/STP/RO/ZLD System
	Customer	'M/s. Sandoz. Pvt. Ltd.

S. No.	Description	Sub-Contractor / Vendor	Buyer (SWTS)	Remarks
	bolts, nuts, gaskets etc., required for connection			various components for the system.
D	CONTROL & INSTRUMENTATION			NIL
E	OTHERS			
1.	Civil works including foundation, Platform			By End customer/Buyer-
2.	Building			By End customer/Buyer-
3.	Embedded material		√	
4.	Spares	√		Scope as in above specs
5.	Shop Test and Inspection	√		Vendor to provide their QAP/ITP
6.	Shop Painting	√		As per Suez painting spec.
8.	Transport to site		√	
9.	Erection at site		√	
10.	Site test		√	
11.	Commissioning & Site Tests	√		
12.	Supervision for Erection and Commissioning		√	
13.	Initial charge of lubricants and consumables			NIL
14.	Approval from Local Statutory Authority (if any)			If applicable will be done by END CUSTOMER /BUYER-
F	Miscellaneous			
1.	Name plate	√		English
2.	Lifting lugs, lashing and reinforcement devices for transportation	√		
3.	Hoist & chain block for erection (if require)		√	
5.	Cables and trenches			By End customer
6.	O&M Manual in English language	√		

6. WARRANTY/GUARANTEE

- As per PO

 Water Technologies & Solutions	Project No.	508782
	Project	'Wastewater Treatment Plant – ETP/STP/RO/ZLD System
	Customer	'M/s. Sandoz. Pvt. Ltd.

7. LIST OF DOCUMENTS TO BE SUBMITTED:

7.1 PRE-ORDER STAGE:

1. Inspection test plan compliance
2. Acknowledgment to RFQ
3. Deviation to RFQ specs with reasons if any.

7.2 POST ORDER STAGE:

1. GA drawing of tanks.
2. Detail fabrication drawing
3. Thickness Calculation
4. Inspection test plan in-line with RFQ ITP
5. Lifting Drawing
6. Lifting/handling procedure
7. Manufacturing & delivery schedule

DOCUMENTS PRIOR TO SUPPLY:

1. As-built General Arrangement Drawing
2. As-built Fabrication Drawing
3. As-built calculations
4. Inspection dossier and release notes
5. Manufacturing & Delivery Schedule
6. Manufacturing Progress report
7. Guarantee / Warranty certificate
8. Packing list
9. Dispatch documents
10. Material traceability certificates
11. Final product photos before & after packing

8. ATTACHMENTS:

- Technical datasheets for non-metallic tanks
- FRP Tanks - ITP

