

PERMIT TO WORK - CLOSE-OUT OBSERVATION

Oil India Limited | Duliajan | Permit 26165/PTW/0142

Installation: Oil Collecting Station No. 4 Date: 2026-01-27

Activity: Replacement of the crude booster pump mechanical seal

OBSERVATION RECORDED AT CLOSE-OUT

The permit was closed at 1740 hrs with the electrical isolation still in place but the isolation certificate was not returned and the lock box held only two of the four padlocks listed. The pump was energised for a trial run while a fitter was still refitting the coupling guard, and no test for dead was carried out on the motor terminals before the guard work began.

ADDITIONAL NOTE

The gas test recorded on the permit was taken at 0900 hrs and was not repeated after the lunch break, although the permit requires four-hourly testing in the pump house.

Raised by: Shift Supervisor, OCS-4 Reviewed by: HSE Officer