GOVERNMENT PROCUREMENT TENDER SPECIFICATION

Tender Ref: CPWD/DELHI/FLY-03/2026/01 | Dept: Central Public Works Department (CPWD) - Flyo

Supply of High Yield Strength Deformed TMT Steel Rebars for Flyover Pier Caps

GOVERNMENT OF INDIA - CENTRAL PUBLIC WORKS DEPARTMENT

NIT No: CPWD/DELHI/FLY-03/2026/01

Project: Construction of 6-Lane Elevated Corridor and Flyover Interchange

SECTION IV - TECHNICAL SPECIFICATIONS FOR REINFORCEMENT STEEL:

1. MATERIAL SPECIFICATIONS:

Supply of High Strength Deformed Steel Bars for concrete reinforcement in pier caps, deck slabs, and retaining walls.

The steel rebars must strictly conform to IS 1139:1966 for cold twisted steel bars.

2. APPROVED BRANDS & RESTRICTIONS:

Materials shall be procured exclusively from primary producers only: Tata Tiscon or Jindal Panther or SAIL. Rebars from secondary re-rollers or unapproved brands will be summarily rejected.

3. MECHANICAL AND CHEMICAL PARAMETERS:

- Grade: Fe 500D (Ductile grade for seismic zone IV construction).
- Nominal Diameters: 12 mm, 16 mm, 20 mm, 25 mm, and 32 mm.
- Yield Strength (0.2% proof stress): Minimum 500.0 N/mm2.
- Tensile Strength: Minimum 565.0 N/mm2 (Tensile to Yield ratio >= 1.10).
- Percentage Elongation at Fracture: Minimum 16.0%.
- Total Elongation at Maximum Force: Minimum 5.0%.
- Carbon: Maximum 0.25%, Sulphur: Maximum 0.040%, Phosphorus: Maximum 0.040%, (S+P) max 0.075%.
- Each bundle must bear manufacturer BIS Standard Mark certification under the Mandatory Steel Quality Control Order.