GOVERNMENT PROCUREMENT TENDER SPECIFICATION

Tender Ref: JJM/PHED/PIPE-HDPE/2026/142 | Dept: Jal Jeevan Mission - Public Health Engineerin

Procurement of HDPE Pipes for Rural Piped Drinking Water Supply

JAL JEEVAN MISSION - PUBLIC HEALTH ENGINEERING DEPARTMENT

Tender No: JJM/PHED/PIPE-HDPE/2026/142

Sub-Mission: Har Ghar Jal Rural Water Supply Network

SCHEDULE OF REQUIREMENTS:

1. SCOPE OF SUPPLY:

Supply and delivery of High Density Polyethylene (HDPE) solid wall pipes for pressurized conveyance of potable drinking water from headworks to village distribution networks.

2. TECHNICAL CHARACTERISTICS:

- Raw Material: 100% virgin pre-compounded PE 100 polyethylene granules with carbon black content 2.0% to 2.5% uniformly dispersed.
- Nominal Outside Diameter (DN): 110 mm.
- Standard Dimension Ratio: SDR 17.
- Pressure Rating: PN 10 (1.0 MPa working pressure at 27 deg C).
- Minimum Required Strength (MRS): 10.0 MPa.
- Hydrostatic Strength: No rupture or burst during 100 hours test at 20 deg C at 12.4 MPa induced hoop stress, and 165 hours test at 80 deg C.
- Melt Flow Rate (MFR): Between 0.2 and 1.4 g/10 min at 190 deg C / 5 kg load.
- Pipes must possess mandatory BIS ISI certification as per the DPIIT Polyethylene Material Quality Control Order.