

Name of Sub-station : UNIVERSITY ROAD
Sub-station Code No : 1633

	Active Energy				Load In			Current in Amp.			Voltage in kV			Reactive Energy										
Time	Energy Import	Diff MWh	Energy Export	Diff MWh	MW(l)	MW (E)	MVA	Ir	Iy	Ib	Vry	Vyb	Vbr	Q1	Diff in MVArh	Q2	Diff in MVArh	Q3	Diff in MVArh	Q4	Diff in MVArh	Freque ncy(Hz)	Power Factor	
Feeder Name	11KV PARAS				Meter Sr No			LT005177			Class of Voltage			11KV			Code no of Feeder			05505216331LO2206			Date: 31-08-2026	
00:00	1649.4000	0.0000	36163.8200	0.8600	-	0.9262	0.9262	47.03	46.49	45.32	11.493	11.642	11.513	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0517	0.0000	50.00	1.00	
01:00	1649.4000	0.0000	36164.6800	0.7800	-	0.8068	0.8074	40.11	39.21	40.34	11.634	11.727	11.635	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0517	0.0000	50.01	1.00	
02:00	1649.4000	0.0000	36165.4600	0.7400	-	0.7524	0.7534	38.59	37.07	37.21	11.650	11.723	11.654	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0517	0.0000	49.95	1.00	
03:00	1649.4000	0.0000	36166.2000	0.6800	-	0.7046	0.7054	35.49	33.36	35.13	11.711	11.797	11.713	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0517	0.0000	50.01	1.00	
04:00	1649.4000	0.0000	36166.8800	0.6600	-	0.7166	0.7170	35.27	35.20	35.26	11.719	11.833	11.736	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0518	0.0000	50.01	1.00	
05:00	1649.4000	0.0000	36167.5400	0.7000	-	0.6726	0.6742	33.71	33.29	33.05	11.653	11.790	11.680	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0518	0.0000	50.08	1.00	
06:00	1649.4000	0.0000	36168.2400	0.7000	-	0.7050	0.7062	33.90	36.27	36.53	11.488	11.607	11.496	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0518	0.0000	50.07	1.00	
07:00	1649.4000	0.0000	36168.9400	0.6600	-	0.7160	0.7174	35.73	38.20	35.30	11.376	11.436	11.373	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0519	0.0000	50.04	1.00	
08:00	1649.4000	0.0000	36169.6000	0.3600	-	0.6178	0.6186	32.20	34.28	31.30	11.049	11.110	11.042	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0519	0.0000	50.12	1.00	
09:00	1649.4000	0.0400	36169.9600	0.1400	-	0.4174	0.4188	22.62	23.32	21.52	10.810	10.862	10.847	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0519	0.0000	50.15	1.00	
10:00	1649.4400	0.4000	36170.1000	0.0200	-	0.1484	0.1496	10.98	9.18	7.68	10.632	10.610	10.640	0.1981	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	50.01	0.99	
11:00	1649.8400	0.3200	36170.1200	0.0200	0.4460	-	0.4462	20.54	21.91	25.17	10.959	10.978	10.964	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	50.03	-1.00	
12:00	1650.1600	0.3400	36170.1400	0.0000	-	0.1662	0.1680	10.26	9.36	8.31	11.080	11.112	11.107	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	50.07	0.99	
13:00	1650.5000	0.2800	36170.1400	0.0400	0.9082	-	0.9112	45.34	42.68	48.84	11.592	11.589	11.624	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	50.12	-1.00	
14:00	1650.7800	0.2000	36170.1800	0.0800	0.1274	-	0.1294	0.00	7.49	8.79	11.286	11.283	11.310	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	49.97	0.98	
15:00	1650.9800	0.1600	36170.2600	0.0600	-	0.3278	0.3308	16.09	17.89	18.91	11.058	11.089	11.088	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	49.92	0.99	
16:00	1651.1400	0.0000	36170.3200	0.2600	0.1562	-	0.1650	8.58	8.65	11.03	11.110	11.174	11.136	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	50.01	0.95	
17:00	1651.1400	0.0000	36170.5800	0.5400	-	0.3330	0.3362	19.23	17.86	15.77	11.232	11.282	11.269	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0520	0.0000	50.08	0.99	
18:00	1651.1400	0.0000	36171.1200	0.6800	-	0.6186	0.6196	29.91	32.28	32.25	11.389	11.433	11.406	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0521	0.0000	50.13	1.00	
19:00	1651.1400	0.0000	36171.8000	0.7400	-	0.7238	0.7252	35.75	39.01	35.91	11.246	11.303	11.255	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0521	0.0000	49.94	1.00	
20:00	1651.1400	0.0000	36172.5400	0.7800	-	0.7296	0.7322	36.28	39.17	36.66	11.339	11.392	11.340	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0521	0.0001	50.06	1.00	
21:00	1651.1400	0.0000	36173.3200	0.8200	-	0.8160	0.8188	40.29	42.59	41.88	11.378	11.447	11.403	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0522	0.0001	50.00	1.00	
22:00	1651.1400	0.0000	36174.1400	0.8800	-	0.8544	0.8560	41.95	44.84	43.24	11.370	11.485	11.385	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0523	0.0000	50.05	1.00	
23:00	1651.1400	0.0000	36175.0200	0.9400	-	0.9426	0.9428	45.25	48.69	49.55	11.351	11.458	11.351	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0523	0.0000	50.04	1.00	
00:00	1651.1400	0.0000	36175.9600	0.8600	-	0.9086	0.9092	45.55	46.09	45.61	11.412	11.512	11.422	0.1982	0.0000	0.0839	0.0000	2.8199	0.0000	1.0523	0.0000	50.00	1.00	
Max Value	1651.1400	0.4000	36175.9600	0.9400	0.9082	0.9426	0.9428	47.03	48.69	49.55	11.719	11.833	11.736	0.1982	0.0000	0.0839	0.0000	2.8199	-	1.0523	0.0001	50.15	1.00	
Max Time	16:00	10:00	00:00	23:00	13:00	23:00	23:00	00:00	23:00	23:00	04:00	04:00	04:00	16:00	10:00	14:00	11:00	00:00	-	00:00	21:00	09:00	00:00	
Min Value	1649.4000	0.0400	36163.8200	0.0200	0.1274	0.1484	0.1294	8.58	7.49	7.68	10.632	10.610	10.640	0.1981	-	0.0839	-	2.8199	-	1.0517	-	49.92	-1.00	
Min Time	00:00	09:00	00:00	10:00	14:00	10:00	14:00	16:00	14:00	10:00	10:00	10:00	10:00	00:00	-	00:00	-	00:00	-	00:00	-	15:00	11:00	