

FUEL ANALYSIS REPORT

Report No:12345

VESSEL – TEST VSL (IMO Number: 99999)

STATUS: OFF SPEC

Sample ID: 11111

SEAL DATA:	161616-Seal Intact
1st COUNTER SEAL:	NO SEAL
2nd COUNTER SEAL:	NO SEAL
BUNKER INFO DOCUMENT:	B.D.N
DOCUMENT NO:	25404
INDICATED Density @ 15 Deg C:	948.1 Kg/m3
INDICATED Sulphur:	0.471 % mass
INDICATED Flash Point:	80 Deg C
INDICATED Water:	0.3 % volume
SENT FROM:	N/A
AWB NO:	DHL, 12345
DATE RECEIVED:	03-Jul-25
ANALYSIS DATE:	04-Jul-25
REPORT DATE:	04-Jul-25

ISO 8217:2017, Table 2, RMG 380	Job UID: SAMPLE12345-TYPE-001-01	Analysis Date: 04-Jul-2025
---------------------------------	----------------------------------	----------------------------

#	Characteristic(s)	Unit	Limit	Test Result	Test Method
1	Water (Coulometric Karl Fischer)	volume %	0.50 Max	0.7	ASTM D6304-20