BACnet at a glance

What a BACnet controller exposes, and how a supervisor finds it.

A Temco controller speaks BACnet so that a building supervisor can read it without knowing anything about Temco tools. This version documents the object model and the addresses; the wiring is Test1's business.

What a supervisor sees

Every point the controller holds is an object with an instance number. A supervisor reads a point by asking for its object identifier, which is the type and the number together — one 16-bit word, and the only addressing a BACnet device needs.

Finding it

A controller answers a **Who-Is** with an **I-Am**, which carries its device instance and its address. That is the whole discovery mechanism: no scan, no port number, no host name.

Where to go next

- Points — the object types this version exposes, and what each one is for