T3000 Engineering

TestTool: recording data · built Nov 13, 2026

TestTool: recording data

Capturing a session of live point values so that a fault which has already passed can still be looked at.

Download TestTool.exe


Please Update your T3000 software to fix this bugs .


Help->Check for updates ->Update T3000 .

The T3000.exe directory will contain the latest version of TestTool.exe


https://temcocontrols.com/ftp/software/20T3000Update.zip

You can also download it directly from here and extract it to any directory






Select Function 1. Register Monitor



Connect your device




Fill in the Modbus ID, register, sampling time, data type that you want to monitor

Click the "+" sign to add a line

Input 1 value = (Reg7484 * 65536 + Reg7485) / 1000


If it is a combination of two registers, please fill in "Register" with something like 7484-7485, or use the register number if it is a single register.



Click start to start recording


When the recording ends, an access database is generated in the TestTool.exe directory with the current date. Click Draw Graphic to select the database to draw the image

Select the row that you want to draw



You can also open *.mdb directly to see the results

LoggingTime	DEVICEID	REGISTERNUM	Data_Value
1733456739	255	95	88526
1733456733	255	95	88520
1733456727	255	95	88514
1733456721	255	95	88509
1733456715	255	95	88503
1733456710	255	95	88497
1733456704	255	95	88491
1733456698	255	95	88485
1733456692	255	95	88479
1733456686	255	95	88474
1733456680	255	95	88468
1733456675	255	95	88462
1733456669	255	95	88456
1733456663	255	95	88450
1733456657	255	95	88444
1733456651	255	95	88439


Dialog
ID255_REG95
8706
ID255_REG7496
16
ID255_REG7498
16
Auto Scroll
ON
30
26
22
18
14
10
12/04 15:15
12/05 14:53
12/06 14:30
12/07 14:07
12/08 13:44
12/09 13:21