ConvertClass Pro	onerties								
General	speries								
Name	ConvertClass	Number	3		Туре	FC		Language	LAD
Numbering	Automatic								
Information									
Title	ConvertClass	Author			Comment			Family	
Version	0.1	User-defined ID							
Name				Data type	9		Default value		
Input									
Output									
InOut									
▼ Temp									
Output_PI	D_Real			Real					
PV				Real					
SP				Real					
SPRamp				Real					
Constant									
▼ Return									
ConvertCla	ass			Void					

SCALE_X Real to Real

SCALE_X Real to Real

0.0 — MIN #PV — VALUE

300.0 — MAX

EN -

0.0 — MIN

10.0 — MAX

#Output_PID_Real — VALUE

- ENO -

ENO:

%QD30 OUT — "O_FillValve"

"VisuData".Level
— MeterShow

Network 2: Convert LevelMeter: 0-10 -> 0-300

NORM_X Real to Real

NORM_X Real to Real

0.0 — MIN

10.0 — MAX

0.0 — MIN

27648.0 — MAX

VALUE

"ControllerData". Output_PID_ Compact ___

%ID30
"I_LevelMeter" — VALUE

Network 3: Convert Output_PID_Compact: 0-27648 -> 0-10

OUT -#PV

ENO

OUT — #Output_PID_Real