Lab 1.2 source pack

All records are fictional training data. They describe no actual facility, person or organisation. Values are teaching assumptions, not approved design criteria. Do not use outputs to operate, maintain or approve real equipment.

problem-statement.txt

TRAINING CASE PS-17 revision 1
At fictional pump station PS-17, operator A logged intermittent low delivery on 2026-08-17. P-101 duty pump was running. Indicated flow fell from 48 to 32 m3/h at 09:12 and returned to 47 at 09:20. Discharge gauge read 3.1 bar at 09:15. No suction pressure was recorded. Strainer cleaning was mentioned but no work order was attached. Operator B heard an unusual vibration; no instrument reading exists. The standby pump availability is unconfirmed. A draft email says replace the pump today. The supervisor asks for a brief by 16:00: facts, hypotheses, missing evidence, safe next review and owner. No cause has been established.

claim-register.csv

claim: Nominal flow is 50 m3/h; source: DES-01; version: rev2; clause_or_page: 2; verified_by: ; status: Pending

claim: Material is confirmed; source: No source; version: ; clause_or_page: ; verified_by: ; status: Unsupported