Lab 1.1 source pack

All records are fictional training data. They describe no actual facility, person or organisation. Values are teaching assumptions, not approved design criteria. Do not use outputs to operate, maintain or approve real equipment.

access-check.csv

application: Copilot Chat; check: Corporate tenant and chat available; result: ; follow_up:

application: Word; check: Copilot can draft from fictional notes; result: ; follow_up:

application: Excel; check: Copilot available with training workbook; result: ; follow_up:

application: PowerPoint; check: Copilot available for summary; result: ; follow_up:

application: Teams; check: Approved meeting content access; result: ; follow_up:

application: Agent Builder; check: New agent and test available; result: ; follow_up:

application: Researcher; check: Agent available; result: ; follow_up:

application: Analyst; check: Agent available; result: ; follow_up:

application: SharePoint; check: Training library edit access; result: ; follow_up:

problem-statement.txt

TRAINING CASE PS-17 revision 1
At fictional pump station PS-17, operator A logged intermittent low delivery on 2026-08-17. P-101 duty pump was running. Indicated flow fell from 48 to 32 m3/h at 09:12 and returned to 47 at 09:20. Discharge gauge read 3.1 bar at 09:15. No suction pressure was recorded. Strainer cleaning was mentioned but no work order was attached. Operator B heard an unusual vibration; no instrument reading exists. The standby pump availability is unconfirmed. A draft email says replace the pump today. The supervisor asks for a brief by 16:00: facts, hypotheses, missing evidence, safe next review and owner. No cause has been established.