DES-01-rev2

DES-01 Pump design note revision 2
Fictional training reference. Effective 2026-08-01. Supersedes revision 1.
Clause 2 Duty
Nominal delivery is 50 m3/h at 30 m head.
Clause 3 Classroom acceptance
The teaching acceptance band is plus or minus 5 percent of nominal delivery, hence 47.5 to 52.5 m3/h. Record three readings at agreed duty, instrument identity and witness. This is not a published engineering standard.
Clause 4 Materials
Wetted materials remain TBD pending fluid identification and compatibility review.
Clause 5 Release
Responsible engineer review is required before any real-world use.