Transport Planning, Development & Streetworks Management
Wat Tyler West, 5th Floor,
Beckhampton Street,
Swindon, SN1 2JH

**Transport Development Management**

# Memo

To: Planning Services
From: Transport Development Management
Date: 9th January 2023

---

**Application Number:** S/COND/22/0031

**Proposal:** Discharge of condition 8 (Strategic Design Code) from Outline Planning Permission S/OUT/13/1555.

**Location:** Land North Of A420 Eastern Villages

Ed,

Condition 8:
*Prior to the submission of the first reserved matters a Strategic Design Code shall have been submitted to and approved in writing by the Local Planning Authority. The Strategic Design Code shall:*
*a) Develop the vision, design concept, principles and frameworks described in the Design and Access Statement (February 2017);*
*b) Identify the character areas across the site, including the design approach, character area identity and public realm;*
*c) Explain how the design principles for the character areas including the local centres will be applied and co-ordinated across the site;*
*d) Principles to identify how a net biodiversity gain will been achieved across the site; and,*
*e) Set out landscape principles to ensure the green infrastructure framework (including open space) will make a positive contribution to the public realm, SuDS, movement network, the amenity of residential areas and the reduction of pollution.*
*Thereafter the reserved matters submissions for each phase shall demonstrate how the development*

All previous comments, with the exception of the two below, have now been included within the document.

Page 93, 103, 105, 106, 109 – Due to the height difference between the route and the swale, mitigation to prevent falls may be required, depending on the depth of the swale. The designer would need to risk assess and propose mitigation where required. Provision of a minimum 0.5m wide berm, with a shallow swale, should absolve fall risk.

Page 98, A 400m isochrome as a 5 minutes walking distance is 'as the crow flies'. A 300m isochrome is a realistic 5 minute walking distance. The interim bus stop locations are welcomed. If appropriate the turning heads should be illustrated with the phasing strategy.

No highway objection is raised.

Please note that the comments made here represent Officer Opinion and cannot be seen to prejudice Swindon Borough Council's formal determination in relation to any application or planning matter.

**Alison Curtis**
**Senior Transport Development Management Engineer**

Transport Planning, Development & Streetworks Management

Swindon Borough Council

Email: acurtis@swindon.gov.uk
Tel: 07341 077566
Web: www.swindon.gov.uk