From:	Edward Snook
To:	Scanning
Subject:	FW: S/COND/22/0711 - Discharge of Condition 40 and 41: resubmission of documents
Date:	16 May 2023 16:23:51
Attachments:	image001.png image003.png image005.png image008.png image009.png image010.png image011.png

---

From: Sam Wood <SWood@DavidLock.com>
Sent: 16 May 2023 10:27
To: Edward Snook <ESnook@swindon.gov.uk>
Cc: siobhan.murphy@brookbanks.com; Richard Bennett <RBennett2@swindon.gov.uk>; Francesca Parmenter <FParmenter@davidlock.com>; Tanya Cosford <TCosford@DavidLock.com>
Subject: S/COND/22/0711 - Discharge of Condition 40 and 41: resubmission of documents

> **Caution:** This email originated outside SBC . Please take care when clicking links or opening attachments. When in doubt, contact your IT Department on x4900

Ed,

Please follow the WeTransfer link (https://we.tl/t-QQJCXIqNZi) for the updated drainage reports in relation to Condition 40 (Flood Mitigation) and Condition 41 (Surface Water – Full Site). The reports included as part of this submission are to supersede those previously submitted to Swindon Borough Council in December 2022. A summary of the changes provided are set out below:

C40: Flood Mitigation (1335 TN39 R8-Condition 40 Flood Mitigation)

- Identification of mitigation works 1-8 on drawing no. 1335-SK-117 to show the extent of flood mitigation (p20) to reference mitigation area back to the list of items on the original FRA.
- We agreed that area 6 and 8 will be carried out as part of works within Rowborough.

C41: Surface Water - Full Site (1335 SW Drainage Report rev3.1 ISSUED_Part1 – Part5)

Since submitting the application, we have been in discussion with the LLFA, as well as having held several workshops to agree a water drainage strategy, including the location of surface water flow routes and review of the proposed flow rates, catchment areas and subsequent required volumes including consideration for 10% urban creep. These discussion have led to amendments to the report, including:

- Minor changes to text – these are shown in blue.
- Additional wording re existing ponds (to be incorporated in SuDs) and confirmation that any sediment will be removed/disposed of (p8).
- Topographical survey included at appendix A (p29)
- Detailed basin calculations included in appendix F (p34)
- Confirmation that swales and basins will sit outside of flood zone 2 and 3, where swales are sited within flood zones they will act as conveyance only (p12 and p14).
- Clarification on outfall consents (p15)
- Updates to drawing no. 1335-SK-114F to include top and bottom levels of basins (p36)
- Updates to drawing no. 1335-SK-111C to include topographical information on flood zone depths by basin C (p38)

The updated report submitted to discharge Condition 41 includes changes shown in blue, for your ease in reviewing the document, we would therefore ask, that we can submit a formatted report prior to the issue of the decision notice.

Kind regards

Sam

Sam Wood
Assistant Planner

+44 (0) 1908 666276 | +44 (0) 7494 766479
swood@davidlock.com
davidlock.com

David Lock Associates Limited
50 North Thirteenth Street | Central Milton Keynes | MK9 3BP

DAVID LOCK ASSOCIATES