

# Effect of Governor Deadbands on Valve Travel using Long-Term Dynamic Simulation

Thad Haines and Matt Donnelly  
School of Mines and Engineering  
Montana Technological University  
Butte, Montana 59701

**Abstract**—This paper investigates the impact of governor deadbands on valve travel using a novel long-term dynamic (LTD) simulation software environment. The Python based LTD software utilizes a commercial power-flow solver to execute a sequence of power flows that is shown to capture long-term power system dynamics with acceptable accuracy. While classic transient stability simulation is sufficient for investigating the impact of governor deadbands on primary frequency response, LTD software is needed for analyzing the impact of governor deadbands on fuel valve travel over longer periods of time. The presented LTD software enables simulations from tens of minutes to hours on full system base cases. Cumulative valve travel is proposed as a metric for evaluating the impact of various deadband settings. It is shown that use of specific governor deadband settings can actually increase cumulative valve travel over what would be expected without a deadband.

**Index Terms**—Governor deadband, long-term dynamic simulation, time-sequenced power flow, valve travel

## I. INTRODUCTION

Deadbands are commonly implemented in turbine speed governors to prevent a machine from responding to small frequency deviations that are ever present in electrical systems. The North American Electric Reliability Corporation (NERC) has shown benefits of modifying governor deadbands and recommended deadband settings in [1] that the Federal Energy Regulatory Commission (FERC) has adopted as FERC Order 842[2]. Industry usage of deadbands is widely known, however, it is often overlooked in power system simulation. Incorporating governor deadbands into transient simulation models has been shown to generate results that better match measured power system events[3]. While transient stability simulation is useful for the study of primary frequency response, there is little understanding of the impact governor deadbands may have on valve travel in the long-term. Due to the time frame of focus involved with classical transient stability (CTS) simulation, the development of a simulation environment capable of simulating tens of minutes to hours is required. Long-term dynamic (LTD) simulation software focusing on governor dynamics was proposed in [4] and others, but has not been standardized nor fully developed. The use of a single swing equation was proposed in [5] for solving the equations of motion involved with an aggregated system inertia. Using this concept, the aggregate system frequency response can be reasonably captured. In this work, the authors take the concept further to enable the study of governor

deadbands over a much longer simulation duration than can be reasonably accomplished with CTS simulation.

This paper explores the impact of governor deadbands using a novel LTD simulation environment based on GE Energy's Positive Sequence Load Flow (PSLF) system models, dynamic data, and load flow solver. Valve travel as a metric for comparing the impact of various deadband scenarios is proposed. Section II describes the LTD simulation environment used to perform the studies while Section III discusses governor and deadband modeling within the simulation environment. In Section IV, the LTD simulation is validated against mature transient stability simulation. Finally, Section V presents some initial results demonstrating the viability of the proposed valve travel metric and Section VI offers conclusions.

## II. LONG-TERM DYNAMIC SIMULATION TECHNIQUE

Time-sequenced power flow (TSPF) is a method for LTD simulation proven to generate useful results[6]. The basic idea behind TSPF is to solve a power flow, represent system dynamics of interest independent of the power flow solver, 're-seed' the power flow with new values, and repeat. A python based simulation software, Power System Long-Term Dynamic Simulator (PSLTDSim), has been developed to perform LTD simulations using TSPF. PSLTDSim has the ability to calculate system frequency, perform governor dynamics, model automatic generation control (AGC), and insert step, ramp, and noise type perturbances into a power system.

### A. Simulation Assumptions and Simplifications

Due to the relatively large time steps of 1 second used with TSPF, numerous assumptions can be made. Ideal exciters were assumed as modern exciters are typically fast enough to maintain reference voltage under stable conditions. Intermachine oscillations were ignored since the time resolution used is not fine enough to capture these phenomena.

Simplifications of transient stability models are used in PSLTDSim. The only parameters required to model a generator are MW cap, MVA base, and machine inertia. Additionally, a deadband modified tgov1 governor model, Fig. 1, was created to model system governors.

### B. Modeling the System-Wide Frequency Response

Instead of frequency being calculated for every bus, a combined swing equation is used to model only one system




Fig. 1. Block diagram of modified tgov1 model.

frequency. As shown in (1), accelerating power from the entire system, as well as total system inertia  $H_{PU,sys}$ , is used to calculate  $\dot{\omega}_{sys}$ .

$$\dot{\omega}_{sys} = \frac{1}{2H_{PU,sys}} \left( \frac{P_{accPU,sys}}{\omega_{sys}} - D_{sys}\Delta\omega_{sys} \right) \quad (1)$$

### C. Distribution of Accelerating Power

In a system with  $N$  generators, total system accelerating power is calculated by

$$P_{acc,sys} = \sum_{i=1}^N P_{m,i} - \sum_{i=1}^N P_{e,i} \quad (2)$$

where  $P_{m,i}$  is mechanical power and  $P_{e,i}$  is electrical power of generator  $i$ .

System accelerating power is distributed to all generators in the system according to machine inertia as

$$P_{e,i} = P_{e,i} - P_{acc,sys} \left( \frac{H_i}{H_{sys}} \right) \quad (3)$$

where  $H$  has units of  $MW \cdot s$ .

The new value for  $P_{e,i}$  is used in the next power flow solution for each generator. If the difference between expected and resulting power supplied by the slack generator is larger than a set slack tolerance, the difference is redistributed according to (3) until the resulting difference is below the slack tolerance, or a maximum number of iterations take place[5].

## III. IMPLEMENTATION OF DEADBANDS

FERC requirements for governor droop and deadband are 5% and 36 mHz respectively[2]. However, practical implementation is left to generator operators.

### A. Types of Deadbands

Fig. 2 presents implementations of deadbands that follow FERC requirements. If a governor has no deadband, a change in output power is requested for any frequency deviation. A step deadband ignores any frequency smaller than the setpoint  $\pm db_1$  and then steps to meet the set droop curve. A no-step deadband pushes the original droop curve away from the nominal frequency allowing for the droop curve to cross zero at  $\pm db_2$  but never return to the step or no deadband droop curve. A non-linear deadband is introduced that linearly increases from  $\pm\alpha$  to  $\pm\beta$ , after which it follows the original droop curve.




Fig. 2. Different types of deadbands.

## IV. SIMULATION VALIDATION

To validate the chosen simulation approach, identical system perturbances were performed in the PSLF Dynamic Subsystem (PSDS) and PSLTDSim. Frequency was compared to validate the single system frequency assumption calculated by PSLTDSim, and governed generator mechanical power was compared to validate governor action.

Comparison of frequency data from PSDS to LTD was simplified by calculating a single weighted PSDS frequency  $f_w$  based on generator inertia. In a system with  $N$  generators

$$f_w = \sum_{i=1}^N f_i \frac{H_{PU,i} M_{base,i}}{H_{sys}} \quad (4)$$

$$\text{where } H_{sys} = \sum_{i=1}^N H_{PU,i} M_{base,i}. \quad (5)$$

### A. The MiniWECC System

The power system used for validation and valve travel experiments, the miniWECC shown in Fig. 3, is a 120 bus 34 generator system created in PSLF. All 21 governors in the miniWECC are modeled with the tgov1 which enabled easier validation. Further details about the creation and use of the miniWECC may be found in [7]–[9].

1) *Load Step Results:* A 400 MW load step was simulated to occur at 2 seconds. As shown in Fig. 4, all individual PSDS frequencies begin to oscillate after the perturbation while the weighted PSDS frequency appears to follow the general center of oscillation. The LTD system frequency is less oscillatory than the weighted frequency with only minor differences between the two. Fig. 9 quantifies these frequency differences.

When comparing mechanical power in Fig. 6, large MW differences can be seen, however, the percent difference data in Fig. 7 shows results less than 5% max difference, and an average percent difference of less than  $\approx 0.5\%$ .




Fig. 3. MiniWECC system adapted from [9].




Fig. 4. Comparison of frequency during load step.




Fig. 5. Absolute difference of weighted frequency during load step.




Fig. 6. Difference of mechanical power during load step.




Fig. 7. Percent difference of mechanical power during load step.




Fig. 8. Comparison of frequency during load ramp.




Fig. 9. Absolute difference of weighted frequency during load ramp.

2) *Load Ramp Results:* Simulation results from a 40 second 400 MW load ramp in Figs. 8-9 show frequency of LTD being within 1.5 mHz of PSDS. Fig. 10 shows mechanical power differences of less than  $\pm 10$  MW or, as Fig. 11 shows, 1% difference max.

## B. Validation Summary

The step test results show that PSLTDSim is not meant to simulate large transient events with great accuracy. However, repeated small perturbances are modeled with acceptable de-




Fig. 10. Difference of mechanical power during load ramp.




Fig. 11. Percent difference of mechanical power during load ramp.

viation from transient simulation methods.

## V. INITIAL RESULTS

Thirty minutes of random load noise was applied to the system where every governor in the system had an identical deadband. Each type of deadband shown in Fig. 2 was simulated. An experiment was also conducted to explore partial acceptance of the NERC recommendations presented in [1]. While PSLTDSim can model AGC, it was not enabled for these simulations.

### A. System Modifications

The miniWECC system was modified to include three areas for simulation. PSLTDSim was used to set all area governor droops to 5%. Some governors were removed from the system so that only  $\approx 20\%$  of generation capacity in each area had governor control.

### B. System Noise Injection

Every time step, noise is injected into each load  $P_{L,i}$  in the system according to

$$P_{L,i} = P_{L,i}(1 \pm N_Z \text{Rand}_i) \quad (6)$$

where  $N_Z$  represents the maximum amount of random noise to inject as a percent, and  $\text{Rand}_i$  is a randomly generated number between 0 and 1 inclusive. The decision to add or subtract noise is chosen by another randomly generated number. As described, (6) creates random walk behavior in load value that is representative of real power systems[4].

### C. Noise Simulation Results

$N_Z$  was set to 0.03 for all simulations. The change in system loading caused by the added noise is shown in Fig. 12. Fig. 13 shows the resulting system frequency for each type of deadband. The step deadband holds frequency almost exactly on the set deadband except when system loading decreases during minutes 7-11. The other deadband options maintain system frequency near their respective mHz setting until loading increases beyond a point near minute 17.




Fig. 12. Change in total system loading.




Fig. 13. System frequency response of various deadband scenarios.

The first three minutes of a single generators valve travel are shown in Fig. 14 to compare how different deadbands affect movement. A step deadband will send pulse train-esq control signals to the governor valve when system frequency is oscillating over the deadband. These repeated control pulses greatly increase valve travel over the more linear deadband options.

Table I summarizes the valve travel for each generator in the system over the entire 30 minute simulation. A step type deadband has the largest total travel while the no-step deadband has the least.

### D. Partial Acceptance Simulation Results

To test partial acceptance of NERC deadband recommendations, all area deadbands were set to the no-step variety, but two of the three areas had a deadband of 16.6 mHz while the third was set to 36 mHz. The resulting system frequency is shown in Fig. 15.




Fig. 14. Valve movement deadband comparisons.

TABLE I  
TOTAL VALVE TRAVEL FOR VARIOUS DEADBAND SCENARIOS.

Generator	Valve Travel [PU]				
	No DB	Step	No-Step	N-L Droop	No-Step Alt DB
17	0.16	7.48	0.15	0.23	0.19
23	0.16	7.48	0.15	0.23	0.19
30	0.16	7.48	0.15	0.23	0.19
32	0.16	7.54	0.15	0.23	0.19
107	0.16	7.54	0.15	0.23	0.19
41	0.15	6.44	0.14	0.23	0.06
45	0.15	6.44	0.14	0.23	0.06
53	0.16	7.54	0.15	0.23	0.06
59	0.15	6.44	0.14	0.23	0.06
Total:	1.41	64.38	1.32	2.07	1.19




Fig. 15. System frequency response to 0.03% load noise where no-step deadbands have different area settings.

As expected, the area with a larger deadband doesn't respond until after frequency drops below its deadband while the areas with smaller deadbands work to maintain frequency. Individual valve travel for each generator is shown in Table I under the 'No-Step Alt DB' column, and Fig. 16 shows average valve travel over time for each area. In this case, the governor valves with a smaller deadband travel three times more than those with a larger deadband.

## VI. CONCLUSION

PSLTDSim can be used to simulate long term dynamic events. Deadband configurations play a large role in dictating valve travel. A step deadband can lead to vastly increased valve travel compared to other, more linear, options. Smaller




Fig. 16. Average valve travel by area.

deadbands, as recommended by NERC, can reduce valve travel and help regulate frequency if adopted interconnection-wide. If only partial adoption of recommendations is made, machines with smaller deadbands will respond more than machines with larger deadbands.

## ACKNOWLEDGMENT

This material is based upon work supported by the U.S. Department of Energy, Office of Science, Basic Energy Sciences, under Award Number DE-SC0012671.

## REFERENCES

- [1] NERC, "Frequency response initiative report," North American Electric Reliability Corporation, 2012.
- [2] FERC, "Essential reliability services and the evolving bulk-power system—primary frequency response," Federal Energy Regulatory Commission, Docket No. RM16-6-000 Order No. 842, Feb. 2018.
- [3] G. Kou, P. Markham, S. Hadley, T. King, and Y. Liu, "Impact of governor deadband on frequency response of u.s. eastern interconnection," IEEE Transactions on Smart Grid, 2016.
- [4] C. W. Taylor and R. L. Cresap, "Real-time power system simulation for automatic generation control," IEEE Transactions on Power Apparatus and Systems, 1976.
- [5] M. Stajcar, "Power system simulation using an adaptive modeling framework," Master's thesis, Montana Tech, 2016.
- [6] E. Heredia, D. Kosterev, and M. Donnelly, "Wind hub reactive resource coordination and voltage control study by sequence power flow," IEEE, 2013.
- [7] D. Trudnowski, "Properties of the dominant inter-area modes in the wecc interconnect," Montana Tech, 2012.
- [8] J. Sanchez-Gasca, M. Donnelly, R. Concepcion, A. Ellis, and R. Elliott, "Dynamic simulation over long time periods with 100% solar generation," Sandia National Laboratories, SAND2015-11084R, 2015.
- [9] R. Hallett, "Improving a transient stability control scheme with wide-area synchrophasors and the microwecc, a reduced-order model of the western interconnect," Master's thesis, Montana Tech, 2018.