

Effect of Governor Deadbands on Valve Travel using Long-Term Dynamic Simulation

Thad Haines and Matt Donnelly
School of Mines and Engineering
Montana Technological University
Butte, Montana 59701

Abstract—Simulation of governor deadbands is typically ignored, however, deadband settings can greatly affect valve travel. A long-term dynamic simulation method is presented and validated against an industry standard transient simulator. Thirty minute simulations are conducted using a reduced-order WECC system model and resulting valve travel and system frequency are compared. NERC deadband recommendations are shown to reduce valve travel if adopted interconnection wide, but may increase the valve travel of machines in a system with only partial adoption.

Index Terms—Governor deadbands, long-term dynamic simulation, time-sequenced power flow, valve travel

I. Introduction

Deadbands are commonly implemented in turbine speed governors to prevent a machine from responding to small frequency deviations that are ever present in electrical systems. Industry usage of deadbands is widely known, however, it is often overlooked in power system simulation. Incorporating governor deadbands into transient simulation models has been shown to generate results that better match measured power system events[1]. Additionally, numerous long-term operational benefits have been attributed to the alteration of deadband behavior[2]. To better understand how deadbands may affect system behavior, a long-term simulation would seem suitable. Long-term dynamic (LTD) simulation software focusing on governor dynamics was proposed in [3] and others, but has not been standardized nor fully developed.

This paper explores the impact of governor deadbands using a novel LTD simulation environment based on GE Energy's Positive Sequence Load Flow (PSLF) system models, dynamic data, and load flow solver. Valve travel as a metric for comparing the impact of various deadband scenarios is proposed. Section II describes the LTD simulation environment used to perform the studies while Section III discusses governor and deadband modeling within the simulation environment. In Section IV, the LTD simulation is validated against mature transient stability simulation. Finally, Section V presents some initial results demonstrating the viability of the proposed valve travel metric and Section VI offers conclusions.

II. Long-Term Dynamic Simulation Technique

Time-sequenced power flow (TSPF) is a method for LTD simulation proven to generate useful results[4]. The

basic idea behind TSPF is to solve a power flow, perform system dynamics of interest, 're-seed' the power flow with new values, and repeat. A python based simulation software, Power System Long-Term Dynamic Simulator (PSLTDSim), has been developed to perform LTD simulations using TSPF. PSLTDSim has the ability to calculate system frequency, perform governor dynamics, model automatic generation control (AGC), and insert step, ramp, and noise type perturbances into a power system.

A. Simulation Assumptions and Simplifications

Due to the relatively large time steps of 1 second used with TSPF, numerous assumptions can be made. Ideal exciters were assumed as modern exciters are typically fast enough to maintain reference voltage under stable conditions. Intermachine oscillations were ignored since the time resolution used is not fine enough to capture these phenomena.

Simplifications of transient stability models are used in PSLTDSim. The only parameters required to model a generator are MW cap, MVA base, and machine inertia. Additionally, a deadband modified tgov1 governor model, Fig. 1, was created to model system governors.




Fig. 1. Block diagram of modified tgov1 model.

B. Modeling the System-Wide Frequency Response

Instead of frequency being calculated for every bus, a combined swing equation is used to model only one system frequency. As shown in (1), accelerating power from the entire system, as well as total system inertia $H_{PU,sys}$, is used to calculate $\dot{\omega}_{sys}$.

$$\dot{\omega}_{sys} = \frac{1}{2H_{PU,sys}} \left(\frac{P_{accPU,sys}}{\omega_{sys}} - D_{sys}\Delta\omega_{sys} \right) \quad (1)$$

C. Distribution of Accelerating Power

In a system with N generators, total system accelerating power is calculated by

$$P_{acc,sys} = \sum_{i=1}^N P_{m,i} - \sum_{i=1}^N P_{e,i} \quad (2)$$

where $P_{m,i}$ is mechanical power and $P_{e,i}$ is electrical power of generator i .

System accelerating power is distributed to all generators in the system according to machine inertia as

$$P_{e,i} = P_{e,i} - P_{acc,sys} \left(\frac{H_i}{H_{sys}} \right) \quad (3)$$

where H has units of $MW \cdot s$.

The new value for $P_{e,i}$ is used in the next power flow solution for each generator. If the difference between expected and resulting power supplied by the slack generator is larger than a set slack tolerance, the difference is redistributed according to (3) until the resulting difference is below the slack tolerance, or a maximum number of iterations take place[5].

III. Implementation of Deadbands

FERC requirements for governor droop and deadband are 5% and 36 mHz respectively[6]. However, practical implementation is left to generator operators.

A. Types of Deadbands

Fig. 2 presents implementations of deadbands that follow FERC requirements. If a governor has no deadband, a change in output power is requested for any frequency deviation. A step deadband ignores any frequency smaller than the setpoint $\pm db_1$ and then steps to meet the set droop curve. A no-step deadband pushes the original droop curve away from the nominal frequency allowing for the droop curve to cross zero at $\pm db_2$ but never return to the step or no deadband droop curve. A non-linear deadband is introduced that linearly increases from $\pm\alpha$ to $\pm\beta$, after which it follows the original droop curve.

IV. Simulation Validation

To validate the chosen simulation approach, identical system perturbances were performed in the PSLF Dynamic Subsystem (PSDS) and PSLTDSim. Frequency was compared to validate the single system frequency assumption calculated by PSLTDSim, and governed generator mechanical power was compared to validate governor action.

Comparison of frequency data from PSDS to LTD was simplified by calculating a single weighted PSDS




Fig. 2. Different types of deadbands.

frequency f_w based on generator inertia. In a system with N generators

$$f_w = \sum_{i=1}^N f_i \frac{H_{PU,i} M_{base,i}}{H_{sys}} \quad (4)$$

$$\text{where } H_{sys} = \sum_{i=1}^N H_{PU,i} M_{base,i}. \quad (5)$$

A. The MiniWECC System

The power system used for validation and valve travel experiments, the miniWECC shown in Fig. 3, is a 120 bus 34 generator system created in PSLF. All 21 governors in the miniWECC are modeled with the tgov1 which enabled easier validation. Further details about the creation and use of the miniWECC may be found in [7]–[9].

1) Load Step Results: A 400 MW load step was simulated to occur at 2 seconds. As shown in Fig. 4, all individual PSDS frequencies begin to oscillate after the perturbation while the weighted PSDS frequency appears to follow the general center of oscillation. The LTD system frequency is less oscillatory than the weighted frequency with only minor differences between the two. Fig. 9 quantifies these frequency differences.

When comparing mechanical power in Fig. 6, large MW differences can be seen, however, the percent difference data in Fig. 7 shows results less than 5% max difference, and an average percent difference of less than $\approx 0.5\%$.

2) Load Ramp Results: Simulation results from a 40 second 400 MW load ramp in Figs. 8-9 show frequency of LTD being within 1.5 mHz of PSDS. Fig. 10 shows mechanical power differences of less than ± 10 MW or, as Fig. 11 shows, 1% difference max.

B. Validation Summary

The step test results show that PSLTDSim is not meant to simulate large transient events with great accuracy.




Fig. 3. MiniWECC system adapted from [9].




Fig. 4. Comparison of frequency during load step.




Fig. 5. Absolute difference of weighted frequency during load step.

However, repeated small perturbances are modeled with acceptable deviation from transient simulation methods.

V. Initial Results

Thirty minutes of random load noise was applied to the system where every governor in the system had an identical deadband. Each type of deadband shown in Fig. 2 was simulated. An experiment was also conducted to




Fig. 6. Difference of mechanical power during load step.




Fig. 7. Percent difference of mechanical power during load step.




Fig. 8. Comparison of frequency during load ramp.




Fig. 9. Absolute difference of weighted frequency during load ramp.

explore partial acceptance of the NERC recommendations presented in [2]. While PSLTDSim can model AGC, it was not enabled for these simulations.




Fig. 10. Difference of mechanical power during load ramp.




Fig. 11. Percent difference of mechanical power during load ramp.

A. System Modifications

The miniWECC system was modified to include three areas for simulation. PSLTDSim was used to set all area governor droops to 5%. Some governors were removed from the system so that only $\approx 20\%$ of generation capacity in each area had governor control.

B. System Noise Injection

Every time step, noise is injected into each load $P_{L,i}$ in the system according to

$$P_{L,i} = P_{L,i}(1 \pm N_Z \text{Rand}_i) \quad (6)$$

where N_Z represents the maximum amount of random noise to inject as a percent, and Rand_i is a randomly generated number between 0 and 1 inclusive. The decision to add or subtract noise is chosen by another randomly generated number. As described, (6) creates random walk behavior in load value that is representative of real power systems[3].

C. Noise Simulation Results

N_Z was set to 0.03 for all simulations. The change in system loading caused by the added noise is shown in Fig. 12. Fig. 13 shows the resulting system frequency for each type of deadband. The step deadband holds frequency almost exactly on the set deadband except when system loading decreases during minutes 7-11. The other deadband options maintain system frequency near their respective mHz setting until loading increases beyond a point near minute 17.




Fig. 12. Change in total system loading.




Fig. 13. System frequency response of various deadband scenarios.

The first three minutes of a single generators valve travel are shown in Fig. 14 to compare how different deadbands affect movement. A step deadband will send pulse train-esq control signals to the governor valve when system frequency is oscillating over the deadband. These repeated control pulses greatly increase valve travel over the more linear deadband options.




Fig. 14. Valve movement deadband comparisons.

Table I summarizes the valve travel for each generator in the system over the entire 30 minute simulation. A step type deadband has the largest total travel while the no-step deadband has the least.

TABLE I
Total valve travel for various deadband scenarios.

| Generator | Valve Travel [PU] | | | | |
|-----------|-------------------|-------|---------|-----------|----------------|
| | No DB | Step | No-Step | N-L Droop | No-Step Alt DB |
| 17 | 0.16 | 7.48 | 0.15 | 0.23 | 0.19 |
| 23 | 0.16 | 7.48 | 0.15 | 0.23 | 0.19 |
| 30 | 0.16 | 7.48 | 0.15 | 0.23 | 0.19 |
| 32 | 0.16 | 7.54 | 0.15 | 0.23 | 0.19 |
| 107 | 0.16 | 7.54 | 0.15 | 0.23 | 0.19 |
| 41 | 0.15 | 6.44 | 0.14 | 0.23 | 0.06 |
| 45 | 0.15 | 6.44 | 0.14 | 0.23 | 0.06 |
| 53 | 0.16 | 7.54 | 0.15 | 0.23 | 0.06 |
| 59 | 0.15 | 6.44 | 0.14 | 0.23 | 0.06 |
| Total: | 1.41 | 64.38 | 1.32 | 2.07 | 1.19 |

D. Partial Acceptance Simulation Results

To test partial acceptance of NERC deadband recommendations, all area deadbands were set to the no-step variety, but two of the three areas had a deadband of 16.6 mHz while the third was set to 36 mHz. The resulting system frequency is shown in Fig. 15.




Fig. 15. System frequency response to 0.03% load noise where no-step deadbands have different area settings.

As expected, the area with a larger deadband doesn't respond until after frequency drops below its deadband while the areas with smaller deadbands work to maintain frequency. Individual valve travel for each generator is shown in Table I under the 'No-Step Alt DB' column, and Fig. 16 shows average valve travel over time for each area. In this case, the governor valves with a smaller deadband travel three times more than those with a larger deadband.




Fig. 16. Average valve travel by area.

VI. Conclusion

PSLTDSim can be used to simulate long term dynamic events. Deadband configurations play a large role in dictating valve travel. A step deadband can lead to vastly increased valve travel compared to other, more linear, options. Smaller deadbands, as recommended by NERC, can reduce valve travel and help regulate frequency if adopted interconnection-wide. If only partial adoption of recommendations is made, machines with smaller deadbands will respond more than machines with larger deadbands.

Acknowledgment

This material is based upon work supported by the U.S. Department of Energy, Office of Science, Basic Energy Sciences, under Award Number DE-SC0012671.

References

- [1] G. Kou, P. Markham, S. Hadley, T. King, and Y. Liu, "Impact of governor deadband on frequency response of u.s. eastern interconnection," IEEE Transactions on Smart Grid, 2016.
- [2] NERC, "Frequency response initiative report," North American Electric Reliability Corporation, 2012.
- [3] C. W. Taylor and R. L. Cresap, "Real-time power system simulation for automatic generation control," IEEE Transactions on Power Apparatus and Systems, 1976.
- [4] E. Heredia, D. Kosterev, and M. Donnelly, "Wind hub reactive resource coordination and voltage control study by sequence power flow," IEEE, 2013.
- [5] M. Stajcar, "Power system simulation using an adaptive modeling framework," Master's thesis, Montana Tech, 2016.
- [6] FERC, "Essential reliability services and the evolving bulk-power system—primary frequency response," Federal Energy Regulatory Commission, Docket No. RM16-6-000 Order No. 842, Feb. 2018.
- [7] D. Trudnowski, "Properties of the dominant inter-area modes in the wecc interconnect," Montana Tech, 2012.
- [8] J. Sanchez-Gasca, M. Donnelly, R. Concepcion, A. Ellis, and R. Elliott, "Dynamic simulation over long time periods with 100% solar generation," Sandia National Laboratories, SAND2015-11084R, 2015.
- [9] R. Hallett, "Improving a transient stability control scheme with wide-area synchrophasors and the microwecc, a reduced-order model of the western interconnect," Master's thesis, Montana Tech, 2018.