

# Long-Term Simulation of Power System Dynamics using Time Sequenced Power Flows

Thad Haines

Montana Tech - Master's Thesis Research Project

February 5th, 2019

TODO:

What is LTD - why use it  
system assumptions/main methods of LTD  
goals of research/ code

TODO:


Overview of parts involved in simulation  
(sequence diagram)

other explanations about computery stuff:

ipy vs py?

flow chart of predicted work flow.





## EE554.sav test system:



Generators are identical.  
PSLF models have exciters.


+20 MW Load Step at  $t=2$

# System Response



+20 MW Load Step at  $t=2$


# Detailed Frequency Response




-20 MW Load Step at  $t=2$

# System Response


Real Power Generated




Generator Frequency



Generator Voltage




Reactive Power Generated




-20 MW Load Step at  $t=2$ 

# Detailed Frequency Response





## Proportional gain control of generator $P_M$







Entered into system via parsed text file:

```
# pgov1 busnum busnam basekv id : #9 mwcap droop k1
#!pgov1 21 "21" 22.00 "1 " : #9 mwcap=100.0 0.05 13.0
```





Dynamic model 'pgov1' experiment: -20 MW  $t=2$ , +30 MW  $t=32$

## pgov1 on Gen 1



Dynamic model 'pgov1' experiment: -20 MW  $t=2$ , +30 MW  $t=32$

## pgov1 on Gen 1 & Gen 2



- ▶ Much more work to do.
- ▶ Frequency effects should be accounted for in swing equation.
- ▶ Euler Integration tracks PSLF mean frequency well.
- ▶ Custom dynamic model implementation seems realizable.